



Certificate Reference: PurefoodsCroy sys2 July18

1 DETAILS OF THE CLIENT

Client: Purefoods Croydon
Address: 9 Spitefire Way CR0 4WD

2 DETAILS OF THE FIRE DETECTION AND ALARM SYSTEM

Installation Address: Purefoods Croydon, 9 Spitefire Way, Hawker Road, Croydon, CR0 4WD

Extent of the fire detection and alarm system covered by this certificate: 100% of the installation.

The installation is: New ☒ An alteration ☐ N/A ☐ An extension ☐ N/A ☐

3 INSPECTION AND TESTING OF WIRING SYSTEM(S)

Wiring has been tested in accordance with the recommendations of Clause 38 of BS 5839-1:2013.

Insulation resistance tests:

☒ Between conductors ☒ Between conductors and Earth ☒ Between conductors and screen, if any

Supply circuit(s) tests:

☒ Earth continuity ☒ Earth fault loop impedance

Test(s) required by manufacturer, if any:

☒ Maximum circuit resistance ☒ Other tests

4 SPECIFICATION

Specification against which system was installed:

Z1 office & escape route Z2 w/h top Z3 w/h middle Z4 w/h ground Z5 workshop

5 RELATED REFERENCE DOCUMENTS

Related reference documents and certificate numbers:

See cable route chart for cable runs and eol devices

6 CERTIFICATE OF INSTALLATION

I/we being the competent person(s) responsible (as indicated by my/our signatures below) for the installation of the fire detection and fire alarm system, particulars of which are set out below, CERTIFY that the said installation for which I/we have been responsible complies to the best of my/our knowledge and belief with the specification described below and with the recommendations of Section 4 of BS 5839-1:2013, except for the variations, if any, stated in this certificate.

Variations from the specification and/or Section 4 of BS 5839-1 (see BS 5839-1:2013, Clause 7):

None

The extent of liability of the signatory/signatories is limited to the work described above.

For the INSTALLATION of the system:

Name: Kevin Duffy Position: Qualified Supervisor Signature:  Date: 17/07/2017

7 DETAILS OF THE ELECTRICAL CONTRACTOR

Trading Title: LondonSparks

Address: Airport House
Purley Way
Croydon

Registration Number
(if applicable): 0035258

Telephone Number: 07850557684

Postcode: CR0 0XZ