

NO.	DELAY SEC	MESSAGES
1	N/A	MSG 1
2	N/A	DEVICE IN MANUAL MODE
3	N/A	HOLD BUTTON ACTIVE
4	N/A	MSG 4
5	N/A	RECIPE AUTO PRINT DISABLED
6	N/A	REPORT TICKET PRINTING
7	N/A	FLOW PID CONTROLLER IN MANUAL MODE
8	N/A	DRAIN COOLING TEMPERATURE PID CONTROLLER IN MANUAL MODE
9	N/A	MSG 9
10	N/A	MSG 10
11	N/A	PRESS "START" BUTTON TO RESUME RECIPE
12	N/A	MSG 12
13	N/A	MSG 13
14	N/A	MSG 14
15	N/A	MSG 15
16	N/A	MSG 16
17	N/A	FILL HOLD
18	N/A	EMPTY HOLD
19	N/A	SUPPLY TEMPERATURE HOLD
20	N/A	RETURN TEMPERATURE HOLD
21	N/A	RINSE CONDUCTIVITY HOLD
22	N/A	ALKALINE CONDUCTIVITY HOLD
23	N/A	ACID CONDUCTIVITY HOLD
24	N/A	ALKALINE INJECTION/MIX TIME HOLD
25	N/A	ACID INJECTION/MIX TIME HOLD
26	N/A	MSG 26
27	N/A	MSG 27
28	N/A	MSG 28
29	N/A	MSG 29
30	N/A	MSG 30
31	N/A	SEPARATOR TANK IN LOW LEVEL
32	N/A	LOW LEVEL RECOVERY IN PROGRESS
33	N/A	MSG 33
34	N/A	MSG 34
35	N/A	ALKALINE TANK LOW LEVEL
36	N/A	ACID TANK LOW LEVEL
37	N/A	MSG 37
38	N/A	MSG 38
39	N/A	MSG 39
40	N/A	NO START INTERLOCK
41	N/A	REMOTE STOP ENABLED
42	N/A	MSG 42
43	N/A	MSG 43
44	N/A	MSG 44
45	N/A	MSG 45
46	N/A	MSG 46
47	N/A	MSG 47
48	N/A	MSG 48