


REFER TO LIGHTING CONSULTANT'S DRAWINGS AND
ARCHITECTURAL RCPS FOR PUBLIC SPACE LIGHTING
LAYOUTS.

FOR PRICING PURPOSES, ASSUME THAT EACH UNIQUE FIXTURE TYPE WITHIN A SPACE SHALL ON A DEDICATED CONTROL ZONE (UNLESS OTHERWISE NOTED). PLUS ADDITIONAL ZONES FOR PRIMARY AND SECONDARY DAYLIGHT ZONES.

ASSUME EGRESS LIGHTING WITH BYPASS RELAYS FOR ALL LIGHTING IN THE PATH OF EGRESS.

GENERAL LIGHTING NOTES:

1. REFER TO DRAWING E0.00 FOR LEGEND, SYMBOLS AND GENERAL NOTES.
 2. REFER TO LIGHTING FIXTURE SCHEDULE ON DRAWING E7.30 SERIES FOR SPECIFICATION OF FIXTURES.
 3. REFER TO DRAWING E8.03 SERIES FOR LIGHTING CONTROL DRAWINGS.
 4. REFER TO ARCHITECTURAL FLOOR PLANS FOR EQUIPMENT LOCATIONS.
 5. REFER TO ARCHITECTS REFLECTED CEILING PLAN FOR EXACT LOCATION OF LIGHTING FIXTURE PRIOR TO INSTALLATION (TYPICAL).
 6. REFER TO ARCHITECTURAL ELEVATIONS FOR COORDINATION OF WALL MOUNTED FIXTURE LOCATIONS.
 7. LOCATION AND GROUPING ARRANGEMENT/ORIENTATION OF ALL SWITCHES SHALL BE COORDINATED WITH THE ARCHITECT, MECHANICAL EQUIPMENT, AND OTHER WALL-MOUNTED DEVICES PRIOR TO INSTALLATION.
 8. THE ELECTRICAL CONTRACTOR SHALL VERIFY ALL CEILING TYPES AND COORDINATE FIXTURE TRIMS PRIOR TO PURCHASE OF LIGHTING FIXTURES.
 9. THE ELECTRICAL CONTRACTOR SHALL FURNISH AND INSTALL ALL LIGHTING FIXTURES COMPLETE WITH MOUNTING HARDWARE.
 10. ALL EXIT SIGNS AND EMERGENCY EGRESS LIGHTING SHALL BE CONNECTED TO THE EMERGENCY GENERATOR.
 11. EMERGENCY EGRESS LIGHTING SHALL BE PROVIDED THROUGHOUT THE BUILDING TO ILLUMINATE ALL EGRESS CORRIDORS, LOBBIES, ETC. BRANCH CIRCUITS SHALL ORIGINATE FROM THE EMERGENCY GENERATOR. AREAS REQUIRING SUCH CONTROL OF EGRESS LIGHTING SHALL BE PROVIDED WITH BYPASS RELAYS. EMERGENCY BRANCH CIRCUIT CONDUCTORS ALL BE RUN IN SEPARATE DEDICATED CONDUITS WITH NO OTHER WIRING.
 12. UNDER NORMAL CONDITIONS, EMERGENCY LIGHTING SHALL FUNCTION LIKE THE NORMAL LIGHTING IN EACH SPACE. PROVIDE UL 924 LISTED DEVICE TO TURN EMERGENCY LIGHTS TO FULL BRIGHTNESS UPON LOSS OF NORMAL POWER, REGARDLESS OF CONTROL STATE.
 13. PROVIDE ALL REQUIRED MODULES, INTERFACES, NETWORK MANAGERS, AND CONTROL INTERCONNECTIONS AS REQUIRED BY THE MANUFACTURER(S) TO MEET THE SPECIFIED CONTROL INTENT.
 14. ALL LIGHTING FIXTURE LOCATIONS WITHIN A/V, IT, ELECTRICAL, AND MECHANICAL ROOMS SHALL BE COORDINATED WITH THE RESPECTING TRADES TO AVOID CONFLICTS WITH THE EQUIPMENT AND TO PROVIDE EVEN ILLUMINATION THROUGHOUT THE SPACE.
 15. COORDINATE THE LOCATION OF ALL EXIT SIGNS WITH INTERIOR SIGNAGE. INTERIOR SIGNAGE SHALL NOT BE OBSTRUCTED.
 16. FOR ELECTRIC PANEL LOCATIONS, REFER TO RESPECTIVE POWER FLOOR PLAN.
 17. EXIT SIGN DIRECTIONAL ARROWS SHALL BE AS INDICATED ON THE ELECTRICAL PLANS AND SHALL BE COORDINATED WITH THE ARCHITECTURAL PLANS AND REFLECTED CEILING PLANS.



KEY PLAN

ARCHITECT
TTE ASSOCIATES, INC.
ngress Street, Fifth Floor
Boston, MA 02210
617.895.1000

ASSOCIATE ARCHITECT
KPN ARCHITECTS
1800 Washington Blvd, Suite 414
Baltimore, MD 21230
443.682.7757

CIVIL
RK&K
700 East Pratt Street, Suite 500
Baltimore, MD 21202
410.728.2900

DSCAPE ARCHITECT
OLIN
John F. Kennedy Boulevard,
Suite 1900
Philadelphia, PA 19103
215.412.0000

STRUCTURAL
COLUMBIA ENGINEERING, INC.
6210 Old Dobbin Lane, Suite 150
Baltimore, Maryland 21045
410.992.9970

CAL TRANSPORTATION
F ASSOCIATES, INC.
1000 Brandywine Creek Plaza
Bala Cynwyd, PA 19004
610.667.1717

MEP
BR+A CONSULTING ENGINEERS
10 Guest Street, 4th Floor
Boston, MA 02135
617.254.0016

ARM & FIRE PROTECTION
PTY & ASSOCIATES
Charles Street, Suite 403
altimore, MD 21201
667-202-6036

AUDIO VISUAL & TELECOM
CONVERGENT TECHNOLOGIES
DESIGN GROUP
6501 York Road
Baltimore, MD 21212

SECURITY
ORTON TOMASETTI
Connecticut Ave, NW,
Suite 300
Washington, DC 20036

FOOD SERVICE
COLBURN GUYETTE
100 Ledgewood Place, Suite 104
Rockland, MA, 02370

410.532.2395

LDING ENCLOSURE
ON GUMPERTZ & HEGER
1625 Eye St NW
Suite 900

LEED
SUSTAINABLE DESIGN
CONSULTING
1432 K Street NW, 3rd Floor

ND & AIR QUALITY
RWDI
650 Woodland Rd.

VIBRATION & ACOUSTICS
COLIN GORDON ASSOCIATES
1350 Old Bayshore Hwy, Suite 799

W. Guelph, Ontario
Canada N1K 1B8
519.823.1311

Burlingame, CA 94010
415.570.0350

LIGHTING
ER MARANTZ STONE
est 19th Street, 6th Floor
ew York, NY 10011
212.691.3020

SITE LIGHTING
TILLETT LIGHTING DESIGN
ASSOCIATES
11 Hanover Square, 17th Floor
New York, NY 10005
212.766.0144

CAMPUS UTILITIES
AEI AFFILIATED ENGINEERS
200 International Circle, Suite 5888
Hunt Valley, MD 21030

LIFE SCIENCES BUILDING

600 N Broadway
Baltimore, MD 21205

JOHNS HOPKINS

LIGHTING RCP A - LEVEL 3

	Date:	OCTOBER 24, 2025
	Scale:	1/8" = 1'-0"
	Drawn By:	
	Designed By:	
	Checked By:	
	Proj. Mgr.:	
	Payette Job No.:	17480.00
	Cadd File:	
	Client Job No.:	J.170.24.4000

that these documents were prepared or
me, and that I am duly licensed
under the laws of the State of Maryland.

EL2.03A