


Operator Telephone Fax e-Mail

LEVEL 2 Existing / Calculation surfaces (results overview)



Scale 1:260

Calculation Surface List

No.	Designation	Туре	Grid	E _{av} [lx]	E _{min} [lx]	E _{max} [lx]	u0	E_{min}/E_{max}
1	214-CAD	perpendicular	24 x 18	328	206	402	0.626	0.511
2	201-Sale	perpendicular	17 x 12	352	228	426	0.649	0.536
3	202-Office	perpendicular	32 x 16	342	246	405	0.718	0.606
4	203-Office	perpendicular	18 x 6	355	231	432	0.651	0.535
5	204-Meeting	perpendicular	6 x 9	383	279	439	0.730	0.637
6	205-Meeting	perpendicular	7 x 11	356	237	431	0.667	0.551
7	212-Test Room	perpendicular	16 x 16	379	277	446	0.733	0.623
8	211-CAD	perpendicular	32 x 16	339	166	422	0.490	0.393
9	210-Office	perpendicular	16 x 16	358	252	434	0.705	0.581



Operator Telephone Fax e-Mail

LEVEL 2 Existing / Calculation surfaces (results overview)

Calculation Surface List

No.	Designation	Туре	Grid	E _{av} [lx]	E _{min} [lx]	E _{max} [lx]	u0	E _{min} / E _{max}
10	209-Conference	perpendicular	15 x 9	335	219	406	0.653	0.539
11	208-Cleaner	perpendicular	3 x 7	102	85	119	0.833	0.718
12	207-Resources	perpendicular	8 x 8	89	69	111	0.771	0.618
13	215-Office	perpendicular	16 x 16	330	240	394	0.727	0.609
14	216-Office	perpendicular	16 x 16	329	238	389	0.725	0.612
15	217-Office	perpendicular	8 x 9	333	253	390	0.758	0.648
16	224-Corridor North	perpendicular	40 x 7	150	71	190	0.471	0.372
17	227	perpendicular	4 x 8	125	101	155	0.809	0.655
18	219-Office	perpendicular	11 x 6	186	136	218	0.732	0.627
19	Stairs	perpendicular	6 x 16	7.22	6.44	7.56	0.891	0.851
20	218-Kitchen	perpendicular	17 x 11	377	249	436	0.661	0.571
21	223-Corridor West	perpendicular	4 x 19	223	151	298	0.678	0.507
22	222-Corridor South	perpendicular	50 x 6	245	162	324	0.659	0.498
23	225-Corridor East	perpendicular	16 x 64	163	126	245	0.771	0.515
24	226-Corridor Lockers	perpendicular	13 x 18	181	94	251	0.517	0.373
25	206-Lockers	perpendicular	8 x 8	122	72	150	0.593	0.481
26	220-Toilet	perpendicular	32 x 32	103	13	226	0.131	0.060
27	221-Toilet	perpendicular	16 x 16	104	14	194	0.132	0.071
28	213-Meeting	perpendicular	16 x 16	274	195	322	0.710	0.604
29	218- KitchenBenchtop	perpendicular	2 x 9	282	219	318	0.778	0.689
_								

Summary of Results

Type	Quantity	Average [lx]	Min [lx]	Max [lx]	u0	E_{min} / E_{max}
perpendicular	29	270	6.44	446	0.02	0.01