


Operator Telephone Fax e-Mail

Vinny (Office Lighting) / Calculation surfaces (results overview)



Scale 1:260

Calculation Surface List

No.	Designation	Туре	Grid	E _{av} [lx]	E _{min} [lx]	E _{max} [lx]	u0	E_{min}/E_{max}
1	214-CAD	perpendicular	24 x 18	604	403	821	0.668	0.491
2	201-Sale	perpendicular	17 x 12	501	278	695	0.555	0.400
3	202-Office	perpendicular	32 x 16	459	279	558	0.608	0.501
4	203-Office	perpendicular	18 x 6	478	286	572	0.599	0.500
5	204-Meeting	perpendicular	6 x 9	372	232	443	0.623	0.523
6	205-Meeting	perpendicular	7 x 11	353	203	443	0.577	0.459
7	212-Test Room	perpendicular	32 x 32	479	252	614	0.525	0.410
8	211-CAD	perpendicular	64 x 32	607	320	749	0.527	0.427
9	210-Office	perpendicular	16 x 16	330	174	420	0.527	0.413



Operator Telephone Fax e-Mail

Vinny (Office Lighting) / Calculation surfaces (results overview)

Calculation Surface List

No.	Designation	Туре	Grid	E _{av} [lx]	E _{min} [lx]	E _{max} [lx]	u0	E _{min} / E _{max}
10	209-Conference	perpendicular	15 x 9	329	170	422	0.516	0.402
11	208-Cleaner	perpendicular	3 x 7	155	131	181	0.843	0.723
12	207-Resources	perpendicular	8 x 8	133	94	170	0.703	0.550
13	215-Office	perpendicular	9 x 8	320	152	509	0.475	0.299
14	216-Office	perpendicular	32 x 32	432	227	625	0.526	0.363
15	217-Office	perpendicular	8 x 9	443	281	595	0.635	0.473
16	224-Corridor North	perpendicular	40 x 7	250	123	375	0.491	0.327
17	227	perpendicular	8 x 16	234	158	297	0.673	0.532
18	219-Office	perpendicular	11 x 6	339	269	389	0.793	0.691
19	Stairs	perpendicular	6 x 16	10	9.01	12	0.892	0.775
20	218-Kitchen	perpendicular	17 x 11	401	204	575	0.508	0.354
21	223-Corridor West	perpendicular	4 x 19	317	253	399	0.798	0.634
22	222-Corridor South	perpendicular	50 x 6	317	201	460	0.634	0.437
23	225-Corridor East	perpendicular	16 x 64	243	169	362	0.696	0.467
24	226-Corridor Lockers	perpendicular	13 x 18	276	118	354	0.429	0.334
25	206-Lockers	perpendicular	8 x 8	190	99	250	0.520	0.396
26	220-Toilet	perpendicular	32 x 32	268	157	373	0.585	0.420
27	221-Toilet	perpendicular	32 x 32	300	176	436	0.586	0.403
28	213-Meeting	perpendicular	16 x 16	375	229	476	0.611	0.481
29	218- KitchenBenchtop	perpendicular	2 x 9	351	255	400	0.726	0.637
Summary of Results								

Summary of Results

Type	Quantity	Average [lx]	Min [lx]	Max [lx]	u0	E_{min} / E_{max}
perpendicular	29	379	9.01	821	0.02	0.01