SOLAR PLANT 1: EXECUTIVE TECHNICAL REPORT

Smart Energy Grid Forecasting & Battery Energy Storage Optimization MVP | Date: October 30, 2026

TOTAL GENERATION	PEAK GENERATION	FORECAST ACCURACY	EST. DAILY SAVINGS	AVOIDED CO2	BESS CAPACITY
5,292.5	29.15	25.8%	₹9,114	50.5 T	2.0 MWh
MWh (34 Days)	MW AC Power	Daylight MAPE (LGBM)	Simulated tariff estimate	Tonnes/Day (CEA v19)	0.5 MW / 4h Duration

1. Executive Summary & Purpose

This report presents the consolidated technical, predictive, and economic evaluation of **Solar Plant 1** across a rigorous 4-week analytical workflow. The facility comprises 22 smart inverters interconnected with high-precision weather sensor suites, monitored continuously across 34 consecutive days at 15-minute granularity.


Key engineering objectives achieved in this MVP include:
• **High-Fidelity Feature Pipeline:** Feature extraction incorporating solar zenith geometry, direct/diffuse irradiance separation, and module thermal derating dynamics.
• **Production-Grade Forecasting:** Multi-model evaluation comparing Ridge Regression, LightGBM (GBDT), and Prophet additive models with daylight-filtered metrics and empirical 80%/95% statistical confidence intervals.
• **Substation Duck Curve Modeling:** Empirical net load computation capturing severe midday load depression and steep evening ramp rates.
• **Linear Programming Battery Arbitrage:** PuLP optimization of a 2.0 MWh / 0.5 MW BESS balancing Time-of-Use tariff spreads against cell degradation wear costs.
• **Weather Stress Resilience & Carbon Accounting:** Multi-scenario extreme-weather stress testing and operational CO2 offset accounting benchmarked against the Central Electricity Authority (CEA) Baseline Database Version 19.0.
Estimated financial results: Battery savings use simulated INR tariffs and are estimates, not actual bills or guaranteed savings.

Mandatory Regulatory & Analytical Disclaimers

1. Grid Emission Factor Provenance: CO2 avoidance estimates reflect operational marginal grid electricity displacement derived from the official Central Electricity Authority (CEA), Ministry of Power, Government of India 'CO2 Baseline Database for the Indian Power Sector' User Guide Version 19.0 (Published Dec 2024). The national weighted average emission factor is **0.716 kg CO2e/kWh** (thermal marginal: 0.820 kg CO2e/kWh). Calculations exclude cradle-to-grave module life-cycle assessment (LCA).
2. Substation Load Representation: Feeder demand is generated via a normalized IEEE synthetic load curve scaled to solar plant capacity, reflecting dual-peak commercial/residential grid demand. It illustrates Duck Curve dynamics and does not represent measured SCADA substation telemetry.
3. Economic Tariff Modeling: Financial results are estimated savings based on simulated Time-of-Use assumptions: off-peak ₹5.30/kWh (22:00–06:00), normal ₹6.70/kWh (10:00–18:00), peak ₹7.30/kWh (06:00–10:00 and 18:00–22:00). Battery wear is estimated at ₹0.50/kWh throughput and installation at ₹15,000/kWh. These are not actual utility tariffs or guaranteed savings.

2. Solar Generation & Meteorological Dynamics

Continuous 15-minute telemetry from Solar Plant 1 demonstrates robust diurnal generation characteristics, with peak generation reaching 29.15 MW AC during solar noon (11:30 - 13:00 local time). Target variable integrity has been enforced by isolating AC active power (kW) and excluding cumulative energy yield counters. Generation derating is driven primarily by module temperature escalation, which reaches up to 65°C under high irradiance, causing semiconductor efficiency loss of approximately -0.38%/°C above 25°C STC.



Key Meteorological Driver Correlations with AC Active Power


Meteorological / Physical Feature	Pearson Correlation (r)	Physical Significance & Impact
dc_power	1.000	Key operational and predictive feature.
sensor_irradiation	0.989	Primary radiant driver; near-unity linear correlation with photovoltaic active output.
module_temperature	0.955	Positive diurnal alignment with radiation; introduces negative thermal derating at extremes.
cos_zenith	0.934	Deterministic geometric solar position; sets diurnal generation envelope.
ghi	0.912	Global Horizontal Irradiance; strong global solar predictor from satellite/Open-Meteo.
solar_elevation_deg	0.876	Key operational and predictive feature.

3. Solar Generation Forecasting & Uncertainty Bounds

Day-ahead solar forecasting models were evaluated over out-of-sample test splits using chronologically split training and validation windows. To eliminate nocturnal distortion where actual and predicted generation are identically zero, performance metrics are strictly evaluated on **daylight periods** (actual AC power > 10 kW, normalized threshold 50 kW). Uncertainty intervals are statistically formulated from out-of-sample residual distributions (standard deviation σ), providing calibrated 80% (±1.28σ) and 95% (±1.96σ) prediction bounds clamped to physical plant nameplate boundaries [0, P_max].

Out-of-Sample Forecasting Model Benchmarks (Plant 1 Test Set)


Model Architecture	Daylight RMSE (kW)	Daylight MAE (kW)	Daylight MAPE (%)	Daylight R^2 Score
Ridge Regression (Baseline)	125.21	86.61	22.9%	0.868
LightGBM (GBDT)	152.31	105.25	25.8%	0.804
XGBoost (GBDT)	158.32	109.81	27.4%	0.789
Prophet (Additive TS)	183.24	136.11	47.4%	0.717
Persistence (24h Lag)	242.15	170.60	41.2%	0.506
XGBoost (GBDT)	159.02	104.73	33.5%	0.697
Ridge Regression (Baseline)	159.09	103.70	34.8%	0.696
LightGBM (GBDT)	163.44	106.75	34.1%	0.679
Prophet (Additive TS)	225.15	150.96	55.1%	0.392
Persistence (24h Lag)	302.94	199.05	62.4%	-0.101



4. Substation Duck Curve & Grid Ramp Dynamics

High-penetration solar generation significantly transforms distribution feeder load characteristics. During midday peak irradiation hours (10:00 to 14:00), abundant solar power floods the local network, causing substantial **net load depression** (the 'belly' of the Duck Curve). As the sun sets between 17:00 and 20:00, solar generation abruptly collapses while residential and commercial demand surges, resulting in severe **ramp rates** (the 'neck' of the Duck Curve) that stress conventional thermal peaker plants.


Metric Description	Measured Feeder Value	Operational Impact on Distribution Grid
Peak Substation Demand	2.40 MW	Occurs during evening lighting/appliance peak (18:30 - 20:30 local).
Minimum Midday Net Load	-26.61 MW	Deep midday depression; risks over-voltage and reverse power flow.
Max Evening Ramp Rate	+89.84 MW/h	Demands rapid thermal ramping or fast-acting battery discharge.
Max Morning Down-Ramp	-43.06 MW/h	Rapid thermal unit de-commitment required as solar production surges.



5. Battery Energy Storage Optimization (PuLP LP)

Battery Energy Storage System (BESS) scheduling is formulated as a constrained **Linear Program (LP)** solved to global optimality via PuLP. The mathematical objective maximizes net economic arbitrage revenue under dynamic Time-of-Use electricity tariffs while penalizing electrochemical cell degradation. Physical constraints enforce nameplate power ratings (0.5 MW), round-trip efficiency (90%), state-of-charge limits [10% - 90%], and strict simultaneous charge/discharge mutual exclusivity ($c_t \times d_t = 0$).

Parameter	Value & Unit	Operational & Economic Context
Usable Storage Capacity	2,000 kWh (2.0 MWh)	Utility-scale modular lithium iron phosphate (LFP) chemistry.
Maximum Power (C-rate)	500 kW (0.25C / 4h)	Symmetrical inverter charge and discharge continuous limit.
Round-Trip Efficiency	90.0% ($\eta_c = \eta_d = 94.87\%$)	Combined inverter and electrochemical cell conversion loss.
Operational SoC Envelope	10.0% Min — 90.0% Max	Preserves cell cathode longevity by avoiding deep depletion/overcharge.
Cell Degradation Wear Cost	₹0.50 / kWh throughput	Illustrative pack capital cost (₹15,000/kWh across 5,000 equivalent cycles).
Estimated Savings (Simulated Tariffs)	₹9,114 / day	Throughput: 3,204 kWh/day; 100% mutual exclusivity verified.





6. Extreme-Weather Stress Testing & Carbon Accounting

To evaluate operational resilience under climate anomalies, the forecasting models and battery dispatch pipeline were subjected to six calibrated extreme-weather stress scenarios: **Normal Baseline**, **Heavy Cloud Cover**, **Monsoon Prolonged Low-Irradiance**, **Sudden Ramp Drop**, **Multi-Day Persistent Low**, and **Post-Storm Rapid Recovery**. Avoided greenhouse gas emissions are rigorously calculated according to Central Electricity Authority (CEA) guidelines.

Weather Scenario	Solar Gen (MWh)	Ridge RMSE	LGBM RMSE	BESS Savings	Grid Dep %
Normal Baseline Conditions	130.3	3860.6	3590.8	₹1,584	47.9%
Heavy Cloud Cover Overcast	65.2	1761.9	6197.2	₹1,534	41.5%
Monsoon Prolonged Low-Irradiance	32.6	991.0	8356.2	₹1,406	29.5%
Sudden Midday Irradiance Drop	73.4	2672.6	6624.1	₹1,533	37.7%
Multi-Day Continuous Solar Deficit	52.1	1387.9	7060.1	₹1,523	38.3%
Post-Storm Rapid Solar Recovery	82.8	2532.7	6312.4	₹1,663	44.8%

Grid Emission Factor Baseline	Factor (kg/kWh)	Daily Storage CO2	Daily Total Offset	Annual Projected Offset
Clean / Low-Carbon Grid (0.50)	0.500	3.64 T	35.27 T	12,875 Tonnes
Official CEA Baseline 2024 (0.716)	0.716	5.21 T	50.51 T	18,437 Tonnes
CEA Thermal Marginal (0.820)	0.820	5.97 T	57.85 T	21,115 Tonnes
High-Coal Subcritical Grid (0.95)	0.950	6.92 T	67.02 T	24,462 Tonnes





Engineering Audit & Operational Roadmap: 1. Inverter Topology: Future releases should incorporate inverter-level string failure detection. 2. Satellite Cloud Vector Ingestion: High-resolution optical satellite vectors improve 15-minute ramp prediction. 3. Battery Degradation: Full Arrhenius electrochemical thermal models recommended for commercial BESS procurement.
Verification: Automated validation passed across Weeks 1-4 pipelines. Ready for production demonstration.