

Your Ref:
Our Ref: 21/04939/FUL



Rocco Homes (no 20) Ltd
c/o Mrs Sarah Hufford
Brooklyn Chambers
11 Goring Road
Worthing
BN12 4AP

10th November 2025

DECISION NOTICE

Dear Rocco Homes (no 20) Ltd

TOWN AND COUNTRY PLANNING ACT 1990.

PERMISSION FOR DEVELOPMENT

The London Borough of Lambeth hereby permits under the above mentioned Acts and associated orders the development referred to in the schedule set out below **subject to any conditions imposed** therein and in accordance with the plans submitted, save in so far as may otherwise be required by the said conditions.

In accordance with the statutory provisions your attention is drawn to the statement of Applicant's Rights and General Information attached.

Application Number: 21/04939/FUL **Date of Application:** 21.12.2021 **Date of Decision:** 10.11.2025

Proposed Development At: Havilland House And The Church Of St Anselm, 13 Sancroft Street London SE11 5UG

For: Demolition of Havilland House and the vestry of the Church of St Anselm. Redevelopment of the site involving erection of three storey building with roof top to provide a new church hall (Use Class F1/F2), including kitchen and ancillary spaces at ground floor and 9 residential units (Use Class C3) on the upper floors with communal roof terrace, together with the provision of cycle and refuse store and associated landscaping.

Approved Plans

prepared by RPS (November 2021); Topographical Survey prepared by Cadmap Ltd (02 March 2021); Transport Statement prepared by i-Transport (16 December 2021); Written Scheme of Investigation prepared by MOLA (21st June 2022); Pre Determination Evaluation Report prepared by MOLA (July 2022); Addendum to Internal Daylight Report prepared by MES Building Solutions (15 August 2022); Urban Greening Factor prepared by Lizard Landscape Design and Ecology (09 December 2021). Existing Drawings: 1916/PL2 01; 1916/PL2 02; 1916/PL2 03; 1916/PL2 04; 1916/PL2 05; 1916/PL2 06; Proposed Drawings: 1916/PL2 07; 1916/PL2 08; 1916/PL2 09E; 1916/PL2 11D; 1916/PL2 12D; 1916/PL2 13; 1916/PL2 14; 1916/PL2 15B; 1916/PL2 16A; 1916/PL2 17; 1916/PL2 18; 1916/PL2 19; 1916/PL2 20; 1916/PL2 21; 1916/PL1 03; 1916/PL1 04; LLD2507-ECO-FIG-001 REV 00; LLD2507-LAN-DWG-001 01; LLD2507-LAN-DWG-002 01; ITB16706-GA-001 Dated 04/03/2022; Construction

Lambeth Planning
PO Box 80771
London
SW2 9QQ

Telephone 020 7926 1180
www.lambeth.gov.uk
planning@lambeth.gov.uk

Site Layout Plan Received 14/03/2022. Air Quality Assessment prepared by Redmore environmental (18 March 2022); Air Quality Neutral Assessment prepared by Redmore environmental (8 November 2021); Arboricultural Implications Report prepared by SJA Trees (December 2021); Archaeological Desk Based Assessment prepared by MOLA (November 2021); Construction Management Plan prepared by Rocco Homes Ltd & Lima Construction Ltd (02 November 2021); Daylight & Sunlight Report prepared by MES Building Solution (December 2021); Design and Access Statement prepared by WAMM Consulting (December 2021); Ecological Impact Assessment prepared by Lizard Landscape Design (02 December 2021); Energy & Sustainability Statement prepared by MES Building Solutions (Dated July 2022); Environmental Noise and Impact Assessment prepared by Hann T (December 2021); Fire Statement prepared by Adam Kiziak (November 2021); Heritage Statement prepared by Turley (December 2021); Internal Daylight Report prepared by MES B (04 August 2022); Landscape Design Strategy prepared by Lizard Landscape Design and Ecology (09 December 2021); Odour Assessment prepared by Redmore environmental (14 December 2021); Planning Statement prepared by ECE Planning (December 2021); Statement of Community Benefit and Management prepared by North Lambeth Parish; Statement of Community Involvement prepared by ECE Planning (November 2021); Flood Risk Assessment and Sustainable Drainage Strategy Framework Delivery and Servicing Plan prepared by i-Transport (December 2021);

Conditions

1 The development to which this permission relates must be begun not later than the expiration of three years beginning from the date of this decision notice.

Reason: To comply with the provisions of Section 91(1)(a) of the Town and Country Planning Act 1990 and Section 51 of the Planning and Compulsory Purchase Act 2004.

2 The development hereby permitted shall be carried out in complete accordance with the approved plans and drawings listed in this decision notice, other than where those details are altered pursuant to the conditions of this planning permission.

Reason: For the avoidance of doubt and in the interests of proper planning

3 Prior to the commencement of above ground works, a schedule and details of the materials to be used in the external elevations (including RAL numbers where appropriate) shall be submitted to and approved in writing by the local planning authority. The submission shall include (but not be limited to) the following details:

- a) Material schedule of all facing materials (including windows); and
- b) Sample panel of the proposed brickwork, external walling and roofing to be built on site (including any fixings, mortars, bond) for inspection and approval. Pictures of the samples should be included as part of the material schedule. The samples should be available for inspection from the date the application is received.

The development hereby permitted shall be thereafter built in accordance with the approved details.

Reason: To ensure that the external appearance of the building is satisfactory (Policies Q2, Q5, Q7 and Q8 of the Lambeth Local Plan (2021)).

4 Notwithstanding the details shown on the drawings hereby approved, above ground works shall not commence until drawings showing all external construction detailing of the whole development have been submitted to and approved by the Local Planning Authority in writing.

- a) Details of windows and doors (1:20 scale elevations and larger scale 1:5 or 1:2 detailed cross sections);
- b) Detailed drawings at 1:10 scale (including sections) for all external construction details including brickwork and pointing, entrances, reveals, ledges, copings, cills and lintels, soffits, plant screening, vents and extracts, parapets and rain water goods, soil and waste pipes, handrails and guards rails; and
- c) Details of the screening of the proposed balustrades.

The development shall thereafter be carried out in accordance with the approved details.

Reason: To ensure the external appearance of the building is satisfactory and preserves or enhances the character or appearance of the Kennington Conservation Area and in the interest of visual amenity (Policies Q2, Q5, Q6, Q7, Q8, Q20, Q22 of the Lambeth Local Plan 2021).

5 Prior to above ground works a Delivery and Servicing Management Plan for (a) the residential and (b) the non-residential development shall be submitted to and approved in writing by the local planning authority. The use hereby permitted shall thereafter be operated in accordance with the approved details. The submitted details will include the following:

- a) frequency of deliveries to the site;
- b) frequency of other servicing vehicles such as refuse collections;
- c) dimensions of delivery and servicing vehicles;
- d) proposed loading and delivery locations; and
- e) a strategy to manage vehicles servicing the site.

Reason: To ensure that the delivery arrangements to the building as a whole are appropriate and to limit the effects of the increase in travel movements (Policy T7 Lambeth Local Plan 2021 and Policy T7 of the London Plan 2021).

6 The development hereby approved shall not commence until a Construction and Environmental Management Plan (CEMP) has been submitted to and approved in writing by the local planning authority. The CEMP shall include details of the following relevant measures:

- i. An introduction consisting of a demolition plan and construction phase environmental management plan, definitions and abbreviations and project description and location;
- ii. A description of management responsibilities;
- iii. A description of the construction and demolition programme which identifies activities likely to cause high levels of noise or dust;
- iv. Site working hours and a named person for residents to contact;
- v. Detailed Site logistics arrangements;
- vi. Details regarding parking, deliveries, and storage;
- vii. Details regarding dust and noise mitigation measures to be deployed including identification of sensitive receptors and ongoing monitoring;
- viii. Details of the hours of works and other measures to mitigate the impact of construction on the amenity of the area and safety of the highway network;
- ix. Communication procedures with the LBL and local community regarding key construction issues - newsletters, fliers etc.;
- x. Loading, unloading and storage of plant materials used in the development;
- xi The erection and maintenance of security hoarding / scaffolding affecting the highway if required; and
- xii Wheel washing facilities.

The construction shall thereafter be carried out in accordance with the details and measures approved in the CEMP for the related phase unless the written consent of the Local Planning Authority is received for any variation.

Reason: This is required prior to construction to avoid hazard and obstruction being caused to users of the public highway and to safeguard residential amenity during the whole of the construction period. (Policies T6 and Q2 of the Lambeth Local Plan 2021).

7 Prior to the occupation of the development hereby permitted, a Waste Management Strategy shall be submitted to and approved in writing by the local planning authority. The development hereby permitted shall be built in accordance with the approved details and shall thereafter be retained solely for its designated use. The use hereby permitted shall thereafter be operated in accordance with the approved Waste Management Strategy; this must include but not be limited to provision of internal overnight storage of glass waste and the proposed hours of waste collection. The Waste Management Strategy will align with the guide for architects and developers on waste and recycling storage and collection requirements submitted details and will include the management for the residential bin stores.

Reason: To ensure suitable provision for the occupiers of the development, to encourage the sustainable management of waste and to safeguard the visual amenities of the area (policies Q2 and Q12 of the London Borough of Lambeth Local Plan (2021)).

8 Prior to the occupation of the development hereby permitted, a Waste Management Strategy shall be submitted to and approved in writing by the local planning authority. The development hereby permitted shall be built in accordance with the approved details and shall thereafter be retained solely for its designated use. The use hereby permitted shall thereafter be operated in accordance with the approved Waste Management Strategy; this must include but not be limited to provision of internal overnight storage of glass waste and the proposed hours of waste collection. The Waste Management Strategy will align with the guide for architects and developers on waste and recycling storage and collection requirements submitted details and will include the management for the church hall bin stores.

Reason: To ensure suitable provision for the occupiers of the development, to encourage the sustainable management of waste and to safeguard the visual amenities of the area (policies Q2 and Q12 of the London Borough of Lambeth Local Plan (2021)).

9 The development hereby permitted shall incorporate security measures to minimise the risk of crime and to meet the specific security needs of the development in accordance with the principles and objectives of Secured by Design. Details of these measures shall be submitted to and approved in writing by the local planning authority prior to commencement of the above ground works and shall be implemented in accordance with the approved details prior to occupation.

Reason: To ensure that the development maintains and enhances community safety (Policy Q3 of the London Borough of Lambeth Local Plan (2021)).

10 Prior to occupation, a satisfactory Secured by Design inspection must take place. The resulting Secured by Design certificate shall be submitted to and approved by the local planning authority.

Reason: To ensure that the development maintains and enhances community safety (Policy Q3 of the London Borough of Lambeth Local Plan (2021)).

11 No demolition or development shall commence until full details of the proposed mitigation measures for impact on air quality and dust emissions, in the form of an Air Quality and Dust Management Plan (AQDMP), have been submitted to and approved in writing by the local planning authority. In preparing the AQMDP the applicant should follow the guidance on mitigation measures for medium risk sites (as a minimum) set out in Appendix 7 of the Control of Dust and Emissions during Construction and Demolition SPG 2014 for demolition, earthworks, construction and trackout. Both 'highly recommended' and 'desirable' measures should be included. The AQDMP can form part of the Construction Environmental Management Plan (CEMP). The AQDMP shall include the following for each relevant phase of work:

- o Site location plan including sensitive receptors within 50m of the site boundary;
- o Site layout and equipment plan;
- o A summary of work to be carried out;
- o Outcome of Air Quality And Dust Risk Assessment completed at application stage (AQDRA);
- o Proposed haul routes, location of site equipment including supply of water for damping down, source of water, drainage and enclosed areas to prevent contaminated water leaving the site;
- o Inventory and timetable of all dust and NOx air pollutant generating activities;
- o List of air quality emission and dust control measures to be implemented, appropriate to the site dust risk level as determined by the AQDRA (low, medium, high), as set out in the Dust and Emissions SPG;
- o Details of any fuel stored on-site;
- o Monitoring methods to be implemented;
- o Details of a trained and responsible person on-site for air quality (with knowledge of pollution monitoring and control methods, and vehicle emissions);
- o That construction machinery will meet London NRMM emissions standards;
- o Details of the use of on-road Ultra Low Emission Zone (ULEZ) compliant vehicles e.g. minimum Petrol/Diesel Euro 6 (AIR Index Urban NOx rating A, B) and Euro VI.

No demolition or development shall commence until all necessary pre-commencement measures described in the AQDMP have been put in place and set out on site. The demolition and development shall thereafter be carried out and monitored in accordance with the details and measures approved in the AQDMP.

Reason: Development must not commence before this condition is discharged to manage and mitigate the impact of the development on the air quality and dust emissions in the area and London as a whole, and to avoid irreversible and unacceptable damage to the environment (London Plan policy SI1, and the London Plan SPGs for Sustainable Design and Construction and Control of Dust and Emissions during Construction and Demolition).

12 If Non-Road Mobile Machinery (NRMM) of net power of 37kW and up to and including 560kW is required on site during the course of demolition, site preparation and construction phases, it must comply with the emission standards set out in chapter 7 of the GLA's supplementary planning guidance "Control of Dust and Emissions During Construction and Demolition" dated July 2014 (SPG), or subsequent guidance. Unless it complies with the standards set out in the SPG, no NRMM shall be on site, at any time, whether in use or not, without the prior written consent of the local planning authority. The developer must register all NRMM at <https://nrmm.london/user-nrmm/register> prior to bringing it on to site and shall keep the register up to date by listing all NRMM used during the demolition, site preparation and construction phases of the development.

Reason: To ensure that air quality is not adversely affected by the development in line with London Plan policy 7.14 and the Mayor's SPG: The Control of Dust and Emissions During Construction and Demolition.

13 Fire Statement

Prior to the commencement of above ground works, an updated Fire Statement shall be submitted to and approved in writing by the Local Planning Authority. The updated Fire Statement shall be produced by an independent third party suitably qualified assessor which shall include the following information:

- 1) identify suitably positioned unobstructed outside space:
 - a) for fire appliances to be positioned on
 - b) appropriate for use as an evacuation assembly point
- 2) the development has been designed to incorporate appropriate features which reduce the risk to life and the risk of serious injury in the event of a fire; including appropriate fire alarm systems and passive and active fire safety measures
- 3) the development has been constructed in an appropriate way to minimise the risk of fire spread
- 4) the development provides suitable and convenient means of escape, and associated evacuation strategy for all building users
- 5) a robust strategy for evacuation which can be periodically updated and published, and which all building users can have confidence in
- 6) details of suitable access and equipment for firefighting which is appropriate for the size and use of the development.

The development shall be carried out in accordance with the approved details.

Reason: Development must not commence until this condition is discharged in order to provide a fire-safe development for occupiers (Policy D12 of the London Plan 2021).

14 No development should take place until an updated Flood Risk Assessment (including a Management and Maintenance Plan) for the site has been submitted and approved by the Local Planning Authority. The Flood Risk Assessment shall be managed and maintained thereafter in accordance with the agreed management and maintenance plan.

Reason: To manage the water environment of the development and mitigate the impact on flood risk, water quality, habitat and amenity value (policies EN5 and EN6 of the London Borough of Lambeth Local Plan (2021)).

15 No development above ground shall commence on site until a detailed design for the surface water drainage system and associated pipework presented in the Flood Risk Assessment (Document: Flood Risk Assessment and Sustainable Drainage Strategy - dated 14/12/2021) has been submitted to and approved in writing by the Local Planning Authority. The scheme for the surface water drainage shall be carried out in accordance with the approved details before the development is first put in to use/occupied. The application must also provide evidence of the surface water management system's capability to manage its 1% Annual Exceedance Percentage (AEP) event critical storm with an appropriate climate change factor, including the whole site area in the calculations. Detail of the exceedance flow paths of the final drainage system must also be provided.

Reason: To ensure the development is provided with a satisfactory means of drainage and in the interests of securing a more sustainable development and to reduce the impact of flooding both to and from the development and third parties in accordance with London Plan (2021) and Policy EN6 of the Lambeth Local Plan (2021).

16 No piling shall take place until a Piling Method Statement (detailing the depth and type of piling to be undertaken and the methodology by which such piling will be carried out, including measures to prevent and minimise the potential for damage to subsurface sewerage infrastructure, and the programme for the works) has been submitted to and approved in writing by the local planning authority in consultation with Thames Water. Any piling must be undertaken in accordance with the terms of the approved piling method statement.

Reason: The proposed works will be in close proximity to underground sewerage utility infrastructure. Piling has the potential to significantly impact / cause failure of local underground sewerage utility infrastructure.

17 The use hereby permitted shall not commence until details and full specifications of kitchen fume extraction and filtration equipment, and ongoing maintenance plan, have been submitted to and approved in writing by the local planning authority. The scheme of odour control and filtration shall be designed to mitigate high levels of odour as identified by the EMAQ odour assessment reported by Redmore Environmental report Reference: 5035-1r3 dated 14th December 20221 and the use hereby permitted shall not commence until the approved details are fully implemented. The approved fume extraction and filtration equipment shall thereafter be retained and maintained in working order for the duration of the use in accordance with the approved details.

Reason: To ensure that no nuisance or disturbance is caused to the detriment of the amenities of future residential occupiers or of the area generally (Policy Q2 (Amenity) - Lambeth Local Plan 2021).

18 Plant Noise Assessment

Prior to commencement of construction, a scheme of assessment of the acoustic impact arising from the operation of all internally and externally located plant shall be submitted to and approved in writing by the local planning authority. The assessment of the acoustic impact shall be undertaken in accordance with BS 4142: 2014 (or subsequent superseding equivalent) and other relevant measures, and shall include a scheme of attenuation measures to ensure the rating level of noise emitted from the proposed building services plant is 5dBA less than background.

The use hereby permitted, or the operation of any building services plant, shall not commence until a post-installation noise assessment has been carried out including suitable measurements to confirm compliance with the approved noise criteria and submitted to and approved by the planning authority. The scheme shall be implemented in accordance with the approved details and attenuation measures, and they shall be permanently retained and maintained in working order for the duration of the use and their operation.

Reason: To protect the amenities of adjoining occupiers and the surrounding area (policy Q2 of the London Borough of Lambeth Local Plan (2021)).

19 Noise Management Plan

Prior to any use of the outside garden area hereby approved a Noise Management Plan must be submitted to and approved in writing by the Local Planning Authority. The plan should include but not be limited to, management responsibilities during all operating hours, measures to control noise and disturbance, playing of music or other amplified sound and actions to minimise the adverse effects from users of the garden particularly for organised activities on Saturdays and Sundays. Where any management practices give rise to complaints of a substantiated and significant impact on local amenity received by the operator or London Borough of Lambeth, this must be brought to the attention of the Local Planning Authority and any necessary changes to the management plan implemented to the satisfaction of the Local Planning Authority.

Reason: To protect the amenities of adjoining occupiers and the surrounding area (policy Q2 of the London Borough of Lambeth Local Plan (2021)).

20 Prior to the first occupation of the development hereby permitted, a scheme for the siting and design of all boundary treatments and gates shall be submitted to and approved in writing by the local planning authority. The details shall be submitted at 1:10 scale drawings and include fixings, hinges, latches and other details. The approved scheme shall be fully implemented before the use hereby permitted commences and retained for the duration of the development.

Reason: In order to ensure high quality landscaping for the boundaries of the site in the interests of visual amenity (Policies Q6 and Q15 of the London Borough of Lambeth Local Plan (2021)).

21 No demolition or development shall take place that will cause ground disturbance until an updated written scheme of investigation (WSI) has been submitted to and approved by the local planning authority in writing. For land that is included within the WSI, no demolition or development shall take place other than in accordance with the agreed WSI, which shall include the statement of significance and research objectives, and

A. The programme and methodology of site investigation and recording and the nomination of a competent person(s) or organisation to undertake the agreed works

B. The programme for post-investigation assessment and subsequent analysis, publication & dissemination and deposition of resulting material. This part of the condition shall not be discharged until these elements have been fulfilled in accordance with the programme set out in the WSI.

Reason: To ensure that the proposal is in accordance with Policy Q23 of the Lambeth Local Plan 2021, Policy HC1 of the London Plan 2021 and the NPPF 2021.

22 No development shall take place until details of the public engagement framework pertaining to the site's geo/archaeological program of work have been submitted and approved in writing by the local planning authority. The development shall be carried out in accordance with the approved details.

Reason: To secure public value in respect of the site's geo/archaeological interest in accordance with the NPPF paragraph 205.

23 No development shall take place until details of the foundation design and construction method to protect archaeological remains have been submitted and approved in writing by the local planning authority. The development shall be carried out in accordance with the approved details.

Reason: To secure physical preservation of the site's archaeological interest in accordance with the NPPF.

24 No development above ground shall take place until a specification of all proposed soft landscaping and tree planting has been submitted to and approved in writing by the Local Planning Authority. The specification shall include details of the quantity, size, species, position and the proposed time of planting of all trees and shrubs to be planted, together with an indication of how they integrate with the proposal in the long term with regard to their

mature size and anticipated routine maintenance and protection. The specification also shall include details of the green screening infrastructure around the nursery outdoor play area and outdoor communal spaces. In addition, all shrubs and hedges to be planted that are intended to achieve a significant size and presence in the landscape shall be similarly specified. All tree, shrub and hedge planting included within the above specification shall accord with BS3936:1992, BS4043:1989, BS4428:1989, BS8545:2014 and current Arboricultural best practice.

The details should demonstrate that a net biodiversity gain has been achieved in accordance with the Environmental Impact Assessment prepared by Lizard Landscape Design and Ecology (02 December 2021).

Reasons: In order to introduce high quality soft landscaping in and around the site in the interests of the ecological value of the site and to ensure a satisfactory landscaping of the site in the interests of visual amenity (Policy EN1, Q2, Q9 of the Lambeth Local Plan (2021) and G7 of the London Plan (July 2021)).

25 Prior to commencement of the construction works above ground of the relevant Building of the development hereby permitted, a detailed specification of the biodiverse green roofs shall be submitted to and approved in writing by the Local Planning Authority. The specification shall include details of the quantity, size, species, position and the proposed time of planting of all elements of the green roofs, together with details of their anticipated routine maintenance and protection. The green roofs shall be implemented prior to occupation of the relevant Building and thereafter maintained in accordance with the approved details for the lifetime of the development.

Reason: In order to promote biodiversity and rainwater attenuation on the site. (Policy G1, G5, SI 2 and SI 13 of the London Plan (2021) and Policy EN1, EN4, EN5, EN6 and Q9 of the Lambeth Local Plan (2021)).

26 All planting, seeding or turfing comprised in the approved details of landscaping shall be carried out in the first planting and seeding season following the occupation of the development hereby permitted or the substantial completion of the development, whichever is the sooner. Any trees, hedgerows or shrubs forming part of the approved landscaping scheme which within a period of five years from the occupation or substantial completion of the development die, are removed or become seriously damaged or diseased shall be replaced in the next planting season with others of similar size and species, unless the Local Planning Authority gives written consent to any variation.

Reasons: In order to introduce high quality soft landscaping in and around the site in the interests of the ecological value of the site and to ensure a satisfactory landscaping of the site in the interests of visual amenity (Policy EN1, Q2, Q9 of the Lambeth Local Plan (2021) and G7 of the London Plan (July 2021)).

27 Urban Greening Factor

Prior to above ground works, specification for green infrastructure shall be submitted to and approved in writing by the local planning authority, to achieve an urban greening factor of 0.4 or more on the site. The specification shall demonstrate that all reasonable endeavors have been made to achieve this target and justification should be provided should this target not be met. The development shall not be carried out other than in accordance with the approved details

Reason: To ensure that the development has an acceptable level of sustainability (London Plan Policy G5).

28 Prior to commencement of the development. An Energy Statement compliant with Lambeth Local Plan policies and London Plan policies shall be submitted to and approved in writing by the local planning authority. The report should additionally contain:

- A commitment to 'Be Seen' reporting requirements as per the 'Be Seen' energy monitoring guidance, GLA, Sept 2021.
- Evidence that the heat pump specified complies with the minimum performance standards as set out in the Enhanced Capital Allowances (ECA) product criteria for the relevant ASHP technology as well as evidence that the heat pump complies with other relevant issues as outlined in the Microgeneration Certification Scheme Heat Pump Product Certification Requirements document at: <http://www.microgenerationcertification.org>
- Dynamic overheating modelling in line with the guidance and data sets in CIBSE TM59 and TM49 respectively in keeping with Energy Assessment Guidance, GLA, June 2022.

Reason: To ensure that the development makes the fullest contribution to sustainability (Policy SI 2 and SI 3 of the London Plan (2021) and Policy EN3 of the Lambeth Local Plan (2021))

29 As Built SAP

Prior to first occupation of the development As Built SAP calculations and Block Compliance sheet as an output of the National Calculation Method should be submitted to and approved in writing by the Local Planning Authority

demonstrating that the scheme has achieved a minimum of 35% reduction in carbon emissions over that required by Part L of the Building Regulations 2013, in line with the approved Energy Statement.

Reason: To ensure that the development has an acceptable level of sustainability (policy EN4 of the London Borough of Lambeth Local Plan (2021)).

30 Prior to occupation of the development As Built SBEM calculations should be submitted to and approved in writing by the Local Planning Authority demonstrating that 35% reductions in carbon emissions over Building Regulations Part L 2013 have been achieved, in line with the approved Energy Statement.

Reason: To ensure that the development has an acceptable level of sustainability (policy EN4 of the London Borough of Lambeth Local Plan (2021)).

31 Prior to commencement of the development, for the residential dwellings, satisfactory dynamic overheating modelling in line with the guidance and data sets in CIBSE TM59 and TM49 respectively in keeping with Energy Assessment Guidance, GLA, June 2022 should be submitted to and approved in writing by the Local Planning Authority. This should provide evidence of how the development performs against the overheating criteria along with an outline of the assumptions made in the energy assessment. It is expected that the CIBSE compliance criteria is met for the DSY1 weather scenario.

Reason: To ensure that the development has an acceptable level of sustainability (policy EN4 of the London Borough of Lambeth Local Plan (2021) and SI4 of the London Plan 2021).

32 Prior to the occupation of the development, calculations (and manufacturer's datasheets) should be submitted to and approved in writing by the Local Planning Authority which shows how water consumption rates of less than 105 litres per person per day have been achieved.

Reason: To minimise the consumption of water in homes (policy EN4 of the London Borough of Lambeth Local Plan (2021) and SI5 of the London Plan 2021).

33 Prior to the commencement of above ground works, calculations (and manufacturer's datasheets) should be submitted to and approved in writing by the Local Planning Authority which shows how water consumption in the non-residential spaces achieves the BREEAM Wat 01 Excellent standard (12.5% improvement over the baseline). Prior to commencement of the development, details should be submitted to and approved in writing by the Local Planning Authority to show how the scheme proposes to incorporate measures such as smart metering, water saving and recycling measures to help to achieve lower water consumption rates and to maximise future-proofing.

Reason: To minimise the consumption of water in homes (policy EN4 of the London Borough of Lambeth Local Plan (2021) and SI5 of the London Plan 2021).

34 Prior to the occupation of the residential units hereby approved, a Community Management and Maintenance Plan shall be submitted to and approved in writing by the Local Planning Authority. The Community Management and Maintenance Plan should set how the hall will be used, maintained and managed upon occupation including St Anselm's church.

The community hall thereafter shall only be operated in accordance with the approved Community Management and Maintenance Plan, unless the written consent of the Local Planning Authority is received for any variation.

Reason: To ensure an on-going quality of development for the community and to protect the amenity of adjoining residents (Policies S2 and Q2 of the Lambeth Local Plan 2021).

35 A set of annotated exterior record photographs of the exterior of both buildings (St Anselm's Church and Havilland House), including the interior of the church vestry, accompanied by a plan showing the photograph locations, shall be submitted to the London Historic Environment Record prior to the commencement of demolition on the site.

Reason: To ensure the external appearance of the building is satisfactory and preserves or enhances the character or appearance of the listed building and Kennington Conservation Area and in the interest of visual amenity (Policies Q2, Q5, Q6, Q7, Q8, Q20, Q22 of the Lambeth Local Plan 2021).

36 Notwithstanding details shown on the approved plans, no occupation of the residential parts of the development shall commence until full details of the children's play space provisions (including a minimum area of 23sqm, layout, equipment specification, and phasing of delivery) have been submitted to and approved in writing by the local planning authority and the development has been implemented in accordance with the approved

details and agreed phasing. The children's play areas shall be maintained for the duration of the development and available for all occupiers irrespective of tenure.

Reason: To ensure appropriate provision for children's play on site. (Policy S4 of the London Plan (2021) and Policy H5 of the Lambeth Local Plan (2021)).

37 The property number and name shall be permanently displayed at the street entrance of the block.

Reason: To safeguard the visual amenities of the area (policies Q2 and Q9 of the London Borough of Lambeth Local Plan (2021)).

38 a) Prior to the commencement of the development hereby approved, a BREEAM Pre-Assessment shall be submitted and approved in writing by the Local Planning authority. This should clearly identify the credits to be targeted and detailing how BREEAM 'Excellent' will be achieved. If the Pre-Assessment demonstrates that it is not possible to achieve an 'Excellent' standard, clear justification shall be provided to demonstrate why the standard targeted is the maximum that can be achieved given the constraints of the site.

b) Within six months of work starting on site of the development hereby permitted, a BREEAM New Construction 2018, Fully Fitted, Design Stage (Interim) certificate and summary score sheet shall be submitted to and approved in writing by the local planning authority to show that the BREEAM standard targeted in part (a) above has been achieved for the whole new build development.

c) Within six months of occupation of the development hereby permitted, a BREEAM New Construction 2018, Fully Fitted, Post Construction Review (Final), certificate and summary score sheet shall be submitted to and approved in writing by the local planning authority to show that the BREEAM standard targeted in part (a) above has been achieved for the whole new build development.

Reason: To ensure that the development has an acceptable level of sustainability (Policy EN4 of the Lambeth Local Plan (2021) and Policy SI 2 of the London Plan (2021)).

Notes to Applicants:

In dealing with this application the Council has acted in line with the National Planning Policy Framework to work with the applicant in a positive and proactive manner. The council has made available on its website the policies and guidance provided by Lambeth Local Plan 2020-2035 (September 2021) and its supplementary planning documents. We also offer a full pre-application advice service in order to ensure that the applicant has every opportunity to submit an application that's likely to be considered acceptable.

1. This decision letter does not convey an approval or consent which may be required under any enactment, by-law, order or regulation, other than Section 57 of the Town and Country Planning Act 1990.

2. Your attention is drawn to the provisions of the Building Regulations, and related legislation which must be compiled with to the satisfaction of the Council's Building Control Officer.

3. Your attention is drawn to the provisions of The Party Wall Act 1996 in relation to the rights of adjoining owners regarding party walls etc. These rights are a matter for civil enforcement and, you may wish to consult a surveyor or architect.

4. Your attention is drawn to the need to comply with the requirements of the Control of Pollution Act 1974 concerning construction site noise and in this respect, you are advised to contact the Council's Environmental Health Division.

5. You are advised of the necessity to consult the Principal Highways Engineer of the Highways team on drw@lambeth.gov.uk in order to gain necessary prior approval for undertaking any works within the Public Highway including Scaffold, Temporary/Permanent Crossovers, Oversailing/Under-sailing of the Highway, Drainage/Sewer Connections and Repairs on the Highways, Hoarding, Excavations, Temporary Full/Part Road Closures, Craneage Licences etc. You are advised to contact the Highways team at the earliest possible opportunity.

<https://beta.lambeth.gov.uk/Business-rates-services-and-licensing/licensing-and-permits/Apply-change-or-pay-for-a-licence/Apply-for-a-highways-licence/application-fees-highways-licences>

6. A Groundwater Risk Management Permit from Thames Water will be required for discharging groundwater into a public sewer. Any discharge made without a permit is deemed illegal and may result in prosecution under the provisions of the Water Industry Act 1991. We would expect the developer to demonstrate what measures he will undertake to minimise groundwater discharges into the public sewer. Permit enquiries should be directed to Thames Water's Risk Management Team by telephoning 020 3577 9483 or by emailing trade.effluent@thameswater.co.uk. Application forms should be completed on line via

<https://eur03.safelinks.protection.outlook.com/?url=http%3A%2F%2Fwww.thameswater.co.uk%2F&data=04%7C01%7CKHayler%40lambeth.gov.uk%7C4f1f59f584a140b297e508d9dcfbd3f4%7Cc4f22780485f4507af4a60a971d6f7fe%7C0%7C637783796406411469%7CUnknown%7CTWfpbGZsb3d8eyJWljojMC4wLjAwMDAiLCJQIjoIV2luMzliLCJBTiI6lk1haWwiLCJXVCi6Mn0%3D%7C3000&sdata=oCxRhqbUNB9ltxwmr%2FSR9J9GrzkKJ>

yj6zJE2n1jMfs%3D&reserved=0. Please refer to the Wholesale; Business customers; Groundwater discharges section.

7. Thames Water will aim to provide customers with a minimum pressure of 10m head (approx 1 bar) and a flow rate of 9 litres/minute at the point where it leaves Thames Waters pipes. The developer should take account of this minimum pressure in the design of the proposed development.

8. The Refuse & Recycling Storage Design Guide (2022) can be viewed on the planning policy pages of the council's website.

9. The applicant needs to bear in mind that the application for road closure needs to be submitted 12 weeks in advance to avoid any delays to their programme. If road closure will be needed, the applicant needs to consult with the residents and businesses in advance via letter drops with TM plans and diversion routes, discuss this in residents group meetings if there is one and provide this evidence when applying for Temporary Traffic Regulation Order.

10. The Council strongly encourages the re-use, on site, of the Vestry railings. Should their alteration be required, details should be provided through the discharge of condition 20.

11. The Council will expect the materials to closely reflect locally distinct examples in the locality and complement those of St Anselm's church.

Community Infrastructure Levy (CIL)

This development may be chargeable for the Community Infrastructure Levy (CIL) if it provides one or more dwellings or provides more than 100m² of new-build floorspace. If this development is chargeable for CIL, the Council's CIL team will issue a CIL liability notice soon after the date of this permission.


The party liable for CIL must submit an assumption of liability notice and a notice of commencement prior to any material operation commencing this development. These notices must be submitted to cil@lambeth.gov.uk.

CIL will be normally due within 60 days of commencement of development. If the CIL liability is over £100,000, the CIL due may be paid in accordance with the Council's CIL instalment policy.

Please do not commence development before an assumption of liability notice and commencement notice is submitted, or if you will find it difficult to pay CIL within 60 days of commencement of development.

If you think your development might qualify for relief or exemption, please contact cil@lambeth.gov.uk and apply using the relevant exemption or relief form. Any application for exemption or relief lapses if works commence on the chargeable development prior to the notification of the decision on the exemption or relief claim. Failure to adhere to the CIL Regulations and commencing work without notifying the Council could forfeit any rights you have to appeal, pay in instalments and may also incur additional surcharges and late payment interest on top of your CIL liability.

Yours sincerely



Rob Bristow

Director of Planning, Transport and Sustainability
Climate and Inclusive Growth Directorate

Date printed: 10th November 2025

INFORMATION FOR APPLICANTS GRANTED PLANNING PERMISSION SUBJECT TO CONDITIONS, OR WHERE PERMISSION HAS BEEN REFUSED.

General Information

This permission is subject to due compliance with any local Acts, regulations, building by-laws and general statutory provisions in force in the area and nothing herein shall be regarded as dispensing with such compliance or be deemed to be a consent by the Council thereunder.

Your attention is drawn to the provisions of the Building Regulations 1985 and related legislation which must be complied with to the satisfaction of the Council's Building Control Officer, PO Box 80771, London SW2 9QQ.

The Council's permission does not modify or affect any personal or restrictive covenants, easements, etc., applying to or affecting the land or the rights of any person entitled to the benefits thereof.

STATEMENT OF APPLICANT'S RIGHTS ARISING FROM THE REFUSAL OF PLANNING PERMISSION OR FROM THE GRANT OF PERMISSION SUBJECT TO CONDITIONS.

Appeals to the Secretary of State

If the applicant is aggrieved by the decision of the local planning authority to refuse permission or approval for the proposed development or to grant permission or approval subject to conditions, he may appeal to the Secretary of State in accordance with Section 78 of the Town and Country Planning Act 1990 within six months from the date of this notice. Appeals must be made on a form which is obtainable from The Planning Inspectorate, Room 3/13 Temple Quay House, 2 The Square, Temple Quay, Bristol BS1 6PN. Alternatively an Appeal form can be downloaded from their website at <https://www.gov.uk/appeal-planning-decision>. The Secretary of State has power to allow longer period for the giving of a notice of appeal but he will not normally be prepared to exercise this power unless there are special circumstances which excuse the delay in giving notice of appeal. The Secretary of State is not required to entertain an appeal if it appears to him that permission for the proposed development could not have been granted by the local planning authority, or could not have been so granted otherwise than subject to the conditions imposed by them, having regard to the statutory requirements, to the provisions of the development order, and to any directions given under the order.

Purchase Notice

If permission to develop land is refused or granted subject to conditions, whether by the local planning authority or by the Secretary of State for the Environment, and the owner of the land claims that the land has become incapable of reasonably beneficial use in its existing state and cannot be rendered capable of reasonable beneficial use by the carrying out of any development which has been or would be permitted, he may serve on the London Borough of Lambeth a purchase notice requiring that Council to purchase his interest in the land in accordance with the provisions of Section 137 of the Town and Country Planning Act 1990.

Compensation

In certain circumstances, a claim may be made against the local planning authority for compensation, where permission is refused or granted subject to conditions by the Secretary of State for the Environment on appeal or on a reference of the application to him. The circumstances in which such compensation is payable are set out in Section 120 and related provision of the Town and Country Planning Act 1990.