

Target: Ernakulam Brahmapuram 220kV Engineering Workstation (EWS)

Scan Type: SCADA Cyber Incident - OPC-UA Authentication Bypass OS Details: Embedded Linux RTOS / Substation PLC

Open Ports: 4

Vulnerabilities: 2

DYNAMIC RISK ASSESSMENT

RISK INDEX: 78.0 / 100 (HIGH)

Attack Classifications: Weak Authentication

DISCOVERED NETWORK SERVICES

PORT	PROTOCOL	STATE	SERVICE	VERSION
502	TCP	open	modbus	Modbus SCADA Gateway
104	TCP	open	iec-104	IEC 60870-5-104 Telemetry

DETECTED CVE VULNERABILITIES

- CVE-2022-0941 | CVSS: 9.1 | Severity: HIGH

Description: Anonymous certificate validation exploit attempting unauthorized read/write access to SCADA Historian tag data.

DARKON AI THREAT INTELLIGENCE & REMEDIATION

Darkon AI detected OPC-UA Authentication Bypass targeting Ernakulam Brahmapuram 220kV Engineering Workstation (EWS) in district Ernakulam.

- Block source IP 198.199.83.162 on Industrial Security Firewall.
- Isolate PLC communication interface on target substation.
- Enforce IP Whitelisting for Port 502 / Port 104.