

Target: Kozhikode Kuttiyadi Hydro 220kV Remote Terminal Unit (RTU)

Scan Type: SCADA Cyber Incident - IEC 60870-5-104 Telemetry Flood OS Detected: Embedded Linux RTOS / Substation PLC

Open Ports: 4

Vulnerabilities: 2

DYNAMIC RISK ASSESSMENT

RISK INDEX: 78 / 100 (HIGH)

Attack Classifications: Denial of Service

DISCOVERED NETWORK SERVICES

PORT	PROTOCOL	STATE	SERVICE	VERSION
502	TCP	open	modbus	Modbus SCADA Gateway
104	TCP	open	iec-104	IEC 60870-5-104 Telemetry

DETECTED CVE VULNERABILITIES

- CVE-2023-28341 | CVSS: 9.1 | Severity: HIGH

Description: Malformed IEC 60870-5-104 APDU packet burst targeting Regional Control Center gateway causing telemetry frame drop.

DARKON AI THREAT INTELLIGENCE & REMEDIATION

Darkon AI detected IEC 60870-5-104 Telemetry Flood targeting Kozhikode Kuttiyadi Hydro 220kV Remote Terminal Unit (RTU) in district Kozhikode.

- Block source IP 190.157.125.153 on Industrial Security Firewall.
- Isolate PLC communication interface on target substation.
- Enforce IP Whitelisting for Port 502 / Port 104.