JOINT COMMISSION

Tracer Observation Form

EOC Rounding AW - CURRENT

02/26/2026 03:14 PM

Site: 486045 Midwest Orthopedic Specialty Hospital

Program: Hospital

Observation Header	
Tracer Instructions: *No Instructions Provided*	
Observation Title:	
Observation Date:	
Total Completed Observations:	**Department:**
Survey Team:	**Staff Interviewed:**
Medical Staff:	**Unique Identifier:**
Location:	**Equipment Observed:**
	Contracted Service:
Note:	

Questions (* = Required)

All Areas

1. Are ceiling tiles free from soiling and water damage? ☐ N/A

Compliant? ◯ Yes ◯ No | Num: _____ Den: _____

PE.01.01.01 EP 1 - The hospital's building is constructed, arranged, and maintained to allow safe access and to protect the safety and well-being of patients. Note 1: Diagnostic and therapeutic facilities are located in areas appropriate for the services provided. Note 2: When planning for new, altered, or renovated space, the hospital uses state rules and regulations or the current Guidelines for Design and Construction of Hospitals published by the Facility Guidelines Institute. If the state rules and regulations or the Guidelines do not address the design needs of the hospital, then it uses other reputable standards and guidelines that provide equivalent design criteria.

Corrective Action:

Notes:

2. Are all areas free from visible tape/tape residue ☐ N/A

Instructions: EVS to complete daily Please place in numerator and denominator on a daily basis

Compliant? ◯ Yes ◯ No | Num: _____ Den: _____

IC.06.01.01 EP 3 - The hospital implements activities for the surveillance, prevention, and control of health care–associated infections and other infectious diseases, including maintaining a clean and sanitary environment to avoid sources and transmission of infection, and addresses any infection control issues identified by public health authorities that could impact the hospital.

Corrective Action:

Notes:

3. Area is free from dust and debris- please check tops of lights, booms, picture frames, crash carts ☐ N/A

Compliant? ◯ Yes ◯ No | Num: _____ Den: _____

IC.06.01.01 EP 3 - The hospital implements activities for the surveillance, prevention, and control of health care–associated infections and other infectious diseases, including maintaining a clean and sanitary environment to avoid sources and transmission of infection, and addresses any infection control issues identified by public health authorities that could impact the hospital.

© 2026 Joint Commission. All Rights Reserved. For Internal Use Only.

Corrective Action:

Notes:

4. Are all coverings and finishes on chairs, pads, etc. intact and not torn? Please check furniture in patient rooms, waiting rooms, and mattresses/stretchers. ☐ N/A

Compliant? ◯ Yes ◯ No | Num: _____ Den: _____

IC.06.01.01 EP 3 - The hospital implements activities for the surveillance, prevention, and control of health care–associated infections and other infectious diseases, including maintaining a clean and sanitary environment to avoid sources and transmission of infection, and addresses any infection control issues identified by public health authorities that could impact the hospital.

Corrective Action:

Notes:

5. Is the right to patient privacy protected at all times? PHI is secured? Note: Include observations of visual and auditory privacy. For example: Doors and curtains are closed when applicable. ☐ N/A

Compliant? ◯ Yes ◯ No | Num: _____ Den: _____

RI.11.01.01 EP 5 - The hospital respects the patient's right to personal privacy. Note 1: This element of performance (EP) addresses a patient's personal privacy. For EPs addressing the privacy of a patient's health information, refer to Standard IM.12.01.01. Note 2: For hospitals that use Joint Commission accreditation for deemed status purposes and have swing beds: Personal privacy includes accommodations, medical treatment, written and telephone communications, personal care, visits, and meetings of family and resident groups, but this does not require the facility to provide a private room for each resident.

Corrective Action:

Notes:

6. Carts containing sharps such as procedure and line carts are locked and secure when not in use ☐ N/A

Compliant? ◯ Yes ◯ No | Num: _____ Den: _____

PE.04.01.01 EP 5 - The hospital maintains supplies to ensure an acceptable level of safety and quality. Note: Supplies are stored in a manner to ensure the safety of the stored supplies and to not violate fire codes or otherwise endanger patients.

Corrective Action:

Notes:

7. Areas under sinks do not include storage of patient care items and other items, such as paper products, that could be damaged or contaminated if the items are exposed to water leaks. ☐ N/A

Compliant? ◯ Yes ◯ No | Num: _____ Den: _____

IC.06.01.01 EP 3 - The hospital implements activities for the surveillance, prevention, and control of health care–associated infections and other infectious diseases, including maintaining a clean and sanitary environment to avoid sources and transmission of infection, and addresses any infection control issues identified by public health authorities that could impact the hospital.

Corrective Action:

Notes:

8. Observe the temperature of blanket warmers. Is the temperature observed to be no greater than 130 degrees. Fluids are not stored in blanket warmers. ☐ N/A

Compliant? ◯ Yes ◯ No | Num: _____ Den: _____

PE.04.01.01 EP 2 - The hospital maintains essential equipment in safe operating condition.

Corrective Action:

Notes:

© 2026 Joint Commission. All Rights Reserved. For Internal Use Only.

9. Observe the temperature of fluid warmers (e.g. IV fluids, irrigation solutions). Is the temperature observed to be no greater than 110 degrees. Is temperature log complete and within acceptable range (or corrective action documented)? Are the fluids dated and not beyond the expiration date? ☐ N/A

Compliant? ◯ Yes ◯ No | Num: _____ Den: _____

MM.13.01.01 EP 4 - The hospital removes all expired, damaged, mislabeled, contaminated, or otherwise unusable medications and stores them separately from medications available for patient use. Note: This element of performance is also applicable to sample medications.

Corrective Action:

Notes:

10. Are all patient care items and equipment 3 ft from sinks, or is a barrier in place? ☐ N/A

Compliant? ◯ Yes ◯ No | Num: _____ Den: _____

IC.06.01.01 EP 3 - The hospital implements activities for the surveillance, prevention, and control of health care–associated infections and other infectious diseases, including maintaining a clean and sanitary environment to avoid sources and transmission of infection, and addresses any infection control issues identified by public health authorities that could impact the hospital.

Corrective Action:

Notes:

Hallways

11. Are exits, exit accesses, egress corridors, and exit discharges clear of obstructions or impediments to the public way, such as clutter? For example: equipment, carts, furniture, construction material, snow, and ice. ☐ N/A

Compliant? ◯ Yes ◯ No | Num: _____ Den: _____

PE.03.01.01 EP 3 - The hospital meets the applicable provisions of the Life Safety Code (NFPA 101-2012 and Tentative Interim Amendments [TIA] 12-1, 12-2, 12-3, and 12-4). Note 1: Outpatient surgical departments meet the provisions applicable to ambulatory health care occupancies, regardless of the number of patients served. Note 2: For hospitals that use Joint Commission accreditation for deemed status purposes: The provisions of the Life Safety Code do not apply in a state where the Centers for Medicare & Medicaid Services (CMS) finds that a fire and safety code imposed by state law adequately protects patients in hospitals. Note 3: For hospitals that use Joint Commission accreditation for deemed status purposes: In consideration of a recommendation by the state survey agency or accrediting organization or at the discretion of the Secretary for the US Department of Health & Human Services, CMS may waive, for periods deemed appropriate, specific provisions of the Life Safety Code that would result in unreasonable hardship upon a hospital, but only if the waiver will not adversely affect the health and safety of the patients. Note 4: All inspecting activities are documented with the name of the activity; date of the activity; inventory of devices, equipment, or other items; required frequency; name and contact information of person who performed the activity; NFPA standard(s) referenced for the activity; and results of the activity.

Corrective Action:

Notes:

12. Access to electrical panels, medical gas panels, fire pulls, and fire extinguishers are unobstructed (3 feet clearance) and are the panels locked? ☐ N/A

Compliant? ◯ Yes ◯ No | Num: _____ Den: _____

PE.04.01.01 EP 1 - The hospital meets the applicable provisions and proceeds in accordance with the Health Care Facilities Code (NFPA 99-2012 and Tentative Interim Amendments [TIA] 12-2, 12-3, 12-4, 12-5, and 12-6). Note 1: Chapters 7, 8, 12, and 13 of the Health Care Facilities Code do not apply. Note 2: If application of the Health Care Facilities Code would result in unreasonable hardship for the hospital, the Centers for Medicare & Medicaid Services may waive specific provisions of the Health Care Facilities Code, but only if the waiver does not adversely affect the health and safety of patients. Note 3: All inspecting activities are documented with the name of the activity; date of the activity; inventory of devices, equipment, or other items; required frequency; name and contact information of person who performed the activity; NFPA standard(s) referenced for the activity; and results of the activity.

Corrective Action:

© 2026 Joint Commission. All Rights Reserved. For Internal Use Only.

Notes:

13. Are environmental services/housekeeping storage closets and carts locked when unattended? ☐ N/A

Compliant? ◯ Yes ◯ No | Num: _____ Den: _____

PE.02.01.01 EP 4 - The hospital develops and implements policies and procedures to protect patients and staff from exposure to hazardous materials. The policies and procedures address the following: - Minimizing risk when selecting, handling, storing, transporting, using, and disposing of radioactive materials, hazardous chemicals, and hazardous gases and vapors - Disposal of hazardous medications - Minimizing risk when selecting and using hazardous energy sources, including the use of proper shielding - Periodic inspection of radiology equipment and prompt correction of hazards found during inspection - Precautions to follow and personal protective equipment to wear in response to hazardous material and waste spills or exposure Note 1: Hazardous energy is produced by both ionizing equipment (for example, radiation and x-ray equipment) and nonionizing equipment (for example, lasers and MRIs). Note 2: Hazardous gases and vapors include but are not limited to ethylene oxide and nitrous oxide gases; vapors generated by glutaraldehyde; cauterizing equipment, such as lasers; waste anesthetic gas disposal (WAGD); and laboratory rooftop exhaust. (For full text, refer to NFPA 99-2012: 9.3.8; 9.3.9)

Corrective Action:

Notes:

14. Are clinical areas free from staff food and drinks in accordance with policy? ☐ N/A

Compliant? ◯ Yes ◯ No | Num: _____ Den: _____

IC.06.01.01 EP 3 - The hospital implements activities for the surveillance, prevention, and control of health care–associated infections and other infectious diseases, including maintaining a clean and sanitary environment to avoid sources and transmission of infection, and addresses any infection control issues identified by public health authorities that could impact the hospital.

Corrective Action:

Notes:

Clean Utility/Equipment

15. Is linen stored in a clean room or covered when stored in the hallway or other locations? ☐ N/A

Compliant? ◯ Yes ◯ No | Num: _____ Den: _____

IC.06.01.01 EP 3 - The hospital implements activities for the surveillance, prevention, and control of health care–associated infections and other infectious diseases, including maintaining a clean and sanitary environment to avoid sources and transmission of infection, and addresses any infection control issues identified by public health authorities that could impact the hospital.

Corrective Action:

Notes:

16. Has the code cart been documented as check in accordance with policy? ☐ N/A

Compliant? ◯ Yes ◯ No | Num: _____ Den: _____

PE.04.01.01 EP 2 - The hospital maintains essential equipment in safe operating condition.

Corrective Action:

Notes:

17. Do clean utility rooms contain only clean/sterile items? ☐ N/A

Compliant? ◯ Yes ◯ No | Num: _____ Den: _____

PE.04.01.01 EP 2 - The hospital maintains essential equipment in safe operating condition.

Corrective Action:

Notes:

© 2026 Joint Commission. All Rights Reserved. For Internal Use Only.

18. Is the code cart/defibrillators plugged into emergency (red) outlets? ☐ N/A

Instructions: If the code cart was not able to be plugged into a red outlet, there needs to be a process for back-up if power outage.

Compliant? ◯ Yes ◯ No | Num: _____ Den: _____

IC.06.01.01 EP 3 - The hospital implements activities for the surveillance, prevention, and control of health care–associated infections and other infectious diseases, including maintaining a clean and sanitary environment to avoid sources and transmission of infection, and addresses any infection control issues identified by public health authorities that could impact the hospital.

Corrective Action:

Notes:

19. Is clean equipment segregated from used or dirty equipment? ☐ N/A

Compliant? ◯ Yes ◯ No | Num: _____ Den: _____

IC.06.01.01 EP 3 - The hospital implements activities for the surveillance, prevention, and control of health care–associated infections and other infectious diseases, including maintaining a clean and sanitary environment to avoid sources and transmission of infection, and addresses any infection control issues identified by public health authorities that could impact the hospital.

Corrective Action:

Notes:

20. Observe available medical equipment. If the equipment requires preventative maintenance or testing, is the date on the sticker current? ☐ N/A

Compliant? ◯ Yes ◯ No | Num: _____ Den: _____

PE.04.01.01 EP 2 - The hospital maintains essential equipment in safe operating condition.

Corrective Action:

Notes:

21. Observe equipment, such as IV poles, carts, beds, furniture, curtains, etc. Are all items clean and in good repair? ☐ N/A

Compliant? ◯ Yes ◯ No | Num: _____ Den: _____

PE.04.01.01 EP 2 - The hospital maintains essential equipment in safe operating condition.

Corrective Action:

Notes:

22. Patient care and other clean items are NOT stored directly on the floor. ☐ N/A

Compliant? ◯ Yes ◯ No | Num: _____ Den: _____

IC.06.01.01 EP 3 - The hospital implements activities for the surveillance, prevention, and control of health care–associated infections and other infectious diseases, including maintaining a clean and sanitary environment to avoid sources and transmission of infection, and addresses any infection control issues identified by public health authorities that could impact the hospital.

Corrective Action:

Notes:

23. Clean and sterile patient care items are NOT stored in cardboard boxes AND outside shipping boxes are not used to store items in a clean storage room, in accordance with policy ☐ N/A

Compliant? ◯ Yes ◯ No | Num: _____ Den: _____

© 2026 Joint Commission. All Rights Reserved. For Internal Use Only.

IC.06.01.01 EP 3 - The hospital implements activities for the surveillance, prevention, and control of health care–associated infections and other infectious diseases, including maintaining a clean and sanitary environment to avoid sources and transmission of infection, and addresses any infection control issues identified by public health authorities that could impact the hospital.

Corrective Action:

Notes:

24. Are 18 inches or more of open space maintained below the sprinkler deflector to the top of storage? ☐ N/A
Note: Perimeter wall and stack shelving may extend up to the ceiling when not located directly below a sprinkler head.

Compliant? ◯ Yes ◯ No | Num: _____ Den: _____

PE.03.01.01 EP 3 - The hospital meets the applicable provisions of the Life Safety Code (NFPA 101-2012 and Tentative Interim Amendments [TIA] 12-1, 12-2, 12-3, and 12-4). Note 1: Outpatient surgical departments meet the provisions applicable to ambulatory health care occupancies, regardless of the number of patients served. Note 2: For hospitals that use Joint Commission accreditation for deemed status purposes: The provisions of the Life Safety Code do not apply in a state where the Centers for Medicare & Medicaid Services (CMS) finds that a fire and safety code imposed by state law adequately protects patients in hospitals. Note 3: For hospitals that use Joint Commission accreditation for deemed status purposes: In consideration of a recommendation by the state survey agency or accrediting organization or at the discretion of the Secretary for the US Department of Health & Human Services, CMS may waive, for periods deemed appropriate, specific provisions of the Life Safety Code that would result in unreasonable hardship upon a hospital, but only if the waiver will not adversely affect the health and safety of the patients. Note 4: All inspecting activities are documented with the name of the activity; date of the activity; inventory of devices, equipment, or other items; required frequency; name and contact information of person who performed the activity; NFPA standard(s) referenced for the activity; and results of the activity.

Corrective Action:

Notes:

25. Are the bottom shelves of racks used for storage of sterile and clean supplies designed with an impervious solid material? ☐ N/A

Compliant? ◯ Yes ◯ No | Num: _____ Den: _____

IC.06.01.01 EP 3 - The hospital implements activities for the surveillance, prevention, and control of health care–associated infections and other infectious diseases, including maintaining a clean and sanitary environment to avoid sources and transmission of infection, and addresses any infection control issues identified by public health authorities that could impact the hospital.

Corrective Action:

Notes:

26. Are full oxygen cylinders segregated from cylinders which are not full (e.g. empty and partially full)? ☐ N/A

Compliant? ◯ Yes ◯ No | Num: _____ Den: _____

PE.01.01.01 EP 3 - The hospital's premises are clean and orderly. Note: Clean and orderly means an uncluttered physical environment where patients and staff can function. This includes but is not limited to storing equipment and supplies in their proper spaces, attending to spills, and keeping areas neat.

Corrective Action:

Notes:

27. Are opened ultrasound gel bottles dated with a 28 day expiration date? ☐ N/A

Compliant? ◯ Yes ◯ No | Num: _____ Den: _____

© 2026 Joint Commission. All Rights Reserved. For Internal Use Only.

IC.04.01.01 EP 3 - The hospital's infection prevention and control program has written policies and procedures to guide its activities and methods for preventing and controlling the transmission of infections within the hospital and between the hospital and other institutions and settings. The policies and procedures are in accordance with the following hierarchy of references: a. Applicable law and regulation. b. Manufacturers' instructions for use. c. Nationally recognized evidence-based guidelines and standards of practice, including the Centers for Disease Control and Prevention's (CDC) Core Infection Prevention and Control Practices for Safe Healthcare Delivery in All Settings or, in the absence of such guidelines, expert consensus or best practices. The guidelines are documented within the policies and procedures. Note 1: Relevant federal, state, and local law and regulations include but are not limited to the Centers for Medicare & Medicaid Services' Conditions of Participation, Food and Drug Administration's regulations for reprocessing single-use medical devices; Occupational Safety and Health Administration's Bloodborne Pathogens Standard 29 CFR 1910.1030, Personal Protective Equipment Standard 29 CFR 1910.132, and Respiratory Protection Standard 29 CFR 1910.134; health care worker vaccination laws; state and local public health authorities' requirements for reporting of communicable diseases and outbreaks; and state and local regulatory requirements for biohazardous or regulated medical waste generators. Note 2: For full details on the CDC's Core Infection Prevention and Control Practices for Safe Healthcare Delivery in All Settings, refer to https://www.cdc.gov/infection-control/hcp/disinfection-sterilization/introduction-methods-definition-of-terms.html. Note 3: The hospital determines which evidence-based guidelines, expert recommendations, best practices, or a combination thereof it adopts in its policies and procedures.

Corrective Action:

Notes:

28. After sterilization, medical devices and instruments are stored for less than 1 year before re-inspection and re-processing occurs? ☐ N/A

Instructions: All instruments should have a processing date within the last year. Any packages 1 year or more since processing need to be re-sent to SPD for inspection and re-processing.

Compliant? ◯ Yes ◯ No | Num: _____ Den: _____

IC.04.01.01 EP 3 - The hospital's infection prevention and control program has written policies and procedures to guide its activities and methods for preventing and controlling the transmission of infections within the hospital and between the hospital and other institutions and settings. The policies and procedures are in accordance with the following hierarchy of references: a. Applicable law and regulation. b. Manufacturers' instructions for use. c. Nationally recognized evidence-based guidelines and standards of practice, including the Centers for Disease Control and Prevention's (CDC) Core Infection Prevention and Control Practices for Safe Healthcare Delivery in All Settings or, in the absence of such guidelines, expert consensus or best practices. The guidelines are documented within the policies and procedures. Note 1: Relevant federal, state, and local law and regulations include but are not limited to the Centers for Medicare & Medicaid Services' Conditions of Participation, Food and Drug Administration's regulations for reprocessing single-use medical devices; Occupational Safety and Health Administration's Bloodborne Pathogens Standard 29 CFR 1910.1030, Personal Protective Equipment Standard 29 CFR 1910.132, and Respiratory Protection Standard 29 CFR 1910.134; health care worker vaccination laws; state and local public health authorities' requirements for reporting of communicable diseases and outbreaks; and state and local regulatory requirements for biohazardous or regulated medical waste generators. Note 2: For full details on the CDC's Core Infection Prevention and Control Practices for Safe Healthcare Delivery in All Settings, refer to https://www.cdc.gov/infection-control/hcp/disinfection-sterilization/introduction-methods-definition-of-terms.html. Note 3: The hospital determines which evidence-based guidelines, expert recommendations, best practices, or a combination thereof it adopts in its policies and procedures.

Corrective Action:

Notes:

29. Are all items within the manufacturers' expiration dates? ☐ N/A

Compliant? ◯ Yes ◯ No | Num: _____ Den: _____

© 2026 Joint Commission. All Rights Reserved. For Internal Use Only.

IC.04.01.01 EP 3 - The hospital's infection prevention and control program has written policies and procedures to guide its activities and methods for preventing and controlling the transmission of infections within the hospital and between the hospital and other institutions and settings. The policies and procedures are in accordance with the following hierarchy of references: a. Applicable law and regulation. b. Manufacturers' instructions for use. c. Nationally recognized evidence-based guidelines and standards of practice, including the Centers for Disease Control and Prevention's (CDC) Core Infection Prevention and Control Practices for Safe Healthcare Delivery in All Settings or, in the absence of such guidelines, expert consensus or best practices. The guidelines are documented within the policies and procedures. Note 1: Relevant federal, state, and local law and regulations include but are not limited to the Centers for Medicare & Medicaid Services' Conditions of Participation, Food and Drug Administration's regulations for reprocessing single-use medical devices; Occupational Safety and Health Administration's Bloodborne Pathogens Standard 29 CFR 1910.1030, Personal Protective Equipment Standard 29 CFR 1910.132, and Respiratory Protection Standard 29 CFR 1910.134; health care worker vaccination laws; state and local public health authorities' requirements for reporting of communicable diseases and outbreaks; and state and local regulatory requirements for biohazardous or regulated medical waste generators. Note 2: For full details on the CDC's Core Infection Prevention and Control Practices for Safe Healthcare Delivery in All Settings, refer to https://www.cdc.gov/infection-control/hcp/disinfection-sterilization/introduction-methods-definition-of-terms.html. Note 3: The hospital determines which evidence-based guidelines, expert recommendations, best practices, or a combination thereof it adopts in its policies and procedures.

Corrective Action:

Notes:

Soiled Utility

30. Do soiled utility rooms contain contaminated/soiled items only? ☐ N/A

Compliant? ◯ Yes ◯ No | Num: _____ Den: _____

IC.06.01.01 EP 3 - The hospital implements activities for the surveillance, prevention, and control of health care–associated infections and other infectious diseases, including maintaining a clean and sanitary environment to avoid sources and transmission of infection, and addresses any infection control issues identified by public health authorities that could impact the hospital.

Corrective Action:

Notes:

31. Is PPE available for staff in soiled utility rooms? (Required - gloves of various sizes, disposable gowns and eye protection) ☐ N/A

Compliant? ◯ Yes ◯ No | Num: _____ Den: _____

IC.06.01.01 EP 3 - The hospital implements activities for the surveillance, prevention, and control of health care–associated infections and other infectious diseases, including maintaining a clean and sanitary environment to avoid sources and transmission of infection, and addresses any infection control issues identified by public health authorities that could impact the hospital.

Corrective Action:

Notes:

32. Is the first step of processing soiled instruments completed per the policy? Examples: remove visible soil with cloth/sponge/wipe from the instrument, place in the open position, spray with pre-cleaner and place into transport container (Biohazard bag or rigid container). ☐ N/A

Compliant? ◯ Yes ◯ No | Num: _____ Den: _____

© 2026 Joint Commission. All Rights Reserved. For Internal Use Only.

IC.04.01.01 EP 4 - The hospital's policies and procedures for cleaning, disinfection, and sterilization of reusable medical and surgical devices and equipment address the following: - Cleaning, disinfection, and sterilization of reusable medical and surgical devices in accordance with the Spaulding classification system and manufacturers' instructions - Use of disinfectants registered by the Environmental Protection Agency for noncritical devices and equipment according to the directions on the product labeling, including but not limited to indication, specified use dilution, contact time, and method of application - Use of FDA-approved liquid chemical sterilants for the processing of critical devices and high-level disinfectants for the processing of semicritical devices in accordance with FDA-cleared label and device manufacturers' instructions - Required documentation for device reprocessing cycles, including but not limited to sterilizer cycle logs, the frequency of chemical and biological testing, and the results of testing for appropriate concentration for chemicals used in high-level disinfection - Resolution of conflicts or discrepancies between a medical device manufacturer's instructions and manufacturers' instructions for automated high-level disinfection or sterilization equipment - Criteria and process for the use of immediate-use steam sterilization - Actions to take in the event of a reprocessing error or failure identified either prior to the release of the reprocessed item(s) or after the reprocessed item(s) was used or stored for later use Note 1: The Spaulding classification system classifies medical and surgical devices as critical, semicritical, or noncritical based on risk to the patient from contamination on a device and establishes the levels of germicidal activity (sterilization, high-level disinfection, intermediate-level disinfection, and low-level disinfection) to be used for the three classes of devices. Note 2: Depending on the nature of the incident, examples of actions may include quarantine of the sterilizer, recall of item(s), stakeholder notification, patient notification, surveillance, and follow-up.

Corrective Action:

Notes:

33. Is access to eyewash equipment unobstructed and caps are in place? ☐ N/A

Compliant? ◯ Yes ◯ No | Num: _____ Den: _____

PE.02.01.01 EP 4 - The hospital develops and implements policies and procedures to protect patients and staff from exposure to hazardous materials. The policies and procedures address the following: - Minimizing risk when selecting, handling, storing, transporting, using, and disposing of radioactive materials, hazardous chemicals, and hazardous gases and vapors - Disposal of hazardous medications - Minimizing risk when selecting and using hazardous energy sources, including the use of proper shielding - Periodic inspection of radiology equipment and prompt correction of hazards found during inspection - Precautions to follow and personal protective equipment to wear in response to hazardous material and waste spills or exposure Note 1: Hazardous energy is produced by both ionizing equipment (for example, radiation and x-ray equipment) and nonionizing equipment (for example, lasers and MRIs). Note 2: Hazardous gases and vapors include but are not limited to ethylene oxide and nitrous oxide gases; vapors generated by glutaraldehyde; cauterizing equipment, such as lasers; waste anesthetic gas disposal (WAGD); and laboratory rooftop exhaust. (For full text, refer to NFPA 99-2012: 9.3.8; 9.3.9)

Corrective Action:

Notes:

Patient Care Rooms

34. Are all needles/sharps containers secured to prevent tipping and spilling and are the contents below the full line? ☐ N/A

Compliant? ◯ Yes ◯ No | Num: _____ Den: _____

PE.01.01.01 EP 1 - The hospital's building is constructed, arranged, and maintained to allow safe access and to protect the safety and well-being of patients. Note 1: Diagnostic and therapeutic facilities are located in areas appropriate for the services provided. Note 2: When planning for new, altered, or renovated space, the hospital uses state rules and regulations or the current Guidelines for Design and Construction of Hospitals published by the Facility Guidelines Institute. If the state rules and regulations or the Guidelines do not address the design needs of the hospital, then it uses other reputable standards and guidelines that provide equivalent design criteria.

Corrective Action:

Notes:

35. Are pull cords the correct length for the emergency call lights in bathrooms? Note: Cords should not be on the floor, wrapped around the hand rail, or greater than 6 inches from the floor. ☐ N/A

Compliant? ◯ Yes ◯ No | Num: _____ Den: _____

© 2026 Joint Commission. All Rights Reserved. For Internal Use Only.

PE.02.01.01 EP 6 - The hospital has procedures for the proper routine storage and prompt disposal of trash and regulated medical waste.

Corrective Action:

Notes:

36. Are electrodes in open packages discarded or stored after the package is opened in accordance with manufacturers' recommendations or policy? ☐ N/A

Compliant? ◯ Yes ◯ No | Num: _____ Den: _____

IC.06.01.01 EP 3 - The hospital implements activities for the surveillance, prevention, and control of health care–associated infections and other infectious diseases, including maintaining a clean and sanitary environment to avoid sources and transmission of infection, and addresses any infection control issues identified by public health authorities that could impact the hospital.

Corrective Action:

Notes:

37. Are all pill cutters clean and clear of residue? ☐ N/A

Compliant? ◯ Yes ◯ No | Num: _____ Den: _____

IC.06.01.01 EP 3 - The hospital implements activities for the surveillance, prevention, and control of health care–associated infections and other infectious diseases, including maintaining a clean and sanitary environment to avoid sources and transmission of infection, and addresses any infection control issues identified by public health authorities that could impact the hospital.

Corrective Action:

Notes:

38. Metal equipment such as linen carts and IV Poles are free from rust ☐ N/A

Instructions: Daily

Compliant? ◯ Yes ◯ No | Num: _____ Den: _____

PE.04.01.01 EP 2 - The hospital maintains essential equipment in safe operating condition.

Corrective Action:

Notes:

Nutrition Station

39. Are ice machines clean and free from calcifications? ☐ N/A

Compliant? ◯ Yes ◯ No | Num: _____ Den: _____

IC.06.01.01 EP 3 - The hospital implements activities for the surveillance, prevention, and control of health care–associated infections and other infectious diseases, including maintaining a clean and sanitary environment to avoid sources and transmission of infection, and addresses any infection control issues identified by public health authorities that could impact the hospital.

Corrective Action:

Notes:

40. Are patient food refrigerator logs maintained and up-to-date? Are temperatures within range? If not, is there evidence that corrective action was taken? ☐ N/A

Compliant? ◯ Yes ◯ No | Num: _____ Den: _____

PE.04.01.01 EP 3 - The hospital has proper ventilation, lighting, and temperature control in all pharmaceutical, patient care, and food preparation areas.

© 2026 Joint Commission. All Rights Reserved. For Internal Use Only.

Corrective Action:

Notes:

Nurses Station / Staff Work Areas

41. Is staff, medical staff, and patient personal property secured in accordance with policy and not stored in patient care areas? ☐ N/A

Compliant? ◯ Yes ◯ No | Num: _____ Den: _____

IC.06.01.01 EP 3 - The hospital implements activities for the surveillance, prevention, and control of health care–associated infections and other infectious diseases, including maintaining a clean and sanitary environment to avoid sources and transmission of infection, and addresses any infection control issues identified by public health authorities that could impact the hospital.

Corrective Action:

Notes:

42. Observe all locations where medications are stored and located. Are all medications secured in accordance with policy? Note: Include in the observations medication rooms, carts, bins, drawers, refrigerators, patient rooms/care areas, and special procedure carts or containers. ☐ N/A

Compliant? ◯ Yes ◯ No | Num: _____ Den: _____

MM.13.01.01 EP 2 - The hospital stores all medications and biologicals, including controlled (scheduled) medications, in a secured area and locked when necessary to prevent diversion in accordance with law and regulation. Note 1: Scheduled medications include those listed in Schedules II–V of the Comprehensive Drug Abuse Prevention and Control Act of 1970. Note 2: This element of performance is also applicable to sample medications. Note 3: Only authorized staff have access to locked areas.

Corrective Action:

Notes:

43. Are all pill crushers clean and clear of residue? ☐ N/A

Compliant? ◯ Yes ◯ No | Num: _____ Den: _____

IC.06.01.01 EP 3 - The hospital implements activities for the surveillance, prevention, and control of health care–associated infections and other infectious diseases, including maintaining a clean and sanitary environment to avoid sources and transmission of infection, and addresses any infection control issues identified by public health authorities that could impact the hospital.

Corrective Action:

Notes:

44. Glucometers are clean and not soiled with blood or controls ☐ N/A

Compliant? ◯ Yes ◯ No | Num: _____ Den: _____

IC.06.01.01 EP 3 - The hospital implements activities for the surveillance, prevention, and control of health care–associated infections and other infectious diseases, including maintaining a clean and sanitary environment to avoid sources and transmission of infection, and addresses any infection control issues identified by public health authorities that could impact the hospital.

Corrective Action:

Notes:

45. Open glucose supplies are dated once opened with the appropriate expiration date. ☐ N/A

Compliant? ◯ Yes ◯ No | Num: _____ Den: _____

© 2026 Joint Commission. All Rights Reserved. For Internal Use Only.

NPG.10.01.01 EP 1 - The person from the hospital whose name appears on the Clinical Laboratory Improvement Amendments of 1988 (CLIA '88) certificate, or a qualified designee, establishes written policies and procedures for waived testing that address the following: - Clinical usage and limitations of the test methodology - Need for confirmatory testing (for example, recommendations made by the manufacturer for rapid tests) and result follow-up recommendations (for example, a recommendation to repeat the test when results are higher or lower than the reportable range of the test) - Specimen type, collection, and identification and required labeling - Specimen preservation, if applicable - Instrument maintenance and function checks, such as calibration - Storage conditions for test components - Reagent use, including not using a reagent after its expiration date - Quality control (including frequency and type) and corrective action when quality control is unacceptable - Test performance - Result reporting, including not reporting individual patient results unless quality control is acceptable - Equipment performance evaluation Note 1: Policies and procedures for waived testing are made available to testing personnel. Note 2: The designee should be knowledgeable by virtue of training, experience, and competence about the waived testing performed.

Corrective Action:

Notes:

46. During process observation or staff interviews, can the utilization of the approved cleaning product per the IFU for cleaning and disinfecting of the NovaStat Glucometers be confirmed? ☐ N/A

Instructions: Numerator: Total observations or staff interviews confirming approved cleaning product being utilized for glucometer cleaning
Denominator: Total observations or staff interviews assessing glucometer cleaning (i.e. Yellow Top Bleach Wipes = 4 minutes, PDI Sani-cloth Prime= 1 minute)

Compliant? ◯ Yes ◯ No | Num: _____ Den: _____

IC.05.01.01 EP 1 - The hospital's governing body is responsible for the implementation, performance, and sustainability of the infection prevention and control program and provides resources to support and track the implementation, success, and sustainability of the program's activities. Note: To make certain that systems are in place and operational to support the program, the governing body provides access to information technology; laboratory services; equipment and supplies; local, state, and federal public health authorities' advisories and alerts, such as the CDC's Health Alert Network (HAN); FDA alerts; manufacturers' instructions for use; and guidelines used to inform policies.

Corrective Action:

Notes:

47. During process observation or staff interviews, is the required dwell/wet time for the cleaning product being utilized be observed? (i.e. Yellow Top Bleach Wipes = 4 minutes, PDI Sani-cloth Prime= 1 minute) ☐ N/A

Instructions: Numerator: Total observations or staff interviews confirming appropriate dwell/wet observation is being utilized for glucometer cleaning
Denominator: Total observations or staff interviews assessing glucometer cleaning

Compliant? ◯ Yes ◯ No | Num: _____ Den: _____

IC.05.01.01 EP 1 - The hospital's governing body is responsible for the implementation, performance, and sustainability of the infection prevention and control program and provides resources to support and track the implementation, success, and sustainability of the program's activities. Note: To make certain that systems are in place and operational to support the program, the governing body provides access to information technology; laboratory services; equipment and supplies; local, state, and federal public health authorities' advisories and alerts, such as the CDC's Health Alert Network (HAN); FDA alerts; manufacturers' instructions for use; and guidelines used to inform policies.

Corrective Action:

Notes:

Procedural Areas

48. Are vendors and contracted staff identified with ID badges per policy? ☐ N/A

Compliant? ◯ Yes ◯ No | Num: _____ Den: _____

© 2026 Joint Commission. All Rights Reserved. For Internal Use Only.

NPG.11.01.01 EP 1 - The hospital controls access to and from areas it identifies as security sensitive.

Corrective Action:

Notes:

49. Is storage of full oxygen cylinders limited to 12 or less in spaces not protected as hazardous rooms? Exception: if cylinders are stored in an industrial grade gas cylinder cabinet with doors that are able to be secured, the number of tanks inside does not exceed what the cabinets are rated for. ☐ N/A

Compliant? ◯ Yes ◯ No | Num: _____ Den: _____

PE.01.01.01 EP 3 - The hospital's premises are clean and orderly. Note: Clean and orderly means an uncluttered physical environment where patients and staff can function. This includes but is not limited to storing equipment and supplies in their proper spaces, attending to spills, and keeping areas neat.

Corrective Action:

Notes:

50. If performing aerosol-generating procedures (such as suctioning, intubation, bronchoscopy, or CPR), does the hospital require the use of a gown, eye protection, gloves, and mask? Is there evidence that this policy is being adhered to? ☐ N/A

Compliant? ◯ Yes ◯ No | Num: _____ Den: _____

IC.04.01.01 EP 3 - The hospital's infection prevention and control program has written policies and procedures to guide its activities and methods for preventing and controlling the transmission of infections within the hospital and between the hospital and other institutions and settings. The policies and procedures are in accordance with the following hierarchy of references: a. Applicable law and regulation. b. Manufacturers' instructions for use. c. Nationally recognized evidence-based guidelines and standards of practice, including the Centers for Disease Control and Prevention's (CDC) Core Infection Prevention and Control Practices for Safe Healthcare Delivery in All Settings or, in the absence of such guidelines, expert consensus or best practices. The guidelines are documented within the policies and procedures. Note 1: Relevant federal, state, and local law and regulations include but are not limited to the Centers for Medicare & Medicaid Services' Conditions of Participation, Food and Drug Administration's regulations for reprocessing single-use medical devices; Occupational Safety and Health Administration's Bloodborne Pathogens Standard 29 CFR 1910.1030, Personal Protective Equipment Standard 29 CFR 1910.132, and Respiratory Protection Standard 29 CFR 1910.134; health care worker vaccination laws; state and local public health authorities' requirements for reporting of communicable diseases and outbreaks; and state and local regulatory requirements for biohazardous or regulated medical waste generators. Note 2: For full details on the CDC's Core Infection Prevention and Control Practices for Safe Healthcare Delivery in All Settings, refer to https://www.cdc.gov/infection-control/hcp/disinfection-sterilization/introduction-methods-definition-of-terms.html. Note 3: The hospital determines which evidence-based guidelines, expert recommendations, best practices, or a combination thereof it adopts in its policies and procedures.

Corrective Action:

Notes:

51. Are contaminated reusable sharps immediately, or as soon as possible after use, placed in appropriate containers until properly reprocessed? ☐ N/A

Compliant? ◯ Yes ◯ No | Num: _____ Den: _____

PE.02.01.01 EP 6 - The hospital has procedures for the proper routine storage and prompt disposal of trash and regulated medical waste.

Corrective Action:

Notes:

52. Are sharps disposal containers placed where they are readily accessible to staff and as close as feasible to the immediate area where sharps are used (for example, patient care areas)? ☐ N/A

Compliant? ◯ Yes ◯ No | Num: _____ Den: _____

PE.02.01.01 EP 6 - The hospital has procedures for the proper routine storage and prompt disposal of trash and regulated medical waste.

© 2026 Joint Commission. All Rights Reserved. For Internal Use Only.

Corrective Action:

Notes:

53. Are temperature/humidity levels within the proper range in ORs? ☐ N/A

Compliant? ◯ Yes ◯ No | Num: _____ Den: _____

PE.04.01.01 EP 3 - The hospital has proper ventilation, lighting, and temperature control in all pharmaceutical, patient care, and food preparation areas.

Corrective Action:

Notes:

54. In surgical/procedure areas does the staff have all hair and earrings covered? ☐ N/A

Compliant? ◯ Yes ◯ No | Num: _____ Den: _____

LD.13.01.09 EP 6 - The hospital develops and implements surgical care policies and procedures that maintain high standards for medical practice and patient care.

Corrective Action:

Notes:

55. Are all laryngoscope blades which are stored packaged separately? Include crash carts in observation. ☐ N/A

Compliant? ◯ Yes ◯ No | Num: _____ Den: _____

IC.04.01.01 EP 4 - The hospital's policies and procedures for cleaning, disinfection, and sterilization of reusable medical and surgical devices and equipment address the following: - Cleaning, disinfection, and sterilization of reusable medical and surgical devices in accordance with the Spaulding classification system and manufacturers' instructions - Use of disinfectants registered by the Environmental Protection Agency for noncritical devices and equipment according to the directions on the product labeling, including but not limited to indication, specified use dilution, contact time, and method of application - Use of FDA-approved liquid chemical sterilants for the processing of critical devices and high-level disinfectants for the processing of semicritical devices in accordance with FDA-cleared label and device manufacturers' instructions - Required documentation for device reprocessing cycles, including but not limited to sterilizer cycle logs, the frequency of chemical and biological testing, and the results of testing for appropriate concentration for chemicals used in high-level disinfection - Resolution of conflicts or discrepancies between a medical device manufacturer's instructions and manufacturers' instructions for automated high-level disinfection or sterilization equipment - Criteria and process for the use of immediate-use steam sterilization - Actions to take in the event of a reprocessing error or failure identified either prior to the release of the reprocessed item(s) or after the reprocessed item(s) was used or stored for later use Note 1: The Spaulding classification system classifies medical and surgical devices as critical, semicritical, or noncritical based on risk to the patient from contamination on a device and establishes the levels of germicidal activity (sterilization, high-level disinfection, intermediate-level disinfection, and low-level disinfection) to be used for the three classes of devices. Note 2: Depending on the nature of the incident, examples of actions may include quarantine of the sterilizer, recall of item(s), stakeholder notification, patient notification, surveillance, and follow-up.

Corrective Action:

Notes:

56. Are all meds labeled on the sterile field? ☐ N/A

Compliant? ◯ Yes ◯ No | Num: _____ Den: _____

NPG.14.03.01 EP 1 - In perioperative and other procedural settings both on and off the sterile field, the hospital labels medications and solutions that are not immediately administered. This applies even if there is only one medication being used. Note: An immediately administered medication is one that an authorized staff member prepares or obtains, takes directly to a patient, and administers to that patient without any break in the process.

Corrective Action:

Notes:

57. Is the time-out prior to procedure performed and documented properly, including all members in agreement prior to conclusion of time out? ☐ N/A

© 2026 Joint Commission. All Rights Reserved. For Internal Use Only.

Compliant? ◯ Yes ◯ No	Num: _____ Den: _____
NPG.01.06.03 EP 5 - The hospital documents the completion of the time-out. Note: The hospital determines the amount and type of documentation.	
Corrective Action:	
Notes:	
58. Is EMTALA signage posted in its dedicated Emergency Department. ☐ N/A	
Instructions: Signage should be located in the waiting room, triage area, each treatment room, ambulance bay.	
Compliant? ◯ Yes ◯ No	Num: _____ Den: _____
LD.13.01.01 EP 1 - The hospital provides care, treatment, and services in accordance with licensure requirements and federal, state, and local laws, rules, and regulations. Note: For hospitals that use Joint Commission accreditation for deemed status purposes: The hospital meets the Centers for Medicare & Medicaid Services' (CMS) definition of a hospital in accordance with 42 CFR 482.1(a)(1) and (b). (Refer to https://www.ecfr.gov/ for the language of this CMS requirement)	
Corrective Action:	
Notes:	
59. Vendor equipment is labeled/identified as having been tested for safety prior to use in the hospital ☐ N/A	
Instructions: Daily	
Compliant? ◯ Yes ◯ No	Num: _____ Den: _____
PE.04.01.01 EP 2 - The hospital maintains essential equipment in safe operating condition.	
Corrective Action:	
Notes:	
60. Is EMTALA signage posted in its dedicated OB Department. ☐ N/A	
Instructions: Signage should be located in the waiting room, triage area, each treatment room (including C-section suites).	
Compliant? ◯ Yes ◯ No	Num: _____ Den: _____
LD.13.01.01 EP 1 - The hospital provides care, treatment, and services in accordance with licensure requirements and federal, state, and local laws, rules, and regulations. Note: For hospitals that use Joint Commission accreditation for deemed status purposes: The hospital meets the Centers for Medicare & Medicaid Services' (CMS) definition of a hospital in accordance with 42 CFR 482.1(a)(1) and (b). (Refer to https://www.ecfr.gov/ for the language of this CMS requirement)	
Corrective Action:	
Notes:	

© 2026 Joint Commission. All Rights Reserved. For Internal Use Only.