

ELECTRONIC FIELD SERVICE REPORT (eFSR)

GENERATOR MAINTENANCE & TECHNICAL INSPECTION RECORD

1. SERVICE & CUSTOMER DETAILS

Job / Ticket Ref:		Date & Time:	
Customer Name:		Site ID / Location:	
Contact Person:		Contact Number:	

2. EQUIPMENT & ENGINE DETAILS

Generator Make/Model:		Capacity (kVA / kW):	
Engine Serial No:		Alternator Serial No:	
Hour Meter (HMR):	Hours	Battery Status / Volt:	V

3. SERVICE CHECKLIST & STATUS

Inspection Parameter	Status [OK / Action]	Inspection Parameter	Status [OK / Action]
Engine Oil Level & Quality	[] OK [] Req [] N/A	Fuel Filter Replacement	[] OK [] Req [] N/A
Coolant Level & Protection	[] OK [] Req [] N/A	Radiator Fins & Core Check	[] OK [] Req [] N/A
Water Separator Draining	[] OK [] Req [] N/A	Battery Terminals & Charging	[] OK [] Req [] N/A
Exhaust / Silencer Leakage	[] OK [] Req [] N/A	AVM (Anti-Vibration Mounts)	[] OK [] Req [] N/A

4. PARTS REPLACED & CONSUMABLES USED

Part Description / Item	Qty / Ltr	Part Description / Item	Qty / Ltr
Battery 12v 90mah	1	B check kit	1

5. TECHNICIAN REMARKS & ACTION PLAN

Observations / Corrective Actions Taken: **Replaced new battery and completed oil service then started dg observe the parameters all are in limits running condition okay**

Next Service Due (Date):	Next Service Due (Hours):	Hours
--------------------------	---------------------------	-------

6. FIELD WORK AUTHORIZATION & SIGN-OFF

By signing below, the customer representative acknowledges that the field service operations listed above were completed satisfactorily and equipment has been handed over in operational condition.

TECHNICIAN SIGNATURE	CUSTOMER SIGNATURE
Name: Siva	Name:
Signature:	Signature:
Date: _____	Date: _____