cases	doc 1		doc 2		degision	
	authors	• Macedo, D. • Ren, T. • Zanchettin, C. • Oliveira, A. • Ludermir, T.	authors	David MacÃado     Tsang Ing Ren     Cleber Zanchettin     Adriano L. I. Oliveira     Teresa Ludermir	decision	
			title	Entropic Out-of-Distribution Detection		
			publication_date   2021-05-24 00:00:00			
		Entrania Out of Distribution Detection	source	SupportedSources.INTERNET_ARCHIVE		
	title	Entropic Out-of-Distribution Detection  e   2021-07-18 00:00:00	journal			
	source	SupportedSources.CROSSREF	volume			
		Supportusources.exossker	doi			102
	volume		urls	• https://web.archive.org/web/20201205011648/https://arxiv.org/pdf/1908.05569v11.pdf		103
	doi	10.1109/ijcnn52387.2021.9533899	id	id5122796610781899051		
	urls	<ul> <li>http://xplorestaging.ieee.org/ielx7/9533266/9533267/09533899.pdf? arnumber=9533899</li> <li>http://dx.doi.org/10.1109/ijcnn52387.2021.9533899</li> </ul>	abstract	Out-of-distribution (OOD) detection approaches usually present special requirements (e.g., hyperparameter validation, collection of outlier data) and produce side effects (e.g., classification accuracy drop, slower energy-inefficient inferences). We argue that these issues are a consequence of the SoftMax loss anisotropy and disagreement with the maximum entropy principle. Thus, we propose the IsoMax loss and the entropic score. The seamless drop-in replacement of the SoftMax loss by IsoMax loss requires neither additional data collection nor hyperparameter validation. The trained models do not exhibit classification accuracy drop and produce fast energy-efficient inferences. Moreover, our experiments show that training neural networks with IsoMax loss significantly improves their OOD detection performance. The IsoMax loss exhibits state-of-the-art performance under the mentioned conditions (fast energy-efficient inference, no classification accuracy drop, no collection of outlier data, and no hyperparameter validation), which we call the seamless		
	id	id-7699773967363964663				
	abstract					
	versions					
				OOD detection task. In future work, current OOD detection methods may replace the SoftMax loss with the IsoMax loss to improve their performance on the commonly studied non-seamless OOD detection problem.		
			versions			