

Disturbance Short Report

Disturbance Recordings Information

Device Information

Recorder ID	1
IED type	RED670
IED version	2.2.3
Station name	SE LADERA 115kV
Object name	LINEA PANCE
IED name	FN02 T2038106

Fault Information

Trig date and time	18/02/2026 6:07:03.611 p. m.
Trigger signal name	GEN START PRO
Recording number	280
Total recording time	5000 ms
Pre-trig recording time	1000 ms
Post trig recording time	3923 ms
Max. recording time	4000 ms

General Recordings Information


Disturbance recorder	Installed
Event recorder	Installed
System frequency	60 Hz
Sampling frequency	1,2 kHz
Active setting group during recording	1


Fault Location Information

Fault type	L1-N
Fault loop type	L1-N
Fault location	2,7 km (50,9 %)
Status of fault calculation	Ok
Fault direction	Forward

Analog Time Diagram


Trig Date Time: 18/02/2026 6:07:03.611 p. m.





Binary Time Diagram


Trig Date Time: 18/02/2026 6:07:03.611 p. m.




Vector Diagrams

Calculation Time Period : 0,433 ms to 16,26 ms

Currents



Voltages



No.	Name	RMS	Angle
1	-4L110 CT IL1	4618,646(A)	129,3°
2	-4L110 CT IL2	388,05(A)	290,2°
3	-4L110 CT IL3	60,498(A)	14,6°
4	-4L110 CT ILN	4230,496(A)	130,5°
5	L4C IBIAS L1	3676,858(A)	26,8°
6	L4C IBIAS L2	330,831(A)	18,6°
7	L4C IBIAS L1	178,017(A)	190,8°
8	L4C IDL1 MAG	3676,858(A)	26,8°
9	L4C IDL2 MAG	330,601(A)	18,7°
10	L4C IDL3 MAG	75,337(A)	217,1°

No.	Name	RMS	Angle
1	-4PT110 UL1	15543,206(V)	177,2°
2	-4PT110 UL2	71709,695(V)	75,7°
3	-4PT110 UL3	68841,016(V)	321,5°
4	-4PT110 ULN	62493,688(V)	26,0°

Events List

Channel Number	Name	Status	Time
10	GEN START PRO	On	18/02/2026 6:07:03.611 p. m.
14	GEN START L1	On	18/02/2026 6:07:03.611 p. m.
52	EF4PTOC ST FW	On	18/02/2026 6:07:03.611 p. m.
54	EF4PTOC 2HRM	On	18/02/2026 6:07:03.611 p. m.
11	GEN START FW	On	18/02/2026 6:07:03.615 p. m.
60	ZMF STR FW L1	On	18/02/2026 6:07:03.615 p. m.
63	ZMF STR FW PE	On	18/02/2026 6:07:03.615 p. m.
64	ZMF STR	On	18/02/2026 6:07:03.615 p. m.
68	ZMF STR Z2	On	18/02/2026 6:07:03.615 p. m.
70	ZMF STR Z3	On	18/02/2026 6:07:03.615 p. m.
82	85-21 SEND	On	18/02/2026 6:07:03.615 p. m.
50	EF4PTOC STST1	On	18/02/2026 6:07:03.628 p. m.
54	EF4PTOC 2HRM	Off	18/02/2026 6:07:03.628 p. m.
57	ECPSCH CS	On	18/02/2026 6:07:03.636 p. m.
50	EF4PTOC STST1	Off	18/02/2026 6:07:03.661 p. m.
54	EF4PTOC 2HRM	On	18/02/2026 6:07:03.661 p. m.
5	-4L110 CLOSED	Off	18/02/2026 6:07:03.671 p. m.
134	4L110 CLS	Off	18/02/2026 6:07:03.671 p. m.
11	GEN START FW	Off	18/02/2026 6:07:03.685 p. m.
60	ZMF STR FW L1	Off	18/02/2026 6:07:03.685 p. m.
63	ZMF STR FW PE	Off	18/02/2026 6:07:03.685 p. m.
64	ZMF STR	Off	18/02/2026 6:07:03.685 p. m.
68	ZMF STR Z2	Off	18/02/2026 6:07:03.685 p. m.
70	ZMF STR Z3	Off	18/02/2026 6:07:03.685 p. m.
82	85-21 SEND	Off	18/02/2026 6:07:03.685 p. m.
52	EF4PTOC ST FW	Off	18/02/2026 6:07:03.686 p. m.

54	EF4PTOC 2HRM	Off	18/02/2026 6:07:03.686 p. m.
57	ECPSCH CS	Off	18/02/2026 6:07:03.686 p. m.
10	GEN START PRO	Off	18/02/2026 6:07:03.688 p. m.
14	GEN START L1	Off	18/02/2026 6:07:03.688 p. m.
95	L110 AUT SYN	Off	18/02/2026 6:07:03.754 p. m.
95	L110 AUT SYN	On	18/02/2026 6:07:03.936 p. m.
5	-4L110 CLOSED	On	18/02/2026 6:07:04.228 p. m.
134	4L110 CLS	On	18/02/2026 6:07:04.228 p. m.
90	L110 REC PR3P	On	18/02/2026 6:07:04.236 p. m.