



Product Service

Compliance Document

No. D 115067 0079 Rev. 00

Holder of Certificate: **Xiamen Kehua Digital Energy Tech Co., Ltd.**

Room 208-38, Hengye Building
No. 100 Xiangxing Road
Torch High-tech Zone
(Xiang'an) Industrial Zone
361115 Xiamen
PEOPLE'S REPUBLIC OF CHINA

Product: **Converter
(Energy Storage Inverter)**

This Compliance document confirms the compliance with the listed standards on a voluntary basis. It refers only to the sample submitted for testing and certification and does not certify the quality or safety of the serial products. For details see: www.tuvsud.com/ps-cert

Test report no.: 64290253034401

Date, 2025-08-14

Kennen Wang

(Kennen Wang)



Product Service

Compliance Document

No. D 115067 0079 Rev. 00

Model(s): BCS1000K-C-HUD, BCS1250K-C-HUD

Parameters:

Model	BCS1000K-C-HUD	BCS1250K-C-HUD
Battery input/output parameters		
Battery type	Lithium-ion / Lead-acid	
Maximum voltage [V _{DC}]	1500	
Battery rated voltage [V _{DC}]	1250	
Battery voltage range [V _{DC}]	1000 - 1500	
Maximum charge power [kW]	1078.0	1347.5
Maximum discharge power [kW]	1122.4	1403.0
Maximum charge current [A _{DC}]	1078.0	1347.5
Maximum discharge current [A _{DC}]	1122.4	1403.0
Grid terminal parameters		
Rated input/output voltage [V _{AC}]	3P+PE, 690	
Rated input/output frequency [Hz]	50 / 60	
Rated input/output current [A _{AC}]	836.8	1046.0
Maximum continuous input/output current [A _{AC}]	920.5	1150.6
Rated input/output active power [kW]	1000	1250
Maximum input/output active power [kW]	1100	1375
Maximum input/output apparent power [kVA]	1100	1375
Power factor range	0.9 inductive(under-excited) to 0.9 capacitive(over-excited)	

**Tested
according to:**

IEC 61727:2004
IEC 62116:2014