

Investment pack for M2 Ventures GmbH · Document 5 of 5 · Ref LCY-M2V-2026-05 · Confidential · September 2026

Sotira — 6.53 MWp east–west, with a 22.9 MWh battery sized to the site

6.53 MWp	YIELD MODELLED ON PVGIS 5.3	EAST–WEST 12.5°	22.9 MWh · THREE-AND-A-HALF HOUR
SOTIRA, FAMAGUSTA DISTRICT	ABOVE THE 5 MWp CEILING		

A 6.53 MWp east–west park at Sotira in the Famagusta District, on the geometry confirmed with the site owner: 12.5° tilt, 1,250 mm low-edge clearance, 10.603 m shed pitch, 359 strings of 28 bifacial Jinko 650 W modules into twenty Huawei 330 kW inverters. It is the only asset in this pack whose energy yield has been modelled from first principles against measured irradiance rather than taken from a design assumption, and it is included on that basis. It is also larger than the envelope in M2's brief.

6.53 MWp East–west 12.5°, bifacial	6.53 / 22.9 MW / MWh LFP, three-and-a-half hour	€8.48m Turnkey build cost, ex VAT	€1,199,100 Year 1 EBITDA, unlevered	14.1% Year 1 yield on cost
--	---	---	---	--------------------------------------

The yield is measured, not assumed — and it is lower than our other sites

Specific yield here is **1,806 kWh/kWp · yr** against 2,100–2,150 for the south-facing parks elsewhere in this pack. That is not a worse site; it is a different geometry, and the difference is fully explained. An east–west array at 12.5° gives up about 9% against a south-facing array at the same latitude, and the 88% ground coverage ratio that makes the layout fit the Poleodomia envelope also closes off the ground behind the modules, so bifacial gain is 3.6% rather than the 7–11% a widely spaced south-facing array achieves over white albedo. We have set the number out rather than smoothed it, because a yield figure that cannot be traced is worth nothing in diligence.

Configuration at this latitude	kWh/kWp · yr	Note
PVGIS south-facing optimum, 31°, front only	2,006	Theoretical ceiling for the location
Same modules, south 12°, front only	1,917	Orientation comparison
This plant, east–west 12.5°, front only	1,743	–9.1% for the east–west geometry
This plant with bifacial gain at albedo 0.25	1,806	+3.6%, limited by 88% ground coverage

Source: JRC PVGIS 5.3 (SARAH3, 2005–2023) at 35.01084°N, 33.94224°E, with a two-dimensional rear-side model on the PVGIS TMY. Front-side loss stack –11.2%, performance ratio 88.8%. Albedo band: 0.20 soil gives 1,795, 0.30 dry ground gives 1,818. DC/AC ratio 0.99, so no inverter clipping. This is an indicative energy note and not a bankable PVsyst P50/P90; a PVsyst run against the PAN and OND files remains the document a lender will want, and cable ohmic losses are not yet in the stack — each further 1% removes about 118 MWh a year.

Why the battery here is three and a half hours, not four

The four-hour ratio in Document 1 is not a house rule, it is the point at which the curtailed energy runs out. Lower specific yield means less curtailed energy per megawatt-peak, so that point arrives sooner. At Sotira the battery saturates at 22.9 MWh; a 26.1 MWh four-hour system would deliver **exactly the same energy** for a further €414,900 of capital. Sizing to the site rather than to the ratio is worth 0.4 points of yield.

Battery	Capacity	Capex	Delivered to evening market	Capture	Battery revenue
Two hours	13.07 MWh	€1,659,600	4,188 MWh	54.6%	€732,900
Three hours	19.60 MWh	€2,489,500	6,282 MWh	81.9%	€1,099,300
Three and a half hours — recommended	22.87 MWh	€2,904,400	6,532 MWh	85.2%	€1,143,200
Four hours — pack default	26.14 MWh	€3,319,300	6,532 MWh	85.2%	€1,143,200

At 65% curtailment. The fourth hour returns nothing at this site.

Year one

Energy and revenue	MWh	€/MWh	€	Turnkey build cost, ex VAT	€
Gross generation at 1,806 kWh/kWp	11,800	—	—	PV EPC — 6.534 MWp at €0.72/Wp	4,704,500
Exported directly (35%)	4,130	127	524,500	BESS EPC — 22.87 MWh at €127k/MWh	2,904,400
Recovered by battery, sold at night	6,532	175	1,143,200	Development, grid, permits, contingency	866,300
Curtailed, not recovered	1,138	—	—	Total, excluding land and acquisition	8,475,100
Gross energy revenue	10,662	156	1,667,700	Build cost per MWp	1,297,100
Aggregator and offtake fee, 10%			(166,800)	Year 1 yield on cost	14.1%
Operating cost — O&M, insurance, land			(301,900)	Simple payback, unlevered	7.1 years
Year 1 EBITDA, unlevered			1,199,100	Realised average price, all energy sold	€156/MWh

Same EPC and battery rates as every other asset in this pack. Land and acquisition terms are not settled and are excluded.

Sensitivity to curtailment

Curtailment	Exported	Recovered by battery	Gross revenue	Year 1 EBITDA	Yield on cost	Payback
35%	7,670 MWh	3,517 MWh	€1,589,700	€1,128,800	13.3%	7.5 yr
50% — 2025 national actual 47.4%	5,900 MWh	5,025 MWh	€1,628,700	€1,164,000	13.7%	7.3 yr
65% — 2026 national actual, base case	4,130 MWh	6,532 MWh	€1,667,700	€1,199,100	14.1%	7.1 yr
75%	2,950 MWh	7,329 MWh	€1,657,200	€1,189,600	14.0%	7.1 yr

Not modelled, and to the upside: an east–west array produces a flatter daily curve than a south-facing one, shifting output out of the midday hours where curtailment is concentrated and into the morning and late-afternoon shoulders where the grid still accepts it. That should raise the exported share above the 35% national average assumed here. Quantifying it needs half-hourly modelling against the site's own dispatch signal, which we have not yet done and have therefore taken no credit for.

Two things M2 should know before spending time on this one. At 6.53 MWp Sotira is above the 5 MWp ceiling in the original brief and cannot be trimmed without redoing the layout, which is fitted to the Poleodomia envelope at 6,534 kW. And unlike the other three assets, the commercial terms on which this site could be acquired or co-developed are not settled — this document describes an engineering case, not an agreed transaction. It is in the pack because the yield work behind it is the most rigorous we have, and because if M2's envelope is indicative rather than firm it is the largest single asset we can offer.

Contact. Alexander Papacosta, Managing Director · alexander.papacosta@lighthief.com · +357 99 164 158

Basis. Wholesale prices from published TSOC day-ahead market files, 1 Oct 2025 – 11 Feb 2026 (134 trading days, 6,432 half-hourly prints): daytime average €127/MWh, evening peak (17:00–21:00) average €183/MWh. This pack takes €175/MWh for evening capture, €8/MWh below the measured average. Curtailment base case of 65% is the published national rate for January–May 2026 (162 GWh curtailed); 2025 full year was 47.4% (306 GWh, CyprusGrid). Specific yield of 2,150 kWh/kWp · yr is the Lighthief design figure for fixed tilt 25° south with bifacial modules and white albedo; site-specific yield is confirmed by PVsyst before any commitment. Battery round-trip efficiency 87.8% AC–AC; effective capture of curtailed energy 85%, being daily-shape collection multiplied by round-trip efficiency. EPC rates €0.72/Wp (PV, turnkey) and €127,000/MWh (BESS, ex VAT) per the Lighthief EPC workbook v4, February 2026, and are indicative pending final specification and equipment pricing at the date of order. Revenues are stated after a 10% aggregator and offtake fee and before Cyprus corporate income tax, which rose from 12.5% to 15% on 1 January 2026. Figures are unlevered and exclude VAT. Merchant exposure to a day-ahead market with under two years of published price history is the single largest uncertainty in this case; no revenue is contracted.

Disclaimer. This document is confidential and is provided for information only under NDA LCY-NDA-M2V-2026-001. It is not an offer to sell, a solicitation to buy any security or interest, or investment advice. All figures are indicative and subject to confirmatory due diligence, final specification and site conditions. Actual results will differ. Recipients should form their own view and take their own tax, legal and technical advice. Binding figures are the downloadable Excel model available in the data room.