

Sotira PV — Famagusta

6.534 MWp east–west bifacial · 11.80 GWh independent yield · Cyprus (EU)

TOWN PLANNING LAYOUT SUBMITTED · NOT RTB

PREPARED FOR

M2 Ventures

Confidential · non-binding · indicative

PREPARED BY

Alexander Papacosta · Cyprus Director

Lighthief Cyprus Ltd · +357 99 164 158

6.534 MWp

DC · 6.60 MW AC · DC/AC
0.99

11.80 GWh

Annual AC with bifacial

1,806

kWh / kWp · year

€4.18M

Indicative PV EPC · ex VAT

A packed east–west bifacial plant at Sotira, Famagusta District, sized to the **6,534 kW** town-planning layout (Poleodomia). Independent check with JRC PVGIS 5.3 (SARAH3, 2005–2023) at 35.01084°N, 33.94224°E, plus a 2D rear-side model: **11,803 MWh/year AC**, **1,806 kWh/kWp**. Lighthief Cyprus can deliver EPC on this geometry. Not a bankable PVsyst P50/P90 and not a permitted RTB pack.

Investment highlights

- **Site-fit DC.** 10,052 × 650 W modules, 359 strings of 28 — sized to the 6,534 kW Poleodomia layout.
- **No inverter clipping.** 20 × Huawei 330 kW; DC/AC 0.99.
- **Measured resource, not a brochure yield.** Front 1,743 kWh/kWp; +3.6% bifacial at albedo 0.25.
- **EU jurisdiction.** Cyprus CIT 12.5%; wholesale DAM in operation.
- **Clear next work.** Bankable PVsyst, grid application, EPC contract. Town planning is in process, not complete.

Monthly AC (with bifacial)



Season	MWh	Share
Q1 (Jan–Mar)	2,115	18%
Q2 (Apr–Jun)	3,928	33%
Q3 (Jul–Sep)	3,852	33%
Q4 (Oct–Dec)	1,910	16%
Year	11,803	100%

July peak 1,452 MWh · December 484 MWh. Capacity factor 20.6%.

Plant as modelled

Item	Value
Location	Sotira, Famagusta · 35.010841°N, 33.942242°E · 64 m
Module	Jinko 650 W n-type bifacial (JKM650N-66QL6-BDV) · ϕ 0.85
Inverters	20 × Huawei SUN2000-330KTL-H1 · 6.60 MW AC
Geometry	East–west 12.5° · 1,250 mm low edge · tent pitch 10.603 m
Strings	359 × 28 modules = 10,052 pcs = 6.534 MWp
Land GCR	~88% (1.23 m aisle) — why bifacial gain is 3.6%, not 8–10%
Storage on layout	2 MWh unit shown on Poleodomia drawing — not a 4-hour hybrid

Independent yield

Case	MWh/y	kWh/kWp
Front only (PVGIS)	11,390	1,743
Albedo 0.20	11,727	1,795
Design albedo 0.25	11,803	1,806
Albedo 0.30	11,879	1,818
Same DC, south 12° (front)	12,529	1,917
PVGIS south optimum 31°	13,109	2,006

PVGIS 5.3 PVcalc + pvlib 0.15 infinite sheds on SARAH3 TMY. East–west is the site-fit choice, not the energy-maximising tilt.

Indicative commercial — PV EPC only

Item	Basis	Amount
PV EPC (development, client price)	6.534 MWp × €640,000/MWp	€4.18 million
Gross energy (design bifacial)	11,803 MWh/year	11.80 GWh
Illustrative uncurtailed DAM	11,803 MWh × €141/MWh	€1.66 million
Illustrative 50% curtailment case	5,902 MWh × €141/MWh	€832 thousand

EPC is Lighthief's Cyprus development rate, ex VAT, excluding land, RTB, grid works, interconnection, and storage. €141/MWh is the Cyprus DAM daytime reference used in Lighthief investor materials — not a PPA and not a forecast. Site offtake, curtailment, and a larger BESS are not modelled. No IRR is stated until those are fixed.

Status and next steps

Item	Status
Town planning (Poleodomia)	Layout submitted — park titled 6,534 kW + 2 MWh BESS. Permit not issued.
CERA production licence / building permit / grid	Not claimed in this teaser. To be confirmed in diligence.
Energy yield	Independent PVGIS + bifacial check complete. PVsyst P50/P90 still required for lenders.
EPC	Lighthief Cyprus can contract the 12.5° / 1,250 mm geometry as modelled.
Storage	2 MWh on the planning drawing only. A curtailment-capture BESS would be a separate specification.

This document is strictly confidential, prepared solely for M2 Ventures, and is not an offer to sell securities or a commitment to transact. Figures are indicative. Cable ohmic losses were not in the source loss list (~118 MWh/year per extra 1%). Bankable file remains PVsyst with the manufacturer PAN/OND. Contact: Alexander Papacosta, Cyprus Director · +357 99 164 158 · office@lighthief.com.