



Medium Voltage Transformer Datasheet

4000kVA

MV Transformer



Item	SL-4000/15	SL-4000/20	SL-4000/30
Type	oil immersed	oil immersed	oil immersed
Rated power(kVA)	4000@ 40℃	4000@ 40℃	4000@ 40℃
Rated frequency(Hz)	50	50	50
Vector group	Dy11	Dy11	Dy11
Rated voltage(kV)	15/0.69	20/0.69	30/0.69
Rated current(A)	154/3347	115.5/3347	77/3347
Tap changer	0, ± 2x2.5%	0, ± 2x2.5%	0, ± 2x2.5%
Minimum Peak Efficiency Index(PEI)	Tier 2 Eco Design	Tier 2 Eco Design	Tier 2 Eco Design
No-load loss(kW)	~2.86	~2.86	~2.86
Short circuit loss/load loss(kW)	~32.7	~32.7	~32.7
NO-load current	<0.45%	<0.45%	<0.45%
Short-circuit impedance	8%	8%	8%
IP Grade	IP68@oil tank	IP68@oil tank	IP68@oil tank
Noise level	<65dB	<65dB	<65dB
Cooling method	ONAN	ONAN	ONAN
Altitude	1000m	1000m	1000m
Ambient temperature(℃)	-25~+40@full load	-25~+40@full load	-25~+40@full load
Ambient humidity	0~100%	0~100%	0~100%
Insulation level	A	A	A
Oil type	Mineral oil	Mineral oil	Mineral oil
Oil-temperature Alarm	YES	YES	YES
Oil-temperature	YES	YES	YES

Trip			
Oil level Alarm	YES	YES	YES
Oil level Trip	YES	YES	YES
Certificate	IEC60076	IEC60076	IEC60076



- END -

XIAMEN KEHUA DIGITAL ENERGY TECH CO.,LTD
ADD: ROOM 208-38, HENGYE BUILDING, NO.100 XIANGXING ROAD, TORCH
HIGH-TECH ZONE (XIANGAN) INDUSTRIAL ZONE, XIAMEN,CHINA
Tel: +86-592-5160516
Fax: +86-592-5162166
Email: Intertrade@kehua.com