



Ref. Certif. No.

SG PSB-IT-00502

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT
(IECEE) CB SCHEME

CB TEST CERTIFICATE

Product	Converter
Name and address of the applicant	Xiamen Kehua Digital Energy Tech Co., Ltd. Room 208-38, Hengye Building No. 100 Xiangxing Road Torch High-tech Zone (Xiang'an) Industrial Zone 361115 Xiamen PEOPLE'S REPUBLIC OF CHINA
Name and address of the manufacturer	Xiamen Kehua Digital Energy Tech Co., Ltd. Room 208-38, Hengye Building, No. 100 Xiangxing Road, Torch High-tech Zone, (Xiang'an) Industrial Zone, 361115 Xiamen, PEOPLE'S REPUBLIC OF CHINA
Name and address of the factory	Zhangzhou Kehua New Energy Technology Co., Ltd. No.10, Kongxue Road, Wenpu Industrial Zone, Jiaomei Industrial Zone Comprehensive Development District, Longhai District, 363107 Zhangzhou City, Fujian, PEOPLE'S REPUBLIC OF CHINA
Ratings and principal characteristics	See page 2
Trademark / Brand (if any)	See page 2
Model/type Ref.	BCS1250K-C-HUD, BCS1000K-C-HUD
A sample of the product was tested and found to be in conformity with	IEC 62477-1:2012 IEC 62477-1:2012/AMD1:2016
as shown in the Test Report Ref. No. which forms part of this certificate	085-253032901-000

Page 1 of 2

This CB Test Certificate is issued by the National Certification Body

CBS 115067 0073 Rev. 00

Date, 2025-07-24

(Billy Qiu)

TÜV SÜD PSB Pte Ltd 15 International Business Park TÜV SÜD @ IBP Singapore 609937



PSB Singapore

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT (IECEE) CB SCHEME

Trademark / Brand (Image)


Ratings and principal characteristics

Model:	BCS1000K-C-HUD	BCS1250K-C-HUD
Battery terminal parameters:		
Battery type	Lithium or lead-acid	Lithium or lead-acid
Maximum voltage [Vd.c.]	1500	1500
Rated voltage [Vd.c.]	1250	1250
Battery voltage range [Vd.c.]	1000-1500	1000-1500
Maximum charging power [kW]	1078	1347.5
Maximum discharging power [kW]	1122.4	1403
Maximum continuous charging current [Ad.c.]	1078	1347.5
Maximum continuous discharging current [Ad.c.]	1122.4	1403
AC parameters:		
Maximum apparent power [kVA]	1100	1375
Maximum active power [kW]	1100	1375
Rated voltage [Va.c.]	690, 3W+PE	690, 3W+PE
Maximum continuous current [Aa.c.]	920.5	1150.6
Rated frequency [Hz]	50/60	50/60
General		
Operating temperature range [°C]	-40~60	-40~60
Protective class	Class I	Class I
Ingress protection	IP65(except air duct)	IP65(except air duct)

Page 2 of 2

This CB Test Certificate is issued by the National Certification Body

CBS 115067 0073 Rev. 00

Date, 2025-07-24



(Billy Qiu)

TÜV SÜD PSB Pte Ltd 15 International Business Park TÜV SÜD @ IBP Singapore 609937



PSB Singapore