



Product Service

CERTIFICATE

No. B 115067 0081 Rev. 00

Holder of Certificate: **Xiamen Kehua Digital Energy
Tech Co., Ltd.**

Room 208-38, Hengye Building
No. 100 Xiangxing Road
Torch High-tech Zone
(Xiang'an) Industrial Zone
361115 Xiamen
PEOPLE'S REPUBLIC OF CHINA

Certification Mark:



Product: **Converter**

The product was tested on a voluntary basis and complies with the essential requirements. The certification mark shown above can be affixed on the product. It is not permitted to alter the certification mark in any way. In addition, the certification holder must not transfer the certificate to third parties. This certificate is valid until the listed date, unless it is cancelled earlier. All applicable requirements of the Testing, Certification, Validation and Verification Regulations of TÜV SÜD Group have to be complied. For details see: www.tuvsud.com/ps-cert

Test report no.: 64290253033201

Valid until: 2030-08-28

Date, 2025-08-29

(Billy Qiu)

CERTIFICATE

No. B 115067 0081 Rev. 00

Model(s): **BCS1250K-C-HUD, BCS1000K-C-HUD**

Parameters:

Model:	BCS1000K-C-HUD	BCS1250K-C-HUD
Battery terminal parameters:		
Battery type	Lithium or lead-acid	
Maximum voltage [Vd.c.]	1500	
Rated voltage [Vd.c.]	1250	
Battery voltage range [Vd.c.]	1000-1500	
Maximum charging power [kW]	1078	1347.5
Maximum discharging power [kW]	1122.4	1403
Maximum continuous charging current [Ad.c.]	1078	1347.5
Maximum continuous discharging current [Ad.c.]	1122.4	1403
AC parameters:		
Rated voltage [Va.c.]	690, 3W+PE	
Rated frequency [Hz]	50/60	
Maximum apparent power [kVA]	1100	1375
Maximum active power [kW]	1100	1375
Rated active power [kW]	1000	1250
Maximum continuous current [Aa.c.]	920.5	1150.6
General		
Operating temperature range [°C]	-40~60	
Protective class	Class I	
Ingress protection	IP65(except air duct)	

Tested according to: IEC 62909-1:2017
EN IEC 62909-1:2018
IEC 62909-2:2019
EN IEC 62909-2:2019
IEC 62477-1:2012
IEC 62477-1:2012/AMD1:2016
EN 62477-1:2012/A12:2021
IEC 61727:2004