



	1	2	3	4	5	6	7	8
A	(21) Distance Relay , Phase (21N) Distance Relay , Ground (25) Synchronism Check (27) Undervoltage Protection (49) Thermal Overload			(87N) Differential Protection, Restricted Earth Fault (87T) Differential Protection, Transformer (RI) Reverse Interlocking (30) Annunciator relay (28 Relays) (3I) 3 – Phase Current Measurement (3U) 3 – Phase Voltage Measurement (f) Frequency Measurement (Q) Reactive Power Measurement (P) Active Power Measurement (P.f.) Power Factor Measurement (U) 1 – Phase Voltage Measurement			MCS Measuring Circuit Supervision CBCM Circuit Breaker Condition Monitoring LOR Lock-out Relay TCS Trip Circuit Supervision Local / Remote Interface Bay Orientated Interlocking Logic FR Fault Recording Automatic Voltage Regulation Manual Voltage Regulation MMI/Mimic Display Energy counter, Forward or Reverse Active / Reactive	
B	(50) Instantaneous Overcurrent (50B) Breaker Failure (50N) Instantaneous Ground Fault, Overcurrent (51Ns) Sensitive Ground Fault (51) Overcurrent With Time Delay							
C	(51N) Ground Fault With Time Delay (59) Overvoltage Protection (67) Directional Overcurrent (67N) Directional Ground Fault (67Ns) Directional Sensitive Ground Fault							
D	(79) Auto – Reclosing Relay (81U) Underfrequency Relay (81O) Overfrequency Relay							
E	(86) Lockout Relay (87B) Differential Protection, Busbar (87L) Differential Protection, Line							
F	AM./REV	ΠΕΡΙΓΡΑΦΗ / DESCRIPTION	HMEP./DATE EA/CHEC. AUTOCAD FILE	APRIL 2003 NTS AH DCh DCh	APXH ΗΛΕΚΤΡΙΣΜΟΣ ΚΤΙΡΙΟΤ ELECTRICITY AUTHORITY CYPRUS KENTRIKA ΓΡΑΦΕΙΑ / HEAD OFFICE	ΕΡΓΟ / PROJECT ΤΙΤΛΟΣ / TITLE PROTECTION & CONTROL SYMBOL NOTATION	KATAΚΕΤΑΣΤΗΣ / MANUFACTURER DRG. REF.: - CONTRACT No.: - AP.ΣΧ. / DRG No.	- - Sh. 01 of. 01
	1	2	3	4	5	6	7	8

3-50Hz 22-11kV 2000A 20kA 3-Sec.




check





To be supplied by EAC

main



To be supplied by EAC



ΑΛΛ./REV	ΠΕΡΙΓΡΑΦΗ / DESCRIPTION	ΗΜΕΡ./DATE	ΕΛ./CHEC.	ΗΜΕΡ./ DATE	JAN 2011	ΑΡΧΗ ΗΛΕΚΤΡΙΣΜΟΥ ΚΤΗΡΙΟΤ  ΕΛΕΚΤΡΙΚΗ ΑΥΤΟΡΙΑ ΚΥΠΡΟΣ ΚΕΝΤΡΙΚΑ ΓΡΑΦΕΙΑ / HEAD OFFICE	ΕΠΦΟ / PROJECT 22-11kV SWITCHBOARD ΤΙΤΛΟΣ / TITLE 22kV WINDFARM FEEDER PROTECTION SCHEME	ΚΑΤΑΣΚΕΥΑΣΤΗΣ / MANUFACTURER	B
				DRG. REF.: -	=JZ--				
				CONTRACT No.: -	Sh. 02				
				ΑΡ.ΣΧ. / DRG No. 1S000J8A00S0B000	of. 03				

