


CASMO-4E

Extended Capability CASMO-4

User's Manual



Studsvik

Restricted Distribution - University Release

LEGAL NOTICE

This document was prepared by Studsvik Scandpower, Inc.

Neither Studsvik Scandpower, Inc. (SSP) nor any person acting on behalf of SSP:

- A Makes any warranty or representation, express or implied, with respect to the accuracy, completeness, or usefulness of the information contained in this document, or that the use of any information, apparatus, method, or process disclosed in this document may not infringe privately owned rights or:
- B Assumes any liabilities with respect to the use of, or for damages resulting from the use of any information, apparatus, method or process disclosed in this document.

PROPRIETARY INFORMATION NOTICE

This document is transmitted as part of a license agreement. The recipient shall not reproduce, copy, publish, or otherwise disclose it or the information therein to others without the written consent of SSP.

Copyright 2009, Studsvik Scandpower, Inc.

Table of Contents

| | | |
|----------|-------------------------------------------|------------|
| 1 | CASMO-4E | 1-1 |
| 1.1 | CASMO-4E Overview | 1-1 |
| | | |
| 2 | CASMO-4E Input | 2-1 |
| 2.1 | MxN Input | 2-5 |
| 2.2 | Fuel Storage Rack Input | 2-33 |
| 2.3 | Hexagonal Geometry Input | 2-41 |
| 2.4 | Cluster/Magnox/AGR Input | 2-49 |
| 2.5 | Pn-Scattering Input | 2-57 |
| 2.6 | Miscellaneous Input | 2-61 |
| 2.7 | Input Examples | 2-69 |
| | | |
| 3 | MxN Description | 3-1 |
| 3.1 | General Description of MxN Capability | 3-3 |
| 3.2 | MxN Methodology | 3-4 |
| 3.3 | MxN Depletion Calculations | 3-5 |
| 3.4 | MxN Boundary Conditions | 3-5 |
| 3.5 | Empty Locations: Autogenerated Reflectors | 3-5 |
| 3.6 | Using Single Assembly CASMO Restart Files | 3-6 |
| 3.7 | Boron Letdown During MxN Depletion | 3-7 |
| 3.8 | Axis Spanning Assemblies | 3-7 |
| 3.9 | MxN Shuffle Capability | 3-7 |
| 3.10 | B.P. Shuffle Model | 3-8 |
| 3.11 | Shutdown Cooling Calculation | 3-8 |
| 3.12 | Baffle/Barrel/Pad Automation | 3-9 |
| 3.13 | MxN Output Edits | 3-10 |
| 3.14 | MxN SUMMARY File | 3-10 |
| 3.15 | Maximum MxN Problem Size and Resources | 3-11 |

| | | |
|----------|-------------------------------------------------|------------|
| 4 | Fuel Storage Rack | 4-1 |
| 4.1 | General Description of FSS/FSC Capability | 4-3 |
| 4.2 | Special Features of the FSS/FSC Calculation | 4-3 |
| | | |
| 5 | Hexagonal Model Description | 5-1 |
| 5.1 | General Description of Hexagonal Capability | 5-3 |
| | | |
| 6 | Pn-Scattering Model Description | 6-1 |
| 6.1 | General Description of Pn-Scattering Capability | 6-3 |
| | | |
| 7 | ENDF/B-VI Neutron Data Library | 7-1 |
| 7.1 | ENDF-B/VI Overview | 7-3 |
| 7.2 | Heavy Nuclide Chains in E6 | 7-30 |
| 7.3 | Fission Product Chains in E6 | 7-33 |
| 7.4 | Burnable Absorber Chains in E6 | 7-42 |

List of Figures

| | | |
|-----------|------------------------------------------------------------------------|------|
| Fig. 2.1 | PWR Ex-core Regions | 2-22 |
| Fig. 2.2 | BWR Ex-core Regions | 2-22 |
| Fig. 2.3 | Angular co-ordinate system for placement of pads outside of the barrel | 2-24 |
| Fig. 2.4 | Specification of FSS/FSC Fuel Storage Rack Geometry | 2-37 |
| Fig. 2.5 | RBMK Example | 2-51 |
| Fig. 2.6 | Cluster Geometry | 2-52 |
| Fig. 2.7 | Diagram of MxN Input Example 1 (Mixed 3x3 BWR) | 2-72 |
| Fig. 2.8 | Diagram of MxN Input Example 2 (1/8 Core Model) | 2-75 |
| Fig. 2.9 | Diagram of MxN Input Example 3 (1/4 Core PWR Pre-Shuffle) | 2-80 |
| Fig. 2.10 | Diagram of MxN Input Example 4 (1/4 Core PWR Post Shuffle) | 2-85 |
| Fig. 3.1 | MxN Segment Numbering | 3-3 |
| Fig. 3.2 | Placement of Segments into MxN Background Mesh | 3-4 |
| Fig. 3.3 | MxN Axis Spanning Assemblies | 3-7 |
| Fig. 4.1 | Example FSS/FSC fuel rack model | 4-4 |
| Fig. 7.1 | E6 Heavy Nuclides: Lower Part (to Am-244) | 7-31 |
| Fig. 7.2 | E6 Heavy Nuclides: Upper Part (to Cf-252) | 7-32 |
| Fig. 7.3 | E6 Fission Products Mass Numbers 76-87 | 7-34 |
| Fig. 7.4 | E6 Fission Products Mass Numbers 88-100 | 7-35 |
| Fig. 7.5 | E6 Fission Products Mass Numbers 100-110 | 7-36 |
| Fig. 7.6 | E6 Fission Products Mass Numbers 110-121 | 7-37 |
| Fig. 7.7 | E6 Fission Products Mass Numbers 122-132 | 7-38 |
| Fig. 7.8 | E6 Fission Products Mass Numbers 133-144 | 7-39 |
| Fig. 7.9 | E6 Fission Products Mass Numbers 142-151 | 7-40 |
| Fig. 7.10 | E6 Fission Products Mass Numbers 152-160 | 7-41 |
| Fig. 7.11 | E6 Burnable Absorbers: Ag, Cd, In | 7-42 |

List of Tables

| | | |
|-----------|--------------------------------------------|------|
| Table 2.1 | List of Input Cards by Module | 2-3 |
| Table 7.1 | Group Boundaries for the ENDF/B-VI Library | 7-5 |
| Table 7.2 | Nuclides for the ENDF/B-VI Library | 7-7 |
| Table 7.3 | Edited Fission Products | 7-19 |
| Table 7.4 | Lumped Fission Product Nuclides ID=401 | 7-19 |
| Table 7.5 | Lumped Fission Product Nuclides ID=402 | 7-19 |
| Table 7.6 | Lumped Fission Product Nuclides ID=403 | 7-20 |
| Table 7.7 | Temperatures for the ENDF/B-VI Library | 7-21 |

1 CASMO-4E

1.1 CASMO-4E Overview

CASMO-4E is an extended version of the lattice physics code CASMO-4 which has additional, optional capabilities beyond the base version. Some of these capabilities offer extensive functionality well beyond the standard CASMO-4, e.g., the MxN model which can perform full core, 2D transport theory calculations.

The optional CASMO-4E modules include:

- 1) MxN calculation (arbitrary arrangements of multiple fuel assemblies)
- 2) Generalized fuel storage rack calculation
- 3) Hexagonal geometry calculations (VVER-440 and VVER-1000)
- 4) Calculations with ENDF/B- VI library
- 5) Cluster/Magnox/AGR calculations
- 6) Azimuthal depletion (AZI and LAZ)
- 7) Pn-scattering model

This document covers the additional cards needed for the above models. For the description of input cards not documented here, the user is referred to the base CASMO-4 User's Manual.

2 CASMO-4E Input

CASMO-4E follows the same input convention as CASMO-4. The CASMO-4E input is divided into data blocks (in the following for brevity called "cards"), which are identified by an alphanumeric string of three characters. The input of one card may be given on one or several lines and several cards are allowed on the same line. Each line may contain up to 80 characters. Data beyond column 80 will generate a fatal error. A card name or any other input parameter must not be divided on two lines.

Input parameters are given in a way similar to (but not identical to) standard format free FORTRAN. Parameters are separated by a separator: **blank ()**, **comma (,)**, **equal sign (=)**, **semicolon (;)**, or **the end of a line**. A **slash (/)** is used as a separator between arrays of variable length. A separator may be surrounded by any number of blanks.

The three character card identifier must be surrounded by separators. A **slash is not allowed in the first position after the card identifier**, i.e., the card name must be followed by one of the other separators, e.g., by a blank. All **alphanumeric character strings other than card identifiers must be contained within single quotes (')**, e.g., 'MOD'.

A repetition factor can be used to specify the same parameter value to several consecutive positions. **The repetition factor is an integer immediately followed by an asterisk and the parameter value**, e.g., 4*1 is identical to 1,1,1,1.

A position for a parameter value can be skipped in input by inputting two consecutive commas. The default value or the value from the previous card of the same type then remains unaltered. If a card of the same type is given more than once in the input, then **the parameters of the last card overwrites earlier data**. This is also the case for stacked cases and restart cases (where CASMO-4E reads the original input from the restart file).

A slash is not needed at the end of a card.

Comments can be written on any input card after an asterisk, which must be preceded by a separator. This feature also allows extra comment cards starting with an asterisk.

Tabs and other hidden characters should be avoided in the input.

The input description in Section 2 divides the cards into five categories, viz.

| | | |
|------------|---------------------------------|-----------|
| 2.1 | MxN Input | 5 |
| 2.2 | Fuel Storage Rack Input | 33 |
| 2.3 | Hexagonal Geometry Input | 41 |
| 2.4 | Cluster/Magnox/AGR Input | 49 |
| 2.5 | Pn-Scattering Input | 57 |
| 2.6 | Miscellaneous Input | 61 |
| 2.7 | Input Examples | 69 |

Default values are provided whenever it is possible. **SSP recommends that the default values be used as much as possible.** This reduces the risk of input errors and makes the input shorter and easier to check. The user should not change defaults for options in the program unless there is a clear understanding of how that specific option affects the calculation.

The user should not stack cases of different type, e.g., a single bundle and a 2x2 segment calculation. Multiple depletion and coefficient calculations can be stacked. Coefficient calculations are allowed in the same run as the depletion(s), i.e., CASMO-4E can generate and read a restart file in the same run. Colorset cases may not be stacked.

Most input cards can be combined. There are of course, some obvious exceptions where the cards would be contradictory. There are also certain limitations in the code. It has been attempted to mark in the input description when particular combinations of cards are not allowed.

CASMO-4E uses **metric units** if nothing else is clearly marked in the description of the input card. Units not generally marked in the manual are:

| | |
|--------------------|---------------------------|
| Material densities | gram/cm ³ |
| Temperatures | K (Kelvin) |
| Dimensions | cm |
| Burnup (Exposure) | MWd/kg (= GWd/metric ton) |

CASMO-4E performs an automatic **thermal expansion** of dimensions and densities. This automatic thermal expansion can be bypassed by using the THE card.

Table 2.1 lists all input cards by module and shows where to find the detailed input description.

Table 2.1 List of Input Cards by Module

| | Card | Description | Page |
|------------|------------------------------------------------|----------------------------------------------------------|-------------|
| 2.1 | MxN Input | | 5 |
| | Required: | | |
| | MXN | Multi-segment input | 7 |
| | LSE | Layout of segments for MxN | 9 |
| | BAS | Base segment data | 10 |
| | SEG | Segment data | 11 |
| | Optional MxN Statepoint Parameter Maps: | | |
| | LCR | Control rod disposition map | 12 |
| | LEX | Exposure map | 13 |
| | LRO | Segment rotation map | 14 |
| | LSD | Shutdown cooling Map (SDC) | 15 |
| | LTF | Fuel temperature map | 16 |
| | LTM | Moderator temperature map | 17 |
| | LVD | Void map | 18 |
| | Optional MxN Baffle/Barrel/Pad Model: | | |
| | BAF | Ex-core PWR baffle auto-generation | 19 |
| | BRL | PWR barrel or BWR shroud auto-generation | 20 |
| | PAD | PWR pad or BWR vessel auto-generation | 23 |
| | Optional MxN Miscellaneous Input: | | |
| | BPS | B.P. shuffle | 27 |
| | S3I | Generate equivalent SIMULATE input | 28 |
| | SMR | Gamma smearing factor for MxN | 29 |
| | SSA | Sigma-transport correction for steel in baffle/reflector | 30 |
| | SUM | Generate MxN Summary File | 31 |
| 2.2 | Fuel Storage Rack Input | | 33 |
| | FSS | Fuel Storage Rack Side | 34 |
| | FSC | Fuel Storage Rack Corner | 38 |
| 2.3 | Hexagonal Geometry Input | | 41 |
| | HEX | Hexagonal Geometry Option | 42 |
| | PIN | Pin Geometry | 45 |

| | Card | Description | Page |
|------------|---------------------------------|--------------------------------------------------------|-------------|
| 2.4 | Cluster/Magnox/AGR Input | | 49 |
| | CLU | Cluster specification (RBMK and CANDU) | 50 |
| | MAG | Pin cell for British Magnox fuel | 54 |
| | AGR | Cluster specification for British AGR assembly designs | 55 |
| 2.5 | Pn-Scattering Input | | 57 |
| | PNO | Pn-scattering order for advanced data libraries | 58 |
| | UNQ | Uniform quadrature for 2D transport calculation | 59 |
| 2.6 | Miscellaneous Input | | 61 |
| | AZI | Azimuthal subdivision of pins | 62 |
| | LAZ | Layout of azimuthal subdivision of pins | 63 |
| | OFF | Turn off models | 64 |
| | PSC | Generate color graphic of geometry | 28 |
| | PSF | Filename for PostScript/Tiff graphic | 67 |
| | QCK | Quick execution | 68 |
| 2.7 | Input Examples | | 69 |

2.1 MxN Input

| Card | Description | Page |
|--------------------------------------------------|----------------------------------------------------------|------|
| Required: | | |
| MXN | Multi-segment input | 7 |
| LSE | Layout of segments for MxN | 9 |
| BAS | Base segment data | 10 |
| SEG | Segment data | 11 |
| Optional MxN Statepoint Parameter Maps: | | |
| LCR | Control rod disposition map | 12 |
| LEX | Exposure map | 13 |
| LRO | Segment rotation map | 14 |
| LSD | Shutdown cooling Map (SDC) | 15 |
| LTF | Fuel temperature map | 16 |
| LTM | Moderator temperature map | 17 |
| LVD | Void map | 18 |
| Optional MxN PWR Baffle/Barrel/Pad Model: | | |
| BAF | Ex-core PWR baffle auto-generation | 19 |
| BRL | PWR barrel or BWR shroud auto-generation | 20 |
| PAD | PWR pad or BWR vessel auto-generation | 23 |
| Optional Miscellaneous MxN Related Input: | | |
| AUT | Automated reflector pitch | 27 |
| BPS | B.P. shuffle | 27 |
| S3I | Generate equivalent SIMULATE input | 28 |
| SMR | Gamma smearing factor for MxN | 29 |
| SSA | Sigma-transport correction for steel in baffle/reflector | 30 |
| SUM | Generate MxN Summary File | 31 |

This section describes the CASMO-4E MxN function which allows for a more general specification of problem geometry than can be given on the BWR/PWR or BAS (2x2 segment input) cards. This module allows CASMO-4E to model large configurations, e.g., 1/4 or full core using full 2D characteristics transport theory.

The cards MXN, LSE, LRO, LCR, LVD, LTF, LTM, LEX, LSD, BPS, BAF, BRL, PAD, SUM, S3I, AUT, and SMR are MxN specific cards. The cards: BAS, SEG may be used in other calculations, e.g., standard 2x2 colorsets.

No cards other than LSE, LRO, LCR, LVD, LTF, LTM, LSD, LEX, BAF, BRL, PAD, BPS, and SUM are allowed between the MXN and BAS cards. **The MXN card must immediately follow the TTL card.**

The LSE card must be the first card of the “MxN Map cards” since it provides the master layout of the calculation. Any BAF, BRL or PAD cards must precede the LSE map.

For MxN applications the user will most likely need to use the MEM card and the FIL card as described in the base CASMO-4 manual.

Card image files are not generated for MxN calculations and automated coefficient calculations (including S3C) are not available. Furthermore, stacked cases are not supported for MxN calculations.

MXN Multi-segment input

| MXN | ISYM, IAXIS, PRIMXN, IBUNEXP |
|------------|-------------------------------------|
|------------|-------------------------------------|

| | |
|---------|------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|
| ISYM | Problem symmetry indicator: 1 Full rectangular problem geometry. 2 Diagonal problem symmetry. Only diagonally symmetric assemblies are allowed on the diagonal. All input must truly be diagonally symmetric. This option applies diagonal symmetry only in the 2D characteristics solution (which can save considerable memory). If diagonal symmetry is requested, the various MxN related maps, e.g., LSE, LRO etc. must still be input in full geometry. |
| IAXIS | Axis spanning assemblies 0 Axis spanning assemblies not present (BWR and even lattice PWRs) 1 Axis spanning assemblies present on north and west sides (typically odd lattice PWR) (not available for rotational B.C.) |
| PRIMXN | MxN edit control 1 Minimal assembly oriented output --This is an edit control flag 2 Maximum assembly oriented output (includes pin by pin output) 3 Not currently used 4 Mega-option. Adds additional data for auto-generated assemblies which would normally be suppressed. |
| IBUNEXP | Restart file exposure interpretation 0 Interpret restart files as marked (when read) with cycle exposure 1 Interpret restart files as marked (when read) with assembly average exposure |

Default:

| | |
|---------|---|
| ISYM | 1 |
| IAXIS | 0 |
| PRIMXN | 1 |
| IBUNEXP | 0 |

Example:

```
MXN 1 * Default full problem geometry
MXN 2 1 * Diagonal symmetry with axis spanning assembly
```

Comment:

1. The MxN card signals to CASMO that it is to perform an MxN calculation. This card may not appear in a single assembly or standard 2x2 calculation. The MXN card must follow immediately after the TTL card.
2. The axis spanning assembly option is limited to 1/4 core, i.e., both major axes contain axis spanning assemblies --half core modeling is not available. The spanning axes are the north and west sides. One caveat when using the axis spanning assembly option is that if an axis spanning assembly has an odd number of pin, then **all axis spanning assemblies must have the same number of pins**.
3. Requesting PRIMXN=2 or 4 can generate large output files.
4. The IBUNEXP parameter is relevant only if performing a calculation which reads pre-existing CASMO restart files.
The MxN input follows a strict hierarchy of order dependent input cards. An MxN input deck should be structured as follows:

```

MEM (if needed)  * dynamic memory
TTL (required)   * Title cards
MXN (required)   * MxN sentinel
BAF (optional)   * PWR baffle
BRL (optional)   * PWR barrel
PAD (optional)   * PWR pad
LSE (required)   * Layout of MxN segments
LRO (optional)   * Input rotation map
LCR (optional)   * Control rod maps
LTF (optional)   * Fuel temperature maps
LTM (optional)   * Moderator temperature maps
LVD (optional)   * Void maps
LSD (optional)   * Shutdown cooling map
LEX (optional)   * Exp map (present only if using restart files)
BAS
    Data common to all segments
SEG 1
    Segment 1 data
SEG 2
    Segment 2 data
    .      .      .
    .      .      .
    .      .      .
SEG N
    Segment N data
STA
```

LSE Layout of segments for MxN

| LSE | N_1 | N_2 | N_3 |
|------------|-------|-------|--------------------|
| | - | - | - |
| | - | - | - |
| | - | - | N_n /NLSEX NLSEY |

N_i Segment number (matching a segment number given on SEG card later in the input).
The same segment can be placed in more than one position. A zero in a position indicates that an autogenerated reflector occupies that position.

NLSEX Number of segments in the x direction.

NLSEY Number of segments in the y direction.

Default: None

Example:

```
LSE
1 2 0
2 3 2
0 2 1 / 3 3    * A 3x3 assembly layout with 2 water holes
```

Comment:

1. This card is required for all MxN calculations.
2. Placing a 0 in the LSE map indicates that the assembly location is vacant and CASMO will create an appropriate composition in that location (unvoided water) for an auto-generated reflector segment (unvoided water) or an appropriate PWR baffle, barrel, and pads if requested. The moderator temperature for these auto-generated segments is taken from the TMO card located in the BAS section of the input.
3. The LSE map is the "MASTER MAP" for the MxN input and as such must proceed any of the other MxN map cards such as LEX, LTF, LTM, LVD, LSD, LCR, LRO etc.
4. If running in diagonal symmetry, the entire LSE map (NLSEX by NLSEY) must still be input.

BAS Base problem data

| | |
|------------|--|
| BAS | |
|------------|--|

Default: None

Comment:

Data that is common to all segments is to follow the BAS card. After an MXN card, no parameters should be given on the BAS card (unlike a BAS card in a standard 2x2 calculation). An MxN input deck should roughly be structured:

- MEM (if needed) * dynamic memory
- TTL (required) * Title card
- MXN (required) * MXN sentinel
- BAF (optional) * PWR baffle
- BRL (optional) * PWR barrel
- PAD (optional) * PWR pad
- LSE (required) * Layout of MxN segments
- LRO (optional) * Input rotation map
- LCR (optional) * Input control rod maps
- ITF (optional) * Fuel temperature maps
- LTM (optional) * Moderator temperature maps
- LVD (optional) * Void maps
- LSD (optional) * Shutdown cooling map
- LEX (optional) * Exp map (present only if using restart files)

```
BAS
      Data common to all segments
SEG 1
      Segment 1 data
SEG 2
      Segment 2 data

.      .      .
.      .      .
.      .      .
SEG N
      Segment N data
STA
END
```

SEG Segment specific data

| SEG | N |
|------------|----------|
|------------|----------|

N Segment number which corresponds to a segment number in the LSE map.

Default: None

Comment:

The SEG card functions like the SEG card in a standard 2x2 calculation, that is, after the SEG card follows segment specific data. An MxN input deck should roughly be structured:

```
MEM (if needed)  * dynamic memory
TTL (required)   * Title card
MXN (required)   * MXN sentinel
BAF (optional)   * PWR baffle
BRL (optional)   * PWR barrel
PAD (optional)   * PWR pad
LSE (required)   * Layout of MxN segments
LRO (optional)   * Input rotation map
LCR (optional)   * Input control rod maps
LTF (optional)   * Fuel temperature maps
LTM (optional)   * Moderator temperature maps
LVD (optional)   * Void maps
LEX (optional)   * Exp map (present only if using restart files)
```

```
BAS
      Data common to all segments
```

```
SEG 1
      Segment 1 data
```

```
SEG 2
      Segment 2 data
```

```
  .   .   .
  .   .   .
  .   .   .
```

```
SEG N
      Segment N data
```

```
STA
END
```

LCR Control rod disposition map

| LCR | N_1 | N_2 | N_3 |
|-----|-------|-------|-------------------------------------------------------------------------------------|
| | - | - | - |
| | - | - | - |
| | - | - | N_n / 'cr ₁ ' , 'cr _i ' / EXP ₁ EXP ₂ |

N_i Disposition of control rod. 0 for withdrawn, and > 0 for inserted. Enter a value for each assembly location (corresponding to the LSE and LRO maps). The integer value corresponds to the listing of the control rod pnames, e.g., 'cr₁'.

'cr_i' Name of the control rod associated with rod type i. These names must correspond with those names (PNAMES) used on the PIN/CRD/PRM cards (maximum of 10).

EXP₁ Starting cycle exposure for exposure range for which the LCR map is valid (MWd/kg).

EXP₂ Ending cycle exposure for exposure range for which the LCR map is valid (MWd/kg).

Default: All rods withdrawn.

Example:

```
LCR
1  0  0
0  0  0
0  0  2/ 'CR0' 'CR1' * 3x3 PWR with 2 rod types inserted
```

```
LCR
0  0  0  0
0  1  1  0
0  1  1  0
0  0  0  0/'CRD' 4x4 BWR with central assemblies rodded
```

Comment:

1. The shape of this map should match the LSE map.
2. Multiple LCR maps may be placed after the MxN card (and before the BAS card) if exposure dependent maps are required. The exposure range over which that particular map is valid is specified via EXP₁ and EXP₂.
3. EXP₁ and EXP₂ are required only if exposure dependent maps are required. If EXP₁ and EXP₂ are not input, then the map values are assumed to be constant for the depletion.
4. If exposure dependent maps are specified, then the exposure range from EXP₁ of the first map to EXP₂ of the last map must be complete and continuous. Up to 50 exposure dependent LCR maps may be entered in any single MxN run.

LEX Exposure map

| LEX | E_1 | E_2 | E_3 |
|------------|-------|-------|-------|
| | - | - | - |
| | - | - | - |
| | - | - | E_n |

E_i Exposure in MWd/kg for segment i.

Default: None

Example:

```
LEX
00.0 20.0 00.0
20.0 00.0 20.0
00.0 20.0 00.0
```

Comment:

1. This card can be used to insert depleted assemblies into the MxN calculation.
2. This card will only work when using CASMO restart files generated by the same version of CASMO. When used in combination with the FIL card, the LEX map makes it unnecessary to put RES cards into the SEG inputs.
3. The exposure values on the LEX card must exist on the CASMO restart files being read.

LRO Segment rotation map

| LRO | N_1 | N_2 | N_3 |
|-----|-------|-------|-------|
| | - | - | - |
| | - | - | - |
| | - | - | N_n |

N_i Rotation index of segment n in the multi-segment layout.
The rotation index can have only the following values (the rotation is clockwise).

Index Rotation (degrees)

| | |
|---|-----|
| 0 | 0 |
| 1 | 90 |
| 2 | 180 |
| 3 | 270 |

Default: PWR: All zero.

BWR: 0 1
3 2

Example:

```
LRO
0 1 0 1
3 2 3 2
0 1 0 1 * Default BWR rotations for 4x4
```

Comment:

1. The shape of this map should match the LSE map.
2. If no LRO card is input, and a BWR is being run, then the code autogenerates the following rotation sequences:
0 1
3 2
3. The rotations indicated in the LRO map are absolute rotations and not incremental. This is an important point when bringing data back via restart files through multiple cycles.

LSD Shutdown cooling map (SDC)

| LSD | T_1 | T_2 | T_3 |
|------------|-------|-------|--------------|
| | - | - | - |
| | - | - | - |
| | - | - | $T_n / 'dt'$ |

T_i Shutdown cooling time for segment i.

'dt' 'DD' Shutdown cooling time in days

 'DH' Shutdown cooling time in hours

Default:

T_i None

'dt' 'DH'

Example:

```
LSD
500.0 500.0 500.0
500.0 500.0 500.0
500.0 500.0 500.0 / 'DD'     * Cool all assemblies 500 days
```

Comment:

1. This card can be used to specify shutdown cooling times for reinserted assemblies.
2. When an LSD map is detected, the code will perform a calculation at cycle exposure =0.0 (an initialization statepoint of 1 iteration), perform the shutdown cooling statepoint, and then proceed with any full power depletion.
3. The SDC calculation is performed at a PDE of 1.0E-6.
4. The shape of this map should match the LSE map.
5. Only one LSD map may appear in any MxN calculation.

LTF Fuel temperature map

| LTF | T_1 | T_2 | T_3 |
|------------|-------|-------|-------------------------|
| | - | - | - |
| | - | - | - |
| | - | - | T_n / EXP_1 EXP_2 |

T_i Fuel temperature in Kelvin for segment i.

EXP_1 Starting cycle exposure for exposure range for which the LTF map is valid (MWd/kg).

EXP_2 Ending cycle exposure for exposure range for which the LTF map is valid (MWd/kg).

Default: None

Example:

```
LTF
900.0 900.0 900.0
900.0 880.0 900.0
900.0 900.0 900.0
```

Comment:

1. The shape of this map should match the LSE map.
2. Multiple LTF maps may be placed after the MxN card (and before the BAS card) if exposure dependent maps are required. The exposure range over which that particular map is valid is specified via EXP_1 and EXP_2 .
3. If exposure dependent maps are specified, then the exposure range from EXP_1 of the first map to EXP_2 of the last map must be complete and continuous.
4. EXP_1 and EXP_2 are required only if exposure dependent maps are required. If EXP_1 and EXP_2 are not input, then the map values are assumed to be constant for the depletion.
5. Up to 50 LTF maps may be entered in any one run.
6. No interpolation is performed.
7. If auto-generated reflector segments are present then a TFU card must still appear in the BAS part of the input.

LTM Moderator temperature map

| LTM | T_1 | T_2 | T_3 |
|------------|-------|-------|-------------------------|
| | - | - | - |
| | - | - | - |
| | - | - | T_n / EXP_1 EXP_2 |

T_i Moderator temperature in Kelvin for segment i.

EXP_1 Starting cycle exposure for exposure range for which the LTM map is valid (MWd/kg).

EXP_2 Ending cycle exposure for exposure range for which the LTM map is valid (MWd/kg).

Default: None

Example:

```
LTM
550.0 550.0 550.0
550.0 560.0 550.0
550.0 550.0 550.0
```

Comment:

1. The shape of this map should match the LSE map.
2. Multiple LTM maps may be placed after the MxN card (and before the BAS card) if exposure dependent maps are required. The exposure range over which that particular map is valid is specified via EXP_1 and EXP_2 .
3. If exposure dependent maps are specified, then the exposure range from EXP_1 of the first map to EXP_2 of the last map must be complete and continuous.
4. EXP_1 and EXP_2 are required only if exposure dependent maps are required. If EXP_1 and EXP_2 are not input, then the map values are assumed to be constant for the depletion.
5. Up to 50 LTM maps may be entered in any one run.
6. No interpolation is performed.
7. If auto-generated reflector segments are present then a TMO card must still appear in the BAS part of the input.

LVD Void map

| LVD | V_1 | V_2 | V_3 |
|-----|-------|-------|-------------------------|
| | - | - | - |
| | - | - | - |
| | - | - | V_n / EXP_1 EXP_2 |

V_i Percent void for segment i.

EXP_1 Starting cycle exposure for exposure range for which the LVD map is valid (MWd/kg).

EXP_2 Ending cycle exposure for exposure range for which the LVD map is valid (MWd/kg).

Default: None

Example:

LVD

```
40.0 40.0 40.0
40.0 70.0 40.0
40.0 40.0 40.0
```

LVD

```
40.0 40.0 40.0
40.0 70.0 40.0
40.0 40.0 40.0 / 0.0 2.5 * map valid over range 0.0 to 2.5 MWd/kg
```

Comment:

1. The shape of this map should match the LSE map.
2. Multiple LVD maps may be placed after the MxN card (and before the BAS card) if exposure dependent maps are required. The exposure range over which that particular map is valid is specified via EXP_1 and EXP_2 .
3. If exposure dependent maps are specified, then the exposure range from EXP_1 of the first map to EXP_2 of the last map must be complete and continuous.
4. EXP_1 and EXP_2 are required only if exposure dependent maps are required. If EXP_1 and EXP_2 are not input, then the map values are assumed to be constant for the depletion.
5. Up to 50 LVD maps may be entered in any one run.
6. No interpolation is performed.

BAF Ex-core PWR baffle auto-generation

| BAF | 'MAT' , NPINS , SSA_OPT |
|------------|--------------------------------|
|------------|--------------------------------|

| | | |
|---------|---------------------------------------------------------|--------------------------------------------------------------------------------------------------------|
| 'MAT' | Material of baffle | |
| NPINS | Baffle constructed will be this many pins pitches thick | |
| SSA_OPT | 'ON' | Apply SSA correction to sigma transport in baffle SS and iron in auto-generated baffle segments |
| | 'OFF' | Do not apply SSA correction to sigma transport in baffle SS and iron in auto-generated baffle segments |

Default:

| | |
|---------|---------|
| 'MAT' | = 'MAT' |
| NPINS | = 3 |
| SSA_OPT | = 'ON' |

Example:

```
BAF
BAF 'MI1' * Use MI1 for baffle material
```

Comment:

1. This card is valid only for an MxN calculation.
2. This card will auto-generate PWR baffle segments around the periphery of the fueled core regions.
- 3. The BAF card must appear before the LSE card.**
4. With the BAF card present, the user does not need to input manually built baffle segments, however, the LSE map still needs to provide space for the auto-generated segments (zero's around the real fuel).
5. The SSA (correction to the transport cross section for stainless steel in baffle/reflector) ON/OFF option controls this option for all baffle/barrel/reflector segments and normally should be ON for these segments when using the L-library. SSP recommends use of the defaults.
6. This data is not written to the CASMO restart file.

BRL Ex-core PWR barrel or BWR shroud auto-generation

| | |
|------------|----------------------------------------------------------|
| BRL | RADIUS_IN, RADIUS_OUT, 'MAT1', 'MAT2', 'MAT3', 'MAT4' |
|------------|----------------------------------------------------------|

| | |
|------------|----------------------------------------------------------------------------------------------------------------------------|
| RADIUS_IN | Inner radius of core barrel in cm |
| RADIUS_OUT | Outer radius of core barrel in cm |
| 'MAT1' | PWR: Material of barrel BWR: Material of shroud |
| 'MAT2' | PWR: Material between baffle and barrel (interior to barrel) BWR: Material between core and shroud (interior to shroud) |
| 'MAT3' | PWR: Material between barrel and pads BWR: Material between shroud and vessel (downcomer material) |
| 'MAT4' | PWR: Material outside of pad regions BWR: Material outside of pressure vessel |

Default:

| | |
|------------|---------|
| RADIUS_IN | = None |
| RADIUS_OUT | = None |
| 'MAT1' | = 'CRS' |
| 'MAT2' | = 'MOD' |
| 'MAT3' | = 'MOD' |
| 'MAT4' | = 'MOD' |

Example:

```
BRL 187.95, 194.0
BRL 187.95, 194.0 'MI1' * Use material MI1 for barrel
```

Comment:

1. This card can be used to model the PWR core barrel or a BWR shroud.
 2. This card is valid only for an MxN calculation.
 - 3. The BRL card must appear before the LSE card.**
 4. This card will auto-generate barrel material in segments located around the periphery of the problem.
-

-
5. With the BRL card present, the LSE map still needs to provide space for the auto-generated segments (zero's around the real fuel).
 6. If the user is inputting data for 'MAT2', 'MAT3' and 'MAT4', then the user is responsible for ensuring that the materials are at the proper density and temperature.
 7. This data is not written to the CASMO restart file.
 8. See Figures 2.1 and 2.2 on the next page for the relationships of the various ex-core regions.

Fig. 2.1 PWR Ex-core Regions

| | | | | | | |
|------------------|--------------------|----------|--------------------|----------|-----------------|----------|
| A Core | B Baffle | C | D Barrel | E | F Pad | G |
|------------------|--------------------|----------|--------------------|----------|-----------------|----------|

A: Core region

B: PWR baffle region (see BAF card)

C: Region between baffle and barrel (MAT2)

D: Barrel region (MAT1)

E: Region between barrel and pad (MAT3)

F: Pad region (See PAD card)

G: Region outside of pads (MAT4)

Fig. 2.2 BWR Ex-core Regions

| | | | | | |
|------------------|----------|--------------------|-----------------------|--------------------|----------|
| A Core | B | C Shroud | D Downcomer | E Vessel | F |
|------------------|----------|--------------------|-----------------------|--------------------|----------|

A : Core region

B : Region between core and shroud (MAT2)

C : Shroud (MAT1)

D : Downcomer region (MAT3)

E : BWR pressure vessel (see PAD card)

F : Region outside of pressure vessel (MAT4)

PAD Ex-core PWR pad or BWR vessel auto-generation

| PAD | RADIUS_IN, RADIUS_OUT, ANGLE_START, ANGLE_END, 'MAT' |
|------------|-----------------------------------------------------------------|
|------------|-----------------------------------------------------------------|

| | |
|-------------|-------------------------------------------------|
| RADIUS_IN | Inner radius of pad or vessel in cm |
| RADIUS_OUT | Outer radius of pad or vessel core barrel in cm |
| ANGLE_START | Starting angle in degrees (0-360) |
| ANGLE_END | Ending angle in degrees (0-360) |
| 'MAT' | Material of pad or vessel |

Default:

| | |
|-------------|---------|
| RADIUS_IN | = None |
| RADIUS_OUT | = None |
| ANGLE_START | = None |
| ANGLE_END | = None |
| 'MAT' | = 'CRS' |

Example:

```

PAD 194.8 201.8 32.5 65.0      * Pad 1
PAD 194.8 201.8 112.5 147.5    * Pad 2
PAD 194.8 201.8 212.5 245.0    * Pad 3
PAD 194.8 201.8 292.5 327.5    * Pad 4

```


Comment:

1. This card can be used to model pads around PWR core barrel or the vessel around a BWR.
2. This card is valid only for an MxN calculation.
- 3. The PAD card must appear before the LSE card.**
4. This card will auto-generate barrel material in segments located around the periphery of the problem.
5. The PAD card is multiple input card, i.e. it is permitted to have multiple PAD cards in the input.
6. The code is currently limited to 5 pads.
7. The co-ordinate system for the orientation of the starting and ending angles is 0 degrees straight down, and proceeds counterclockwise such that 90 degrees is to the right, 180 degrees straight up, and 270 degrees to the left. This is shown in the following figure:
13. For BWR applications the PAD cards can be used to model the outer reactor pressure vessel by having each pad encompass the entirety of their respective quadrants, i.e.,

```
PAD 194.8 201.8 0.0 90.0
PAD 194.8 201.8 90.0 180.0
PAD 194.8 201.8 180.0 270.0
PAD 194.8 201.8 270.0 360.0
```

7. This data is not written to the CASMO restart file.

Fig. 2.3 Angular co-ordinate system for placement of pads outside of the barrel



General Comments on the MxN Barrel/Baffle/Pad Model

1. The thickness of the baffle is limited to an integer number of pins (typically 2 or 3 pins thick).

-
2. The automated barrel and pad cannot be used with manual (user built) baffle segments.
 3. The code is currently limited to modeling 5 pads around the exterior of the barrel.
 4. The BAF/BRL and PAD cards must appear in the MXN section of the input and must appear **before** the MxN LSE map.
 5. The LSE map must be "padded" with 0's around the periphery of the fuel to provide a space in which the code may place the auto-generated segments. If the LSE map is too small, then part of the barrel and pads may fall outside the calculated geometry. A warning is issued, but it is allowed.
 6. If the user is overriding a default material with a user constructed material, e.g., an Mixture specification, then that specification must appear in the BAS segment of the input.
 7. Due to the limitation of a curved barrel and curved pads being modeled with square pin cells, the spatial resolution of the barrel and pads is approximately one pin pitch.
 8. The same restrictions that apply to auto-generated reflector segments also apply to the BAF/BRL and PAD segments. These types of segments do not deplete and do not appear in any normalizations in the MxN summary. The macro-group calculation is active for these segments. Restart files are not generated for these segments.
 9. The SSA (correction to the transport cross section for stainless steel in baffle/reflector) ON/OFF option on the BAF card controls this option for all baffle/barrel/reflector segments and normally should be ON for these segments if running with the L-library.
 10. In the case where the pads are not symmetric about the diagonal axis, a 1/4 core calculation can not be run with diagonal symmetry, e.g., MXN 2, 1 cannot be used.
 11. This model makes sense only in the context of CASMO-4E MxN and has no application in single assembly calculations. Also, the user should be aware that any input modeling all the way out to the pads is a spatially large problem and that significant computer memory (and other computer resources) will be required.
 12. The pin pitch for auto-generated segments is taken from the **last segment** encountered in the input stream. This allows the user to include a dummy segment at the end of the input with a customized PWR card to control the number of pins and their pitch in these segments.
 13. A pad spanning across the 360 degree point must be split into two pads.

AUT Autogenerated reflector pitch

| AUT | PITCH |
|------------|--------------|
|------------|--------------|

PITCH Assembly pitch in cm that the code will use to build auto-generated reflectors

Default:

If no AUT card is present, the code will attempt to determine the pitch from the last BWR/PWR card it encountered in the input stream.

Example:

AUT 21.8

Comments:

1. This card is only for MxN cases which use auto-generated reflectors (0 in the LSE map).
2. The code will "suggest" an appropriate value if an AUT card is required.
3. This card will usually be encountered when using MxN and FSS/FSC in combination, but otherwise should rarely be needed.

BPS BP shuffle

| | |
|------------|---------------------------------------------------------|
| BPS | <code>'File_in1',EXP1,'File_in2',EXP2,'File_out'</code> |
|------------|---------------------------------------------------------|

| | |
|-------------------------|-------------------------------------------------------------------------------------------------------------------------------|
| <code>'File_in1'</code> | CASMO-4E restart file name from which to retrieve B.P. data. |
| EXP1 | Exposure (MWd/kg) for file_in1 at which to retrieve B.P. data. |
| <code>'File_in2'</code> | CASMO-4E restart file name from which fuel and assembly data is to be taken. |
| EXP2 | Exposure (MWd/kg) for file_in2 at which to retrieve fuel and assembly data. |
| <code>'File_out'</code> | File name of restart file to be created from the merge of B.P. data from File_in1 at EXP1 into restart file File_in2 at EXP2. |

Default: **None**

Example:

```
BPS 'single.res' 10.0 'host.res' 12.0 'merge.seg1.res'
```

Comment:

1. This card is used to shuffle B.P. data (number densities) from one CASMO-4E restart file into another. The process leaves the original restarts unmodified and produces a third (merged) restart file.
2. B.P. shuffles may be performed only in the context of an MxN calculation and must appear in the MxN section of the input (before the BAS card).
3. Multiple BPS cards are allowed.
4. Interpretation of exposure marking on the restart files (cycle exposure or assembly average) is controlled by the IBUNEXP parameter on the MXN card.
5. The only mechanism to shuffle B.P. data is via CASMO-4E restart files. To insert depleted B.P.'s into a fresh assembly, a restart file at 0.0 exposure must be created for that fresh assembly before the shuffle process.
6. The BPS card may span multiple lines since the filenames may be longer than the 80 column limit for input lines.
7. There is no provision to perform "password" searching on the incoming restart files. It is assumed that the restart files have generated from single assembly straight depletions (no branches) or previous MxN calculations.
8. The merged restart file created is marked with exposure EXP2 (the exposure of the "host" assembly).

S3I Generate equivalent SIMULATE input

| | |
|------------|-------------------------|
| S3I | COPT, TRIM_OPT, LIB_OPT |
|------------|-------------------------|

| | | |
|----------|--------|---------------------------------------------------------------------------------------------------------------|
| OPT | 'OFF' | : No generation of SIMULATE-3 input |
| | 'FULL' | : Generation of SIMULATE-3 input in full core geometry |
| | '1/4' | : Generation of SIMULATE-3 input in 1/4 core geometry |
| TRIM_OPT | 'TRIM' | : Trim baffle/barrel/pad segments to equivalent SIMULATE input |
| LIB_OPT | 'LIB' | : Generate extra cards (commented out) to facilitate use with a real SIMULATE-3 library (FUE.LAB and FUE.MOD) |
| | 'SUP' | : Do not generate extra cards (suppress) |

Default:

COPT='OFF'

TRIM_OPT= 'NO'

LIB_OPT='LIB'

Example:

S3I '1/4'

Comment:

1. This card will generate a SIMULATE input equivalent to the MxN case which has just been run.
 2. This card is valid only for an MxN calculation.
 3. Only full and 1/4 core geometry generation is supported.
 4. The user has no control of the filename of the generated SIMULATE input which is:
s3."input_filename" where input_filename is the name of the CASMO input file.
 5. A file is generated only for the first statepoint.
 6. This option is provided as only an aid for building an equivalent SIMULATE-3 input deck and some user modifications of the generated deck may be required. This is particularly true for PWR baffle segments which are treated as real assemblies in C4 but are part of the reflector in SIMULATE.
 7. If making direct comparisons between an MxN CASMO and a SIMULATE using a library generated from single assembly inputs, the user must be careful to run the single assembly CASMOs with comparable options, e.g., FUM,,3.
 8. This option has no effect in a single assembly calculation.
 9. This edit is suppressed if a simultaneous gamma calculation is requested.
-

SMR Gamma smearing factor for MxN

| SMR | VAL |
|------------|------------|
|------------|------------|

VAL Fraction of gamma smearing on pin power distribution.

Default:

VAL=0.07 (single assembly and standard 2x2)

VAL=0.00 (MxN)

Example:

VAL=0 . 07

Comment:

1. This data is written to the restart file.
2. This data is not written to the card image file.
3. The default value of 0.0 for MxN calculations allows for easy power distribution comparisons to SIMULATE-3. If comparing an MxN power distribution to a single assembly power distribution then the value of 0.07 should be input into the MxN calculation.

SSA Sigma-transport correction for steel in baffle/reflector

| | |
|------------|---------------|
| SSA | 'COPT' |
|------------|---------------|

'COPT' 'ON' : Apply sigma transport correction to iron and steel in baffle/reflector.
 'OFF' : Do not apply sigma transport correction to iron and steel in baffle/reflector.

Default:

'COPT' = 'ON' for single assembly (REF cases only)
 'OFF' for MxN cases

Example:

SSA 'OFF' * Turn OFF steel correction in baffle/reflector

Comment:

1. This card controls the application of a correction factor to the transport cross section for iron and steel (isotope IDs= 347 and 26000) in reflector regions of reflector calculations. In single assembly non-reflector cases, this flag has no impact.
2. When running an MxN calculation with user built baffle/reflector segments present, since the code cannot automatically identify these segments as reflector/baffle regions, those particular segments should turn on the SSA correction (the user should include an SSA 'ON' in those particular segments) to be consistent with single assembly results. If the user is using the BAF card instead of manually building the baffle segments, the SSA correction is turned on by default for those segments.

SUM Generate MxN summary file

| SUM | COPT |
|------------|-------------|
|------------|-------------|

OPT 'OFF' : No generation of MxN summary file

 'ON' : Generation of MxN summary file

Default:

COPT='OFF'

Example:

SUM 'ON'

Comment:

1. This card is valid only for an MxN calculation.
2. This card will generate an ASCII data file which summarizes the MxN calculation. Although the file is ASCII it is not a lot of data (about 1.2 megabytes per statepoint for a full core PWR MxN calculation).
3. The output summary file will be named: **input_basename.sum**, where input_basename is the root part of the input filename (without the .inp).
4. This file is designed to be read by other programs (post-processors) and is not designed to be particularly person readable.
5. The file is divided in blocks delimited by STA and END to facilitate searching by user written post-processing programs.
6. The SUM card should appear in the BAS part of the input.
7. A SUM card with no COPT indicates SUM 'ON'.

2.2 Fuel Storage Rack Input

| Card | Description | Page |
|------|--------------------------|------|
| FSS | Fuel Storage Rack Side | 34 |
| FSC | Fuel Storage Rack Corner | 38 |
| CCT | Concrete composition | 40 |

These cards describe the geometry and compositions of rack regions around a segment.

FSS Fuel Storage Rack Side

(See Figure 2.4 at end of FSS description).

| | |
|------------|-------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|
| FSS | $T_1 / dx_{1,1}, dx_{1,2}, \dots, dx_{1,m} / 'c_{1,1}', 'c_{1,2}', \dots, 'c_{1,m}' /$ $T_2 / dx_{2,1}, dx_{2,2}, \dots, dx_{2,m} / 'c_{2,1}', 'c_{2,2}', \dots, 'c_{2,m}' /$ \vdots \vdots \vdots $T_n / dx_{n,1}, dx_{n,2}, \dots, dx_{n,m} / 'c_{n,1}', 'c_{n,2}', \dots, 'c_{n,m}' //$ $'l_1', \dots, 'l_k' / XSP1, XSP2, TWID$ $1 \leq k \leq 4, \quad 1 \leq m \leq 40, \quad 1 \leq n \leq 10$ |
|------------|-------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|

| | | |
|-------------|-------------------------------------------------------------------------|--------------------------------------------------------------------------------------|
| T_j | Thickness of slab _j (cm) | $1 \leq j \leq 10$ |
| $dx_{j,i}$ | Length of sub-slab _{j,i} (cm) | $1 \leq j \leq 40$ The sum of sub-slab length must be equal to the segment width. |
| $'c_{j,i}'$ | Composition for sub-slab _{j,i} | |
| $'l_i'$ | Side position indicator, 'N', 'E', 'S' or 'W' | $1 \leq i \leq 4$ Note the double slash before $'l_i'$ |
| XSP1 | Mesh spacing (1 mesh per XSP1 cm) for slabs < TWID cm | |
| XSP2 | Mesh spacing (1 mesh per XSP2 cm) for slabs > TWID cm | |
| TWID | Threshold slab thickness in cm to change from mesh spacing XSP1 to XSP2 | |

Default:

| | |
|----------------|--------------------|
| T_n : | None |
| $'dx_{j,i}'$: | None |
| $'c_{j,i}'$: | None |
| $'l_i'$: | 'N', 'E', 'S', 'W' |
| XSP1: | 0.2 (mesh/cm) |
| XSP2: | 0.4 (mesh/cm) |
| TWID: | 5.0 (cm) |

Comment:

1. This card is to be used in conjunction with the FSC card.
2. For each side, FSS is specified 'as you see it' when the rack is rotated so that the FSS side is located above (north of) the segment. The ordering of slabs, T_j , within FSS is from the outside to the inside (closest to the segment). The sub-slabs, $dx_{j,i}$, are specified from left to right. If the side position indicator is omitted, then the same side description is used for all sides, clock wise rotated around. Up to four FSS cards are allowed, one for each side. The number of slabs (and the thickness) may be different for each side. The number of sub-slabs (and the lengths) may be different for each slab. For each slab, the sum of the sub-slab lengths must be equal to the width of fuel segment (including outer water gaps).
3. Default mesh spacing is recommended. By default, for slabs < 5.0 cm thick, the mesh spacing is one mesh every 0.3 cm, and for slabs > 5.0 cm thick the mesh spacing is one mesh every 0.5 cm. This two level implementation is a provision to reduce the number of mesh in regions where a fine mesh spacing is not important.
4. The following options are set automatically with the FSS/FSC model:
Fundamental mode: OFF
Thermal expansion: OFF
Number of 2D energy groups: 40
(The default number of 2D groups may be overridden by input of the GRP or CON card as long as 2D and macro groups are the same, e.g. GRP 25 25)

Code Limitations:

1. There is currently a maximum of 10 slabs allowed per side (out from the fuel segment) each of which may be composed of up to a maximum 40 sub-slab lengths. There is a limitation of a maximum of three sub-slab lengths across any one pincell width.
2. The FSS/FSC calculation is mutually exclusive with the following calculations: BUF, CRD, FST, REF, AGR, CLU, HEX, MOVEROD and S3C. Cruciform control rods (CRD) are not permitted in an FSS/FSC model. Library generation with S3C is not supported.
3. **The FSC/FSS model is only supported in full geometry (ISYM=1).**
However, if the segment data is coming via a restart file (e.g., from a standard depletion), the segment data can be generated in half assembly and the code will expand it out to full geometry (if an appropriate BWR/PWR card with ISYM=1 is present) for the FSS/FSC rack calculation.
4. The macrogroup calculation is not active (and may not be turned on) for any FSS/FSC calculation.
5. FSS/FSC data is not written to the restart file.
6. MOD should be used instead of COO for FSS regions (COO may contain smeared SPA).

Example:

```

* Thickness (cm)/ Sub-slab lengths (cm)          / Sub-slab compositions/
*
FSS  1.5          / 15.25                          / 'MOD' /                * Outermost slab
      0.25         / 2.0 1.5 3.0 2.25 3.0 1.5 2.0 / 'CRC' 'MI2' 'CRC' 'MI2' 'CRC' 'MI2' 'CRC' /
      0.5          / 15.25                          / 'CRS' /
      0.5          / 2.5 10.25 2.5                  / 'CRC' 'MI2' 'CRC' /
      0.2          / 15.25                          / 'CRS' /
      0.3          / 2.0 11.25 2.0                  / 'CRC' 'MI2' 'CRC' / * Innermost slab

```

or the equivalent input:


```

* Thickness (cm)/ Sub-slabs
*
FSS  1.5          / 15.25                          * Outermost slab
      / 'MOD'
      /0.25       / 2.0 1.5 3.0 2.25 3.0 1.5 2.0
      / 'CRC' 'MI2' 'CRC' 'MI2' 'CRC' 'MI2' 'CRC'
      /0.5        / 15.25
      / 'CRS'
      /0.5        / 2.5 10.25 2.5
      / 'CRC' 'MI2' 'CRC'
      /0.2        / 15.25
      / 'CRS'
      /0.3        / 2.0 11.25 2.0 * Innermost slab
      / 'CRC' 'MI2' 'CRC'

```

Fig. 2.4 Specification of FSS/FSC Fuel Storage Rack Geometry

FSS side regions are in light shade, and FSC corners in darker shade. Dimensions and compositions are shown for the 'reference' north FSS region. The other sides are clockwise rotated (default if FSS is not specified for individual sides).



FSC Fuel Storage Rack Corner

(See Figure 2.4 at end of FSS description).

| | |
|------------|------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|
| FSC | $'c_{1,1}', 'c_{1,2}', \dots, 'c_{1,m}'$ $'c_{2,1}', 'c_{2,2}', \dots, 'c_{2,m}'$ \vdots \vdots \vdots $'c_{n,1}', 'c_{n,2}', \dots, 'c_{n,m}'$ $'P_1', \dots, 'P_k' / \text{IROT}_1 \dots \text{IROT}_k$ $1 \leq k \leq 4, \quad 1 \leq m \leq 10, \quad 1 \leq n \leq 40$ |
|------------|------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|

$'c_{j,i}'$ Composition for corner region j,i

$'P_i'$ Corner position indicator, 'NW', 'NE', 'SE' or 'SW'. $1 \leq i \leq 4$

IROT_i Clockwise rotation factor(s) to be applied to the input orientation(s):

0 = 0 degrees (as is)

1 = 90 degrees

2 = 180 degrees

3 = 270 degrees

IROT_i refers to the corner defined by position indicator P_i .

Specify IROT_i for each position P_i .

Default:

$'c_{j,i}':$ None

$'P_i':$ **If the corner position indicator is omitted, then data are applied to all corners and rotated appropriately, i.e. the program will automatically add position indicators / rotation factors:**
'NW', 'NE', 'SE', 'SW' / 0, 1, 2, 3
to the input. See comment 3.

$\text{IROT}_i:$ **0**

Comment:

1. This card is to be used in conjunction with the FSS card (see additional comments there).
2. FSC only specifies compositions in the corners. The number of corner regions, and the size of the corner regions, are determined by the intersections of the FSS slabs. For example, if the north FSS face has 5 slabs, and the west FSS face has 4 slabs, then the NW corner will have $4 \times 5 = 20$ regions. If the number of slabs is different where two sides intersect, then the corner region and the FSC input will be rectangular.

-
3. If the FSC card is encountered without any corner position indicator, then the input array of compositions is presumed to be in the NW corner, and this array is subsequently rotated as it is positioned in the other corners. If the FSC card is encountered with corner position indicator(s) then it is applied directly as it appears in the input unless the user has specifically requested a rotation via the IROT parameter. This allows the user to specify the corners as they appear in-situ in the problem.
 4. MOD should be used instead of COO for FSC regions (COO may contain smeared SPA).
 5. This data is not written to the restart file.

Example:

```
* Compositions of fuel storage rack corner as it sits in the NW corner
* and use it for all corners (NW, NE, SE, SW). Code will auto-rotate.
* Matrix is 6x6 since each side has 6 slabs
*
FSC  'MOD' 'MOD' 'MOD' 'MOD' 'MOD' 'MOD'
      'MOD' 'CRC' 'CRC' 'CRC' 'CRC' 'CRC'
      'MOD' 'CRC' 'CRS' 'CRS' 'CRS' 'CRS'
      'MOD' 'CRC' 'CRS' 'CRC' 'CRC' 'CRC'
      'MOD' 'CRC' 'CRS' 'CRC' 'CRS' 'CRS'
      'MOD' 'CRC' 'CRS' 'CRC' 'CRS' 'CRC'
```

CCT Concrete composition

| | |
|------------|---------------------------------------|
| CCT | $D, C, T/ID_1= W_1, \dots, ID_n= W_n$ |
|------------|---------------------------------------|

- D Density of the composition
- C Thermal expansion coefficient
- T Temperature (K)
- ID_i Nuclide identification
- W_i Weight percent of nuclide ID_i

Default:

The program provides the following default as an example of a composition for concrete. The composition is intended to provide scattering and absorption similar to a real concrete mixture.

CCT 2.4 / 1001=0.5 8000=50. 13000=8 14000=39.5 26000=2

See comment below.

Example:

See default above.

Comment:

1. **Concrete compositions can vary considerably.** The amount of moisture (hydrogen) and iron in the default is arbitrary, but within a typical range.
2. The default is provided as a matter of convenience to the user. The default should be used only in applications where the concrete composition has very little influence on results, e.g. in a reflector region outside of racks. **The user should define his own composition if more appropriate information about the concrete present in his application is available.**

2.3 Hexagonal Geometry Input

| Card | Description | Page |
|------|---------------------------|------|
| HEX | Hexagonal Geometry Option | 42 |
| PIN | Pin Geometry | 45 |


These cards describe the layout and geometry of the hexagonal geometry reactors that can be modeled with CASMO. This model was specifically designed for reactor of VVER-440 and VVER-1000 designs.

HEX


Hexagonal geometry option

| | |
|-----|------------------------------|
| HEX | NPST, S, CHW, BXW, GAO, ISYM |
|-----|------------------------------|


| | |
|------|-----------------------------------------------------------------------------------------|
| NPST | Number of pins along a diagonal of the bundle |
| S | Pin pitch (triangular pitch) |
| CHW | Inner distance between parallel box walls (VVER 440) Interassembly pitch (VVER 1000) |
| BXW | The thickness of the box wall (VVER 440) BXW = 0 for VVER 1000 |
| GAO | The thickness of half the outer water gap (VVER 440) GAO = 0 for VVER 1000 |
| ISYM | Symmetry indicator: 1 full bundle 2 half bundle 6 one sixth bundle |




ISYM = 1



ISYM = 2



ISYM = 6



Default:

| | |
|------|----------------------------------------------|
| CHW | Calculated from number of pins and pin pitch |
| BXW | 0 |
| GAO | 0 |
| ISYM | 6 |

Example:*** * * Full bundle VVER 440 input**

HEX 13, 1.22 14.0 0.2 0.2 1

*

LPI

* Layout of pins

```

      1 1 1 1 1 1 1
      1 1 1 1 1 1 1 1
      1 1 1 1 1 1 1 1 1
      1 1 1 1 1 1 1 1 1 1
      1 1 1 1 1 1 1 1 1 1 1
      1 1 1 1 1 1 1 1 1 1 1 1
      1 1 1 1 1 1 2 1 1 1 1 1 1
      1 1 1 1 1 1 1 1 1 1 1 1
      1 1 1 1 1 1 1 1 1 1 1
      1 1 1 1 1 1 1 1 1 1
      1 1 1 1 1 1 1 1 1
      1 1 1 1 1 1 1

```

LFU

* Layout of FUE

```

      1 1 1 1 1 1 1
      1 1 1 1 1 1 1 1
      1 1 1 1 1 1 1 1 1
      1 1 1 1 1 1 1 1 1 1
      1 1 1 1 1 1 1 1 1 1 1
      1 1 1 1 1 1 1 1 1 1 1 1
      1 1 1 1 1 1 0 1 1 1 1 1 1
      1 1 1 1 1 1 1 1 1 1 1 1
      1 1 1 1 1 1 1 1 1 1 1
      1 1 1 1 1 1 1 1 1 1
      1 1 1 1 1 1 1 1 1
      1 1 1 1 1 1 1

```

* * *

*** * * 1/6 bundle VVER 440 input**

HEX 13, 1.22 14.0 0.2 0.2 6

*

LPI

* Layout of pins

```

      2
      1 1
      1 1 1
      1 1 1 1
      1 1 1 1 1
      1 1 1 1 1 1
      1 1 1 1 1 1 1

```

```

LFU
      0
    1 1
  1 1 1
1 1 1 1
  1 1 1 1
1 1 1 1 1
  1 1 1 1 1
1 1 1 1 1 1
  1 1 1 1 1 1
* * *
* * * 1/6 bundle VVER 440 Control Cell input
TTL TFU=300 TMO=300 BOR=600 * VVER-440 CONTROL CELL
FUE 1 10.28/4.35
BOX 7.9/347=100
CRA 7.9/347=98 5000=2
CAN 5.85
HEX 13 1.22 14.0 0.2 0.15
*Define the Absorber Cell. Negative values represent hexagonal zones.
*Absorber "rod" occupies all 127 pin cell locations.
PIN 1 2.0 5.15 5.7 -6.15 -6.85/'CRS' 'COO' 'CRS' 'COO' 'CRA'//127
PIN 2 0.378 0.455/'1' 'CAN' * Pin of neighbouring bundle
LPI 2 27*1 * At least 1 (dummy) fuelled pin needed
* * for formal (program) reasons
BUF 2 8 * Buffer zone, representing part of
* * neighbouring bundle
STA
* * *
* * * 1/6 bundle VVER 1000 input
TTL TFU=850 TMO=580 BOR=1000 * VVER-1000 Fuel Assembly
FUE 1 10.282/2.4
HEX 21 1.275 23.4 , , , 6
PIN 1 0.07 0.378 0.387 0.455/'AIR' '1' 'AIR' 'CAN'
PIN 2 0.56 0.63/'MOD' 'CRS'
PIN 3 0.56 0.63/'MOD' 'CRS'
PIN 3 0.35 0.41 0.56 0.63/'B4C' 'CRS' 'MOD' 'CRS'//1 'RCC' 'ROD'
LPI 2 * Pin layout (also specifies fuel)
  1 1
    1 1 1
  1 1 3 1
1 1 1 1 1
  3 1 1 1 1 3
    1 1 1 3 1 1 1
  1 1 1 1 1 1 1 1
    1 1 1 1 1 1 1 1 1
      1 1 1 1 1 1 1 1 1 1
        1 1 1 1 1 1 1 1 1 1

```

1. The HEX input card must precede all layout cards (LPI, LFU etc). If not, the execution is aborted with an error message.

PIN Pin geometry

| | |
|------------|-------------------------------------------------------------------------------------------------------------|
| PIN | $N, R_1, \dots, R_n, 'c_1', \dots, 'c_n', m_1, \dots, m_n /$ $C, 'pname', 'ROD' \qquad 1 \leq n \leq 20$ |
|------------|-------------------------------------------------------------------------------------------------------------|

| | |
|-----------|---------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|
| N | Pin type number $1 \leq N \leq 28$. |
| R_i | <p>Radii of pin. The thickness of a ring must be ≥ 0.002. See Example 6 below for a large circular tube and Example 7 for a large square box. For a square box R_i is half the distance between the flat surfaces of the box. The zone outside R_n will contain COO. Enter a negative value for hexagonal zones of a VVER-440 control cell or dummy assembly. For a hexagonal zone R_i is half the distance between the flat surfaces of the hexagon.</p> |
| ' c_i ' | Compositions for the pin regions. For fuel compositions use the FUE number. |
| m_i | Micro meshes between radii R_i and R_{i-1} |
| C | <p>The pin occupies C pin cells ($C \leq 16$, except for VVER-440 control bundle). $C = 1$ for normal pins, $C = 4$ for large C-E rods, $C = 3.5$ for GE-11 water rods, $C = 9$ for a circular water rod and $C = -9$ for a square rod occupying 9 pin cells. For the control bundle or dummy bundle of a VVER-440 reactor, enter the total number of pin cell locations in the bundle (e.g., $C=127$).</p> |
| 'pname' | <p>Three character identification. The identification is written to the CI file, block TIT, if the pin type is given in the LPI card. 'pname' should normally be blank. It is recommended that control rods are marked by e.g. 'RCC' so that linking codes reading the card image file can separate rodded cases from unrodded. See Example 3 below. 'pname' = 'CRD' or 'CRx' (x is an integer $0 \leq x \leq 9$) activates the program to calculate the control history, ECH, written to block TIT in the CI file. This is of importance only when rodded depletions are made.</p> |
| 'ROD' | <p>A PIN card used to define a control rod must have a 'pname' and be marked 'ROD' if the ROD card is to be used for insertion and withdrawal of rods. A PIN card marked 'ROD' will only be activated by the ROD card, and it will then replace a previous PIN card with the same pin type number. Up to four different PIN cards can be marked 'ROD' if they have different 'pname'.</p> |

Default:

| | |
|-----------|------------------------------------------------------------------------------------------|
| ' c_1 ' | ' c_1 ' = 'fuel', ' c_2 ' = 'CAN' if $n = 2$ |
| | ' c_1 ' = 'fuel', ' c_2 ' = 'AIR', ' c_3 ' = 'CAN' if $n = 3$ |
| | The fuel composition number is determined by the LFU cards. |

| | | |
|-----------------------------------------------------------------------------|-------|-------------------------|
| All compositions must be given if any of the default values cannot be used. | | |
| $m_1 \dots m_k$ | = 10 | for fuel with Gd_2O_3 |
| | = 1 | for all other regions |
| C | = 1 | |
| 'pname' | blank | |

Example:

1. Fuel pin:

```
PIN 1 .50 .55
```

2. Annular fuel pin:

```
PIN 2 .237 .530 .540 .61/'AIR' '1' 'AIR' 'CAN'
```

Defaults can not be used for annular fuel pins.

3. Burnable poison rod in PWR:

```
PIN 4 .20 .23 .24 .43 .44 .48 .56 .60/
      'AIR' 'CRS' 'AIR' 'MI1' 'AIR' 'CRS' 'COO' 'BOX'//1 'BPR'
```


4. Guide tube of ABB/C-E type:

```
PIN 2 1.27 1.37/'MOD' 'BOX'//4
```

5. GE-11 type water rod:


```
PIN 2 1.1 1.2/'MOD' 'BOX'//3.5
```

This design has two large water rods, together occupying 7 pin cells, i.e. 3.5 pin cells each.




6. Circular tube occupying 9 pin cells.

PIN 2 2.0 2.1/'MOD' 'BOX'//9



7. Square rod occupying 9 pin cells.


PIN 2 2.0 2.1/'MOD' 'BOX'//9



8. Absorber Cell of a VVER-440 Reactor.

PIN 1 2.0 5.0 6.0 -6.2 -6.8/'CRS' 'COO' 'CRS' 'COO' 'CRA'//127

This design contains 3 inner circular regions and 2 outer hexagonal regions and occupies all pin cell locations in the assembly.



2.4 Cluster/Magnox/AGR Input

| Card | Description | Page |
|------|--------------------------------------------------------|------|
| CLU | Cluster specification (RBMK and CANDU) | 50 |
| MAG | Pin cell for British Magnox fuel | 54 |
| AGR | Cluster specification for British AGR assembly designs | 55 |

These cards describe the layout and geometry of various cluster type reactors that can be modeled with CASMO. Specifically, this includes reactors of the RBMK, CANDU, Magnox, and AGR designs. Modeling these types of reactors also requires the CASMO ENDF/B-VI library.

CLU Cluster specification (RBMK and CANDU)

| CLU | $R_1, N_1, NPIN_1, \dots, R_n, N_n, NPIN_n/R_{n+1}, \dots, R_{n+k}/$ $'c_{n+1}', \dots, 'c_{n+k}' /$ |
|-----|---------------------------------------------------------------------------------------------------------|
| | $1 \leq i \leq n ; 1 \leq j \leq k$ |

| | |
|-------------|----------------------------------------------------------------|
| R_i | Radius on which centers of pins in ring i are placed. |
| N_i | Pin type number for pins in ring i (unique for each ring). |
| $NPIN_i$ | Number of pins of type N_i in ring i. |
| R_{n+j} | Outer radius of each region j outside of the final pin ring n. |
| $'c_{n+j}'$ | Composition of each region j outside of the final pin ring n. |

Default: Nove

Example:

```
TTL *RBMK EXAMPLE
TFU=800 TMO=400 VOI=40
FUE 1 10.2/2.0
PIN 1 .575 .675/'MOD' 'CAN'
PIN 2 .575 .675/'1' 'CAN'
PIN 3 .575 .675/'1' 'CAN' * keep unique for each ring
CLU 0.0 1 1
      1.6 2 6
      3.2 3 12/
      3.95 4.4 5.7 14.1/'COO' 'BOX' 'MI1' 'MI2'
MI1 1.1,, 623/6001=100 * graphite rings surrounding pressure tube
MI2 2.2,,1023/6001=100 * graphite moderator
PDE 20
THE 0
STA
END
```

For the input example above CASMO will internally create the following additional input cards in order to allow the program to go through its normal calculational sequence.

```
PWR 11 1.60000 , , , , , 1,2
PIN 51 0.90070 0.90170 / 'BOX' 'CAN'
PIN 52 0.90070 0.90170 / 'MI1' 'CAN'
PIN 53 0.90070 0.90170 / 'MI2' 'CAN'
LPI
53 53 53 53 53 53 53 53 53 53 53
53 52 52 52 52 52 52 52 52 52 53
53 52 51 51 51 51 51 51 51 52 53
53 52 51 3 3 3 3 3 51 52 53
53 52 51 3 1 1 1 3 51 52 53
```

```

53 52 51  3  1  2  1  3 51 52 53
53 52 51  3  1  1  1  3 51 52 53
53 52 51  3  3  3  3  3 51 52 53
53 52 51 51 51 51 51 51 51 52 53
53 52 52 52 52 52 52 52 52 52 53
53 53 53 53 53 53 53 53 53 53 53

```

Comments:

1. When CLU is used for an RBMK, the neutron data library must be ENDF-B/VI which contains necessary data for graphite (6001). Below is shown the cluster specified in the input example (approximately to scale, except the outermost circle).

2. CLU cards cannot be stacked.

3. The same PIN number cannot appear in more than one ring (must be unique).

4. A white boundary condition is applied at the edge of the problem.

Fig. 2.5 RBMK Example





Fig. 2.6 Cluster Geometry



MAG Pin cell for British Magnox fuel rod

| | |
|------------|---------------------------------------------------------------------------------|
| MAG | $R_1, \dots, R_n / 'c_1', \dots, 'c_n' / m_1, \dots, m_n$ $1 \leq n \leq 30$ |
|------------|---------------------------------------------------------------------------------|

R_i Outer radius of ring i

$'c_i'$ Compositions for the pin regions. For fuel compositions use the FUE number.

m_i Micro meshes between radii R_i and R_{i-1} .

Default:

$'c_1'$ $'c_1' = \text{'fuel'}$, $'c_2' = \text{CAN}$, $'c_3' = \text{COO}$ if $n = 3$

The MAG card resets the materials AIR, COO, MOD and CAN to the following default values:

COO 1.65/6001=100 * Graphite

MOD 1.65/6001=100 * Graphite

CAN 1.74/12000=100 * Magnesium cladding

AIR 0.025/6000=27.2727 8000=72.7273 * CO2 coolant

And resets the coefficients used to distribute the U-238 resonance absorptions (card DRI):

DRI 1.0, 13.0, -17.0, 0.5

Example:

MAG 1.5 2.5 5.0 11.0/'1' 'CAN' 'AIR' 'COO'/20, 1, 1, 1

Comment:

1. The user should be sure that the cross section library contains both graphite and magnesium.
2. The MAG card functions in a similar way to that of the PIC card, with the exception of the above mentioned default settings.
3. If the MAG card is present, the code will check the fuel composition for the presence of oxygen and, if found, will abort execution. The user may override this fatal error via the ERR card.
4. The outer radius of the pin cell gets converted to a square region with reflective boundaries for the two-dimensional transport calculation. The user should ensure that the value used for the outer radius is chosen appropriately.

AGR Cluster specification for British AGR assembly designs

| AGR | $R_1, N_1, NPIN_1, \dots, R_n, N_n, NPIN_n / R_{n+1}, \dots, R_{n+k} /$ $'c_{n+1}', \dots, 'c_{n+k}' /$ |
|-----|------------------------------------------------------------------------------------------------------------|
| | $1 \leq i \leq n ; 1 \leq j \leq k$ |

R_i Radius on which centers of pins in ring i are placed.

N_i Pin type number for pins in ring i (unique for each ring).

$NPIN_i$ Number of pins of type N_i in ring i .

R_{n+j} Outer radius of each region j outside pin ring n .

$'c_{n+j}'$ Composition of each region j outside pin ring n .

Default:

The AGR card resets the materials COO and MOD to the following default values:

COO 0.0308/6000=27.29 8000=72.71 * CO2

MOD 1.65/6001=100 * Graphite

Example:

```
TTL *AGR EXAMPLE
TFU=850 TMO=700
FUE 1 10.4/2.55
PIN 1 .7/'MOD' 'CAN'
PIN 2 .3 .7 .8/'AIR' '1' 'CAN'
PIN 3 .3 .7 .8/'AIR' '1' 'CAN'
PIN 4 .3 .7 .8/'AIR' '1' 'CAN'
AGR 0.0 1 1
      1.6 2 6
      3.2 3 12
      6.0 4 18/
      7.0 8.0 11.0 25.0/'COO' 'MOD' 'COO' 'MOD'
PDE 20
THE 0
. . .
STA
END
```

Comments:

1. The AGR card functions in a similar way to that of the CLU card.
2. AGR cards cannot be stacked.
3. The same PIN number cannot appear in more than one ring (must be unique).
4. A white boundary condition is applied at the edge of the problem.

2.5 Pn-Scattering Input

| Card | Description | Page |
|------|-------------------------------------------------|------|
| PNO | Pn-scattering order for advanced data libraries | 58 |
| UNQ | Uniform quadrature for 2D transport calculation | 59 |

These cards control the Pn higher order scattering model in CASMO-4E. Use of the Pn-scattering model requires the CASMO ENDF/B-VI advanced data library.

PNO Pn scattering order for advanced data libraries

| | |
|------------|-------------|
| PNO | IORD |
|------------|-------------|

IORD Pn scattering order to use in the forward flux solution (0 through 7)

Default:

IORD=0

Example:

PNO 5 * Pn-scattering order set to 5

Comment:

- 1.This card can only be used with E6 data library which contains Pn scattering data.
2. The Pn-scattering calculation requires a unified quadrature for the 2D transport solution and automatically uses the UNQ card defaults. An UNQ card is not required unless the characteristics ray spacing or number of azimuthal angles needs to be refined.
3. **The Pn-scattering calculation has not been implemented in diagonal symmetry (IGEOM=2 or 8). If the input is not in full geometry, the code automatically expand the problem to full geometry.**
- 4.The E6 advanced data library contains anisotropic scattering data (matrices) for the following 20 idents: (H in H2O), O, Al, Si, Cr, Mn, Fe, Ni, Zr, Nb, U-235, U-238, Pu-239, Zirc-2, Zirc-4, ZIRLO, stainless steel, Inconel-718, Inconel-750 with Pn data available up to order 7 for most of the idents (the heavy isotopes have data only up to order 5). These idents cover most of the important contributors to higher order scattering.
5. The Pn-scattering model is fully compatible with the S3C option.
6. Use of the Pn-scattering model will be CPU and memory intensive. Some cases may require use of the MEM card to increase the amount of memory available to the job.
7. P3 is generally sufficient in most cases to capture any Pn-effect.
8. This data is not written to the restart file.
9. This card is not normally required.

UNQ Uniform quadrature for 2D transport calculation

| | |
|------------|-----------------------|
| UNQ | NAZIM, NPOLAR, XSPACE |
|------------|-----------------------|

NAZIM Number of azimuthal angles

NPOLAR Number of polar angles

XSPACE Ray-spacing (cm)

Default:

NAZIM=32

NPOLAR=3 (=5 for MOX)

XSPACE=0.1 cm

Example:

UNQ 128 5 0.05 * 128 azi, 5 polars and 0.05 cm spacing

Comment:

1. This card instructs the code to use a unified quadrature in the characteristics based, 2D neutron transport solution (based on the input parameters on the card) rather than the standard 3-level quadrature.
2. All three values must entered on the UNQ card.
3. This card has no effect on the quadrature used in the gamma transport calculation.
4. This card is useful when used in conjunction with the Pn-scattering model where some cases may require refinement of the ray-spacing or number of azimuthal angles.
5. SSP recommends use of the default values. Use of values less than the default values can seriously degrade the accuracy of the 2D transport solution.
6. This card is not normally required.

2.6 Miscellaneous Input

| Card | Description | Page |
|-----------------------------|-----------------------------------------|------|
| Azimuthal Depletion: | | |
| AZI | Azimuthal subdivision of pins | 62 |
| LAZ | Layout of azimuthal subdivision of pins | 63 |
| Miscellaneous: | | |
| OFF | Turn off models | 64 |
| PSC | Generate color graphic of geometry | 65 |
| PSF | Filename for PostScript/Tiff graphic | 67 |
| QCK | Quick execution | 68 |

AZI Azimuthal subdivision of pins

| | |
|------------|-------------------------------------------------------------------------------------------------------|
| AZI | $N_1, \text{'opt}_{11}', \text{'opt}_{12}', \dots / N_2, \text{'opt}_{21}', \text{'opt}_{22}', \dots$ |
|------------|-------------------------------------------------------------------------------------------------------|

- N_i 1, 4 or 8; azimuthal subdivision will be done in 1 (no subdivision), 4 or 8 equal parts of pins of type 'opt_{ij}'.
- 'opt_{ij}' 'GD' pins containing Gd
 'B10' pins containing burnable boron (5010)
 'ER' pins containing Er
 'ALL' all pins **containing burnable nuclides**

Default:

AZI 1 'ALL'

Example:

AZI 4 'GD'

Comment:

The segments are numbered counterclockwise as shown below.



Edits for azimuthal regions can be obtained using the RAD input card.

LAZ Layout of azimuthal subdivision of pins

| LAZ | N_1 | or | | | N_1 | N_2 | N_3 | - |
|------------|-------|-----------|---|---|-------|-------|-------|---|
| | N_2 | N_3 | | | - | - | - | - |
| | - | - | - | | - | - | - | - |
| | - | - | - | - | - | - | - | - |

N_i 1, 4 or 8; azimuthal subdivision of pin i will be done in 1 (no subdivision), 4 or 8 equal parts.

Specify N_i for each pincell in that part of the bundle for which the calculation will be done according to parameter ISYM on card BWR/PWR.

Default:

N_i = 1

Example:

LAZ

1

1 1

1 4 1

1 1 1 1



1 8 1 8 1

1 1 1 1 1 1

Comment:

A number must be given in each position. Pins **not** containing burnable nuclides (e.g. water holes) will **not** be subdivided irrespective of the value of N_i on the LAZ card.

The segments are numbered counterclockwise as shown below.



Edits for azimuthal regions can be obtained using the RAD input card.

OFF Turn OFF models

| | |
|------------|---------------------------------------------------------------------|
| OFF | 'copt₁, 'copt₂' ... 'copt_n' |
|------------|---------------------------------------------------------------------|

| | |
|----------------------|------------------------------------------------------------------------------------------------------------|
| 'copt _n ' | Any of the following parameters: |
| 'GAD' | Turn off advanced quadratic Gd depletion model (reverts to previous "sub-step" skipping model) |
| 'LEG' | Turn off Legendre polynomials for polar angles integration (reverts to previous cosine**2 weighting model) |
| 'SSA' | Turn off iron and stainless steel correction to transport cross section in baffle/reflector |
| 'RND' | Turn off rounding of input statepoint parameters |

Comment:

- 1. This card is not normally required.

PSC Generate color graphic of geometry

| | |
|------------|-------------------------------------------|
| PSC | I1, I2, I3, I4 // XSTRT,YSTRT,SCALE/IFPSC |
|------------|-------------------------------------------|

| | |
|-------|------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|
| I1 | Drawing data type $0 < I1 \leq 2$ (in increasing order of spatial resolution) 0: By LFU type (with major materials in separate colors) 1: By X-S set type 2: Flat source regions (smallest spatial sub-division in CASMO) |
| I2 | Azimuthal angle number (0 indicates draw all angles which is generally what the user wants). If I2 is input as a negative number, then reflective counterpart angles are also drawn. (Needed only for special cases). |
| I3 | 1: Generate graphic for neutron thermal quadrature 2: Generate graphic for neutron epithermal quadrature 3: Generate graphic for neutron fast quadrature |
| I4 | 0: Fullest possible resolution (best picture, largest file size) 1: 600 DPI 2: 300 DPI (smallest file size) |
| I5 | 0: COO and MOD different colors of blue in graphic (default) 1: COO and MOD both light blue in graphic 2: COO and MOD both dark blue in graphic |
| XSTRT | X position offset of lower left hand corner of drawing |
| YSTRT | Y position offset of lower left hand corner of drawing |
| SCALE | Multiplicative scale factor for sizing of drawing |
| IFPSC | 0: Generate Tiff format, 1: Generate PostScript Format |

Default:

I1=0, I2=0, I3=1, I4=2, I5=0, XSTRT=0.0, YSTRT=0.0, SCALE=1.0, IFPSC=0

Example:

PSC

Comment:

1. This card is intended primarily for debugging the physical layout of MxN or FSS/FSC geometries. Since the resulting picture is built up from the individual tracks in the characteristics ray-tracing (very low level), this diagram provides an accurate picture of the geometry as actually seen by the 2D transport solution and is very different from picture generation schemes which interpret the input and attempt to draw cylinders and squares etc.
2. The output file is generated in the file: baseinput.name.yy, where yy is ps or tif. (see the PSF card for renaming the file).
3. The generated graphics file may be quite large and the generation of this file does increase run time.
4. The default file format for the generated files is Tiff which will generate a smaller file than the equivalent PostScript file. Both file formats may be viewed by a variety of graphics viewers. SSP does not support or recommend any specific Tiff or PostScript viewers.
5. The picture may be centered on the page through use of XSTRT and YSTRT parameters. (Note, it is possible for the XSTRT and YSTRT to move the generated picture off the page!).
6. Only one graphic will be generated within any one particular run and then only for the first statepoint.
7. It is possible for two adjacent regions to have the same color, i.e., there is no guarantee of spatial color distinctiveness.
- 8. The resultant graphics are not intended to be "publication quality" and the capability is provided only to help the user verify the input geometry.**

PSF Filename for PostScript/Tiff graphic

| | |
|------------|-------------|
| PSF | 'FILE_NAME' |
|------------|-------------|

FILE_NAME Filename for ray tracing graphic

Default:

The graphic file is generated in the file: baseinput.name.xxx, where xxx may be ps or tif.

Example:

```
PSF 'ge-12.tif' * Name the file ge-12.tif
```

Comment:

1. This card works in concert with the PSC card.
2. The file produced is named exactly as input (no .ps or .tif suffix is automatically applied).
3. This data is not written to restart file or the Card Image File.

QCK Quick execution

| | |
|------------|--|
| QCK | |
|------------|--|

Example:

QCK

Default: None**Comment:**

1. This card runs the input in a greatly reduced spatial and energy detail in order to check the complete mechanics of the run. Specifically, the number of 2D energy groups is set to 4 and the quadrature to: 32 azimuthal angles, 1 polar angle, and a mesh spacing of 0.2 cm. The macrogroup calculation is skipped.
2. **This option is not to be used for analysis as the accuracy of the solution will be severely degraded.**
3. This option can be helpful when setting up large MxN problems.
4. Card image files are not generated during a QCK execution.
5. The following warning is issued when a QCK card is detected:

[WARNING] IN ROUTINE <INP_QCK>. QCK card detected --Do not use results for analysis!!

and at termination:

```
*****
*   CASMO-4E NORMAL TERMINATION   *
*   -WARNINGS ENCOUNTERED-        *
*****
====>Quick option used ---Results not appropriate for analy-
sis.....
STOP: C-4E Complete....
```

2.7 Input Examples

This section contains complete inputs for typical CASMO-4E applications.

| Subsection | Page | Type of cases |
|------------|------|--------------------------------------------------|
| 2.8.1 | 70 | MxN Input Example 1: Mixed 3x3 BWR |
| 2.8.2 | 73 | MxN Input Example 2: 1/8 Core BWR Depletion |
| 2.8.3 | 76 | MxN Input Example 3: 1/4 Core PWR Base Depletion |
| 2.8.4 | 81 | MxN Input Example 4: 1/4 Core PWR Shuffle |
| 2.8.5 | 86 | AZI Sample Input |
| 2.8.6 | 87 | LAZ Sample Input |
| 2.8.7 | 88 | CLU/MAG/AGR Sample Inputs |
| 2.8.8 | 89 | FSS/FSC Sample Input |
| 2.8.9 | 91 | Pn Scattering Sample Input |

2.8.1 MxN Input Example 1: Mixed 3x3 BWR

Example 1 is a 3x3 lattice of mixed BWR assemblies (see Figure 2.7) depleted to 1.0 GWd/MT and with the gamma calculation active. All dimensions and enrichments are approximate and are merely intended to be representative of normal values.

```

MEM 50 30 30
TTL *Mixed BWR 3x3
MXN 2 * Diagonal Sym.

LSE 3 4 1
    4 3 2
    1 2 3/3 3


LCR 1 1 1
    1 1 1
    1 1 1/'CRD'

BAS
TFU 750 TMO 560
PDE 50.00 'KWL'
CRD 0.415 0 1.98 10.3608 0.2110 0.5756/'CRA' 'CRS'/'/'CRD','ROD'
DEP -1.0
GAM
* Note: all design numbers are approximate
SEG 1 *Atrium like
BWR 10 1.295 13.40 0.2 1.000 0.5 1.25
PIN 1 0.43 0.44 0.50
PIN 2 1.70 1.75/'MOD','BOX'/'-9
PIN 3 0.50 /'COO'
LPI
1 1 1 1 1 1 1 1 1 1
1 1 1 1 1 1 1 1 1 1
1 1 1 1 1 1 1 1 1 1
1 1 1 1 1 1 1 1 1 1
1 1 1 1 2 2 2 1 1 1
1 1 1 1 2 2 2 1 1 1
1 1 1 1 2 2 2 1 1 1
1 1 1 1 1 1 1 1 1 1
1 1 1 1 1 1 1 1 1 1
1 1 1 1 1 1 1 1 1 1
1 1 1 1 1 1 1 1 1 1
FUE 1 10.314/1.60
FUE 2 10.314/2.10
FUE 3 10.314/2.60
FUE 4 10.314/2.90
FUE 5 10.314/3.20
FUE 6 10.314/3.60
FUE 7 10.314/3.80
FUE 8 10.189/3.30,64016=2.00
LFU
1 2 3 4 5 5 4 4 3 2
2 3 5 7 7 7 8 7 6 4
3 5 7 7 8 7 7 7 7 6
4 7 7 8 7 7 7 7 7 7
5 7 8 7 0 0 0 7 8 7
5 7 7 7 0 0 0 7 7 7
4 8 7 7 0 0 0 7 8 7
4 7 7 7 7 7 7 7 7 7
3 6 7 7 8 7 8 7 7 5
2 4 6 7 7 7 7 7 5 4
SEG 2 *GE-12 like
BWR 10 1.295 13.406 0.135 0.952 0.672 1.308 1 /0.25,3.59
PIN 1 0.44 0.45 0.51
PIN 2 1.17 1.25/'MOD','BOX'/'4
PIN 3 0.51 /'COO'
LPI
1 1 1 1 1 1 1 1 1 1
1 1 1 1 1 1 1 1 1 1
1 1 1 1 1 1 1 1 1 1
1 1 1 1 1 2 2 1 1 1
1 1 1 1 1 2 2 1 1 1
1 1 1 2 2 1 1 1 1 1
1 1 1 2 2 1 1 1 1 1
1 1 1 1 1 1 1 1 1 1
1 1 1 1 1 1 1 1 1 1
1 1 1 1 1 1 1 1 1 1
1 1 1 1 1 1 1 1 1 1
FUE 1 10.450/0.71
LFU
1 1 1 1 1 1 1 1 1 1
1 1 1 1 1 1 1 1 1 1
1 1 1 1 1 1 1 1 1 1
1 1 1 1 1 0 0 1 1 1
1 1 1 1 1 0 0 1 1 1
1 1 1 0 0 1 1 1 1 1
1 1 1 0 0 1 1 1 1 1
1 1 1 1 1 1 1 1 1 1

```

```
1 1 1 1 1 1 1 1 1 1
1 1 1 1 1 1 1 1 1 1
SEG 3 * SVEA-64 Like
BWR 9 1.58 13.74 0.08 0.758 0.642 1.01
PIN 1 0.52 0.53 0.62
SLA 3 0.195 0.076 0.1435/'MOD','BOX'
LPI
1 1 1 1 3 1 1 1 1
1 1 1 1 3 1 1 1 1
1 1 1 1 3 1 1 1 1
1 1 1 1 3 1 1 1 1
1 1 1 1 3 1 1 1 1
3 3 3 3 3 3 3 3 3
1 1 1 1 3 1 1 1 1
1 1 1 1 3 1 1 1 1
1 1 1 1 3 1 1 1 1
1 1 1 1 3 1 1 1 1
1 1 1 1 3 1 1 1 1
FUE 2 10.395/1.4
FUE 3 10.395/1.8
FUE 4 10.395/2.5
FUE 5 10.395/2.8
FUE 6 10.395/3.2
FUE 7 10.395/3.7
FUE 9 10.252/3.0,64016=2.0
LFU
2 4 4 4 0 4 5 4 3
4 5 9 7 0 7 9 7 4
4 9 7 7 0 7 7 7 5
4 7 7 7 0 7 7 9 5
0 0 0 0 0 0 0 0 0
4 7 7 7 0 9 7 7 5
5 9 7 7 0 7 7 7 6
4 7 7 9 0 7 7 9 6
3 4 5 5 0 5 6 6 3
SEG 4 *SVEA-100 Like
BWR 11 1.27 13.74 0.08 0.758 0.642 1.01
SLA 3 0.195 0.076 0.109/'MOD' 'BOX'
PIN 1 0.41 0.42 0.49
LPI
1 1 1 1 1 3 1 1 1 1 1
1 1 1 1 1 3 1 1 1 1 1
1 1 1 1 1 3 1 1 1 1 1
1 1 1 1 1 3 1 1 1 1 1
1 1 1 1 1 3 1 1 1 1 1
1 1 1 1 1 3 1 1 1 1 1
3 3 3 3 3 3 3 3 3 3 3
1 1 1 1 1 3 1 1 1 1 1
1 1 1 1 1 3 1 1 1 1 1
1 1 1 1 1 3 1 1 1 1 1
1 1 1 1 1 3 1 1 1 1 1
1 1 1 1 1 3 1 1 1 1 1
1 1 1 1 1 3 1 1 1 1 1
FUE 1 10.395/1.6
FUE 2 10.395/2.5
FUE 3 10.395/2.8
FUE 4 10.395/3.3
FUE 5 10.395/3.5
FUE 6 10.395/4.2
FUE 7 10.395/4.7
FUE 8 10.228/4.0,64016=2.0
LFU
1 1 2 2 2 0 3 3 3 2 1
1 2 3 5 5 0 5 5 4 3 3
2 3 5 8 5 0 6 8 6 8 3
2 5 8 6 6 0 6 6 7 5 4
2 5 5 6 8 0 6 7 8 6 5
0 0 0 0 0 0 0 0 0 0
3 5 6 6 6 0 8 7 6 6 5
3 5 8 6 7 0 7 7 7 8 5
3 4 6 7 8 0 6 7 7 5 5
2 3 8 5 6 0 6 8 5 4 3
1 3 3 4 5 0 5 5 5 3 1
STA
END
```

Fig. 2.7 Diagram of MxN Input Example 1 (Mixed 3x3 BWR)




```
FUE 3 10.494/0.710
LFU
3
3 2
3 1 1
2 1 1 0
2 1 1 0 0
2 1 1 1 1 1
3 2 1 1 1 1 2
3 3 2 2 2 3 3 3
```

```
SEG 2
FUE 1 10.494/2.800
FUE 2 10.494/2.450
FUE 3 10.494/2.100
FUE 4 10.494/1.700
FUE 5 10.250/1.700 7301=4.0
FUE 6 10.250/1.700 7301=4.0
LFU
4
3 2
2 1 6
2 1 3 0
2 1 3 0 0
2 1 1 3 3 4
3 2 1 5 1 1 2
4 3 2 2 2 2 3 4
```

```
SEG 3
FUE 1 10.494/4.400
FUE 2 10.494/3.900
FUE 3 10.494/3.400
FUE 4 10.494/3.000
FUE 5 10.494/2.100
FUE 6 10.250/3.400 7301=4.0
FUE 7 10.250/3.400 7301=4.0
LFU
5
4 2
3 1 6
3 2 1 0
3 7 1 0 0
3 1 6 1 1 6
4 2 1 7 2 1 2
5 4 3 3 3 3 4 5
```

```
STA
END
```


Fig. 2.8 Diagram of MxN Input Example 2 (1/8 Core Model)

2.8.3 MxN Input Example 3: 1/4 Core PWR Base Depletion

This particular PWR 1/4 input contains 2 MOX assemblies and demonstrates several features: boron letdown via PVD, exposure dependent TMO values specified by assembly on the LTM card, and also demonstrates how to manually model the PWR baffle (instead of using the BAF card). **All dimensions and enrichments are approximate and are merely intended to be representative of normal values.**

```
MEM 210 60
TTL * MxN PWR depletion Test Case with 2 mox assemblies
MXN 2 1 * Diagonal sym. with axis spanning assemblies
* Note: all design numbers are approximate
LSE 2 1 2 1 2 1 1 4
    1 2 1 2 1 2 1 4
    2 1 2 3 2 1 1 4
    1 2 3 2 1 1 6 5
    2 1 2 1 1 6 5 0
    1 2 1 1 6 5 0 0
    1 1 1 6 5 0 0 0
    4 4 4 5 0 0 0 0 /8 8

LRO 0 0 0 0 0 0 0 3
    0 0 0 0 0 0 0 3
    0 0 0 0 0 0 0 3
    0 0 0 0 0 0 0 0
    0 0 0 0 0 0 0 0
    0 0 0 0 0 0 0 0
    0 0 0 0 0 0 0 0
    0 0 0 0 0 0 0 0

LTM 550 550 550 550 550 550 550 550
    550 550 550 550 550 550 550 550
    550 550 550 550 550 550 550 550
    550 550 550 550 550 550 550 550
    550 550 550 550 550 550 550 550
    550 550 550 550 550 550 550 550
    550 550 550 550 550 550 550 550
    550 550 550 550 550 550 550 550 / 0.0 1.0

LTM 560 560 560 560 560 560 560 560
    560 560 560 560 560 560 560 560
    560 560 560 560 560 560 560 560
    560 560 560 560 560 560 560 560
    560 560 560 560 560 560 560 560
    560 560 560 560 560 560 560 560
    560 560 560 560 560 560 560 560
    560 560 560 560 560 560 560 560 / 1.0 4.0

LTM 565 565 565 565 565 565 565 565
    565 565 565 565 565 565 565 565
    565 565 565 565 565 565 565 565
    565 565 565 565 565 565 565 565
    565 565 565 565 565 565 565 565
    565 565 565 565 565 565 565 565
    565 565 565 565 565 565 565 565
    565 565 565 565 565 565 565 565 / 4.0 30.0

BAS
* Boron Letdown:
PVD 'BOR' 0.000 1200.0
          0.151 1150.0
          0.501 1120.0
          1.001 1100.0
          3.001 1000.0
          6.001 800.0
          10.001 450.0
          14.001 300.0
          16.001 200.0
          20.001 100.0
          25.001 50.0
          35.001 10.0
WRI -100 /'RES' * Write restart files for each segment as every statepoint
TFU 840
TMO 560
PDE 35.0
```


```
THE 0
XEN 2
DEP -20.0
S3I 'ON'

SEG 1 *
PWR 17,1.26,,,,,1
FUE 1 10.41/3.50
PIN 1 .41 .475/'1' 'CAN'
PIN 2 .57 .615/'COO' 'CAN'
LPI
1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1
1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1
1 1 1 1 1 2 1 1 2 1 1 2 1 1 1 1
1 1 1 2 1 1 1 1 1 1 1 1 1 2 1 1
1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1
1 1 2 1 1 2 1 1 2 1 1 2 1 1 2 1
1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1
1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1
1 1 2 1 1 2 1 1 2 1 1 2 1 1 2 1
1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1
1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1
1 1 2 1 1 2 1 1 2 1 1 2 1 1 2 1
1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1
1 1 1 2 1 1 1 1 1 1 1 1 1 2 1 1
1 1 1 1 1 2 1 1 2 1 1 2 1 1 1 1
1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1
1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1

SEG 2 *
PWR 17,1.26,,,,,1
FUE 1 10.41/2.00
PIN 1 .41 .475/'1' 'CAN'
PIN 2 .57 .615 /'COO' 'CAN'
LPI
1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1
1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1
1 1 1 1 1 2 1 1 2 1 1 2 1 1 1 1
1 1 1 2 1 1 1 1 1 1 1 1 1 2 1 1
1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1
1 1 2 1 1 2 1 1 2 1 1 2 1 1 2 1
1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1
1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1
1 1 2 1 1 2 1 1 2 1 1 2 1 1 2 1
1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1
1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1
1 1 2 1 1 2 1 1 2 1 1 2 1 1 2 1
1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1
1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1
1 1 2 1 1 2 1 1 2 1 1 2 1 1 2 1
1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1
1 1 1 2 1 1 1 1 1 1 1 1 1 2 1 1
1 1 1 1 1 2 1 1 2 1 1 2 1 1 1 1
1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1
1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1

SEG 3 * Representative Mox assembly with bp
PWR 17,1.26,,,,,2
MI1,2.23/14000=40.9006,8000=55.2174,5010=0.7182,5011=3.1638
MI2,7.90,18.E-6/347=100
PIN,1,.41,.42,.475
PIN,2,.57,.61/'MOD','BOX'
PIN,3,.57,.61/'MOD','BOX'
PIN,4,.214,.231,.242,.427,.437,.500,.572,.610/
      'AIR','MI2','AIR','MI1','AIR','MI2','MOD','BOX'
FUE,1,10.2/4.0
FUE,2,10.2/0.72,94238=0.05,94239=2.5,94240=1.0,94241=0.3,
      94242=0.15
FUE,3,10.2/0.72,94238=0.075,94239=3.75,94240=1.5,94241=0.45,
      94242=0.225
FUE,4,10.2/0.72,94238=0.1,94239=5.,94240=2.0,94241=0.60,
      94242=0.300
LPI
1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1
1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1
1 1 1 1 1 4 1 1 4 1 1 4 1 1 1 1
1 1 1 4 1 1 1 1 1 1 1 1 4 1 1 1
1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1
1 1 4 1 1 4 1 1 4 1 1 4 1 1 4 1 1
1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1
1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1
1 1 4 1 1 4 1 1 2 1 1 4 1 1 4 1 1
1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1
```

2-78

Fig. 2.9 Diagram of MxN Input Example 3 (1/4 Core PWR Pre-Shuffle)

Comment: The two MOX assemblies are clearly visibly in this PWR 1/4 case. The Tiff file for this diagram was approximately 49 megabytes and the PostScript file 696 megabytes.

2.8.4 MxN Input Example 4: 1/4 Core PWR Shuffle

In this input, the two MOX assemblies have been shuffled, and two new fresh assemblies placed in the core. All data for the depleted assemblies comes from the CASMO-4E restart files generated by the input given in the previous example (Example 3). This input also demonstrates use of the FIL card to attach the CASMO restart files. Three fresh assemblies have also been inserted. A LEX map could also have been used in this example. All dimensions and enrichments are approximate and are merely intended to be representative of normal values.

```
MEM 210 60
TTL * MxN PSSP 10*1
MXN 1 1 * Full symmetry, axis spanning assemblies present
* Note: all design numbers are approximate

LSE 57 58 59 60 61 62 63 64
    49 99 51 52 44 99 55 56
    41 42 43 53 45 46 47 48
    33 34 26 36 37 38 39 40
    25 35 27 28 29 30 31 0
    17 99 19 20 21 22 0 0
    9 10 11 12 13 0 0 0
    1 2 3 4 0 0 0 0 /8 8

LRO 0 0 0 0 0 0 0 3
    0 0 0 0 0 0 0 3
    0 0 0 0 0 0 0 3
    0 0 0 0 0 0 0 0
    0 0 0 0 0 0 0 0
    0 0 0 0 0 0 0 0
    0 0 0 0 0 0 0 0
    0 0 0 0 0 0 0 0

BAS
THE 0
XEN 2
DEP 0.0
S3I 'ON'
PDE 35.0
PVD 'BOR' 0.000 1200.0
    0.151 1150.0
    0.501 1120.0
    1.001 1100.0
    3.001 1000.0
    6.001 800.0
    10.001 450.0
    14.001 300.0
    16.001 200.0
    20.001 100.0
    25.001 50.0
    35.001 10.0

TFU 840
TMO 550
DEP -0.1
S3I '1/4'
PWR 17,1.26,,,,,1 *Needed for auto-generated reflectors

SEG 1 *
FIL 'pwr.qtr.seg1.res'
RES '*' 10.0

SEG 2 *
FIL 'pwr.qtr.seg2.res'
RES '*' 10.0

SEG 3 *
FIL 'pwr.qtr.seg3.res'
RES '*' 10.0

SEG 4 *
FIL 'pwr.qtr.seg4.res'
RES '*' 10.0
```

```
SEG 9      *
FIL 'pwr.qtr.seg9.res'
RES '*' 10.0

SEG 10     *
FIL 'pwr.qtr.seg10.res'
RES '*' 10.0

SEG 11     *
FIL 'pwr.qtr.seg11.res'
RES '*' 10.0

SEG 12     *
FIL 'pwr.qtr.seg12.res'
RES '*' 10.0

SEG 13     *
FIL 'pwr.qtr.seg13.res'
RES '*' 10.0

SEG 17     *
FIL 'pwr.qtr.seg17.res'
RES '*' 10.0

SEG 18     *
FIL 'pwr.qtr.seg18.res'
RES '*' 10.0

SEG 19     *
FIL 'pwr.qtr.seg19.res'
RES '*' 10.0

SEG 20     *
FIL 'pwr.qtr.seg20.res'
RES '*' 10.0

SEG 21     *
FIL 'pwr.qtr.seg21.res'
RES '*' 10.0

SEG 22     *
FIL 'pwr.qtr.seg22.res'
RES '*' 10.0

SEG 25     *
FIL 'pwr.qtr.seg25.res'
RES '*' 10.0

SEG 26     *
FIL 'pwr.qtr.seg26.res'
RES '*' 10.0

SEG 27     *
FIL 'pwr.qtr.seg27.res'
RES '*' 10.0

SEG 28     *
FIL 'pwr.qtr.seg28.res'
RES '*' 10.0

SEG 29     *
FIL 'pwr.qtr.seg29.res'
RES '*' 10.0

SEG 30     *
FIL 'pwr.qtr.seg30.res'
RES '*' 10.0

SEG 31     *
FIL 'pwr.qtr.seg31.res'
RES '*' 10.0

SEG 33     *
FIL 'pwr.qtr.seg33.res'
RES '*' 10.0

SEG 34     *
FIL 'pwr.qtr.seg34.res'
RES '*' 10.0
```

```
SEG 35  *
FIL 'pwr.qtr.seg35.res'
RES '**' 10.0

SEG 36  *
FIL 'pwr.qtr.seg36.res'
RES '**' 10.0

SEG 37  *
FIL 'pwr.qtr.seg37.res'
RES '**' 10.0

SEG 38  *
FIL 'pwr.qtr.seg38.res'
RES '**' 10.0

SEG 39  *
FIL 'pwr.qtr.seg39.res'
RES '**' 10.0

SEG 40  *
FIL 'pwr.qtr.seg40.res'
RES '**' 10.0

SEG 41  *
FIL 'pwr.qtr.seg41.res'
RES '**' 10.0

SEG 42  *
FIL 'pwr.qtr.seg42.res'
RES '**' 10.0

SEG 43  *
FIL 'pwr.qtr.seg43.res'
RES '**' 10.0

SEG 44  *
FIL 'pwr.qtr.seg44.res'
RES '**' 10.0

SEG 45  *
FIL 'pwr.qtr.seg45.res'
RES '**' 10.0

SEG 46  *
FIL 'pwr.qtr.seg46.res'
RES '**' 10.0

SEG 47  *
FIL 'pwr.qtr.seg47.res'
RES '**' 10.0

SEG 48  *
FIL 'pwr.qtr.seg48.res'
RES '**' 10.0

SEG 49  *
FIL 'pwr.qtr.seg49.res'
RES '**' 10.0

SEG 50  *
FIL 'pwr.qtr.seg50.res'
RES '**' 10.0

SEG 51  *
FIL 'pwr.qtr.seg51.res'
RES '**' 10.0

SEG 52  *
FIL 'pwr.qtr.seg52.res'
RES '**' 10.0

SEG 53  *
FIL 'pwr.qtr.seg53.res'
RES '**' 10.0

SEG 54  *
FIL 'pwr.qtr.seg54.res'
RES '**' 10.0
```

```
SEG 55  *
FIL 'pwr.qtr.seg55.res'
RES '*' 10.0

SEG 56  *
FIL 'pwr.qtr.seg56.res'
RES '*' 10.0

SEG 57  *
FIL 'pwr.qtr.seg57.res'
RES '*' 10.0

SEG 58  *
FIL 'pwr.qtr.seg58.res'
RES '*' 10.0

SEG 59  *
FIL 'pwr.qtr.seg59.res'
RES '*' 10.0

SEG 60  *
FIL 'pwr.qtr.seg60.res'
RES '*' 10.0

SEG 61  *
FIL 'pwr.qtr.seg61.res'
RES '*' 10.0

SEG 62  *
FIL 'pwr.qtr.seg62.res'
RES '*' 10.0

SEG 63  *
FIL 'pwr.qtr.seg63.res'
RES '*' 10.0


SEG 64  *
FIL 'pwr.qtr.seg64.res'
RES '*' 10.0

SEG 99  * Fresh Assembly
PWR 17,1.26,,,,,1
FUE 1 10.41/4.00
PIN 1 .4096 .4750/'1' 'CAN'
PIN 2 .5690 .6147/'COO' 'CAN'
LPI
2 2 2 2 2 2 2 2 2 2 2 2 2 2 2 2 2
2 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 2
2 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 2
2 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 2
2 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 2
2 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 2
2 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 2
2 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 2
2 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 2
2 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 2
2 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 2
2 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 2
2 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 2
2 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 2
2 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 2
2 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 2
2 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 2
2 2 2 2 2 2 2 2 2 2 2 2 2 2 2 2 2

STA
END
```

Fig. 2.10 Diagram of MxN Input Example 4 (1/4 Core PWR Post Shuffle)

Comment: The 2 MOX assemblies in this PWR 1/4 case have clearly been shuffled from their previous locations (Example 3) and 3 fresh assemblies have been added (visible as squares in the diagram).



2.8.5 AZI Sample Input

```
TTL TFU=850 TMO=560 VOI=00 * Ex: AZI Option
FUE 1 10.16/2.5
FUE 2 10.16/3.3
FUE 3 10.16/3.5
FUE 4 10.16/4.0
FUE 5 10.16/4.9
FUE 6 10.16/2.2
FUE 7 9.98/2.2 7300=7
LFU 1
    2 7
    3 4 4
    4 5 5 7
    4 7 5 0 0
    4 5 5 5 0 7
    3 4 4 5 5 5 4
    2 7 4 5 7 5 4 7
    1 2 3 4 4 4 3 2 1
AZI 8 'ALL'
BWR 9 1.4300 13.2461 0.3048 0.6921 0.6921 1.2700
PIN 1 0.47 0.48 0.56
PIN 2 0.45 0.46 0.53
PIN 3 0.66 0.69/'MOD' 'CAN'
PIN 4 0.46 0.53/'MOD' 'CAN'
LPI 1
    1 1
    1 1 1
    1 2 2 2
    1 2 2 3 4
    1 2 2 2 3 2
    1 1 1 2 2 2 1
    1 1 1 2 2 2 1 1
    1 1 1 1 1 1 1 1 1
PDE 50 'KWL'
DEP -10
* Edit azimuthal data for Gd
RAD 11 14 17 30 32 39 44/64152 -64160
STA
END
```


2.8.6 LAZ Sample Input

```

TTL TFU=850 TMO=560 VOI=00 * Ex: LAZ Option
BWR 9 1.4300 13.2461 0.3048 0.6921 0.6921 1.2700
FUE 1 10.16/2.5
FUE 2 10.16/3.3
FUE 3 10.16/3.5
FUE 4 10.16/4.0
FUE 5 10.16/4.9
FUE 6 10.16/2.2
FUE 7 9.98/2.2 7300=7
LFU 1
    2 7
    3 4 4
    4 5 5 7
    4 7 5 0 0
    4 5 5 5 0 7
    3 4 4 5 5 5 4
    2 7 4 5 7 5 4 7
    1 2 3 4 4 4 3 2 1
LAZ 1
    1 8
    1 1 1
    1 1 1 8
    1 8 1 1 1
    1 1 1 1 1 8
    1 1 1 1 1 1 1
    1 8 1 1 8 1 1 8
    1 1 1 1 1 1 1 1
PIN 1 0.47 0.48 0.56
PIN 2 0.45 0.46 0.53
PIN 3 0.66 0.69/'MOD' 'CAN'
PIN 4 0.46 0.53/'MOD' 'CAN'
LPI 1
    1 1
    1 1 1
    1 2 2 2
    1 2 2 3 4
    1 2 2 2 3 2
    1 1 1 2 2 2 1
    1 1 1 2 2 2 1 1
    1 1 1 1 1 1 1 1 1
PDE 50 'KWL'
DEP -40
STA
END

```

2.8.7 CLU/MAG/AGR Sample Inputs

```
TTL TFU=300 TMO=300 * TEST OF *CLU* APPLICATION
ERR 9
* ENDF-VI library needed
FUE 1 9.54/2.0
MOD 1.695/6001=100
CLU 0.0 1 1
      1.6 2 6/
      2.6 3.0 14.1/'COO' 'BOX' 'MOD'
PIN 1 0.75/'BOX'
PIN 2 0.5915 0.6815/'1' 'CAN'
PIN 3 0.6815/'COO'
STA
END
```

```
TTL TFU=760 TMO=571 * GENERIC MAGNOX PINCELL CALCULATION
*UO2 DENSITY = 18.66G/CC, INITIAL 235U=0.71 WT%
FUE 1 18.66/0.71 92238=99.29 8000=0
MAG 1.406 2.51 5.03 11.12/'1' 'CAN' 'AIR' 'MOD'/10
PDE 20
DEP -10
STA
END
```

```
TTL *AGR EXAMPLE
TFU=850 TMO=700
FUE 1 10.4/2.55
PIN 1 .7/'MOD' 'CAN'
PIN 2 .3 .7 .8/'AIR' '1' 'CAN'
PIN 3 .3 .7 .8/'AIR' '1' 'CAN'
PIN 4 .3 .7 .8/'AIR' '1' 'CAN'
AGR 0.0 1 1
      1.6 2 6
      3.2 3 12
      6.0 4 18/
      7.0 8.0 11.0 25.0/'COO' 'MOD' 'COO' 'MOD'
PDE 20
THE 0
STA
END
```

2.8.8 FSS/FSC Sample Input

```

MEM 45 10
TTL * EX: FSS/FSC FUEL STORAGE RACK EXAMPLE
*
* Calculation will be in 40 energy groups, (no macrogroup calc.)
* Thermal expansion will be OFF and fundamental mode calc. will be omitted
*
TFU=920
TMO=560.0
MI2 7.9 / 14000=1.5    24000=18.0  25000=1.0    26000=70.0  28000=9.5
PSC
*
* Describe fuel storage rack side with 6 slabs (and various sub-slabs)
* Description is for the north side and will be used for all sides (N,W,S,E)
*
* Thickness (cm) / sub-slab lengths (cm)          / sub-slab materials/
FSS 1.5          / 15.25                          / 'COO' / * Outermost slab
     0.25        / 2.0 1.5 3.0 2.25 3.0 1.5 2.0 /
                               'CRC' 'MI2' 'CRC' 'MI2' 'CRC' 'MI2' 'CRC' /
     0.5          / 15.25                          / 'CRS' /
     0.5          / 2.5 10.25 2.5                  / 'CRC' 'MI2' 'CRC' /
     0.2          / 15.25                          / 'CRS' /
     0.3          / 2.0 11.25 2.0                  / 'CRC' 'MI2' 'CRC' /
*
* Describe fuel storage rack corner as it sits in the NW corner
* and use it for all corners (NW,SW,SE,NE) (code will auto-rotate)
* Matrix is 6x6 since each side has 6 slabs
*
FSC 'COO' 'COO' 'COO' 'COO' 'COO' 'COO'
    'COO' 'CRC' 'CRC' 'CRC' 'CRC' 'CRC'
    'COO' 'CRC' 'CRS' 'CRS' 'CRS' 'CRS'
    'COO' 'CRC' 'CRS' 'CRC' 'CRC' 'CRC'
    'COO' 'CRC' 'CRS' 'CRC' 'CRS' 'CRS'
    'COO' 'CRC' 'CRS' 'CRC' 'CRS' 'CRC'
*
* Generic BWR fuel segment
*
FUE 1 10.50/2.5
FUE 2 10.50/3.5
FUE 3 10.50/4.5
FUE 4 10.27/4.5 64016=4.0
LFU 1
    2 3
    3 4 3
    3 3 3 4
    3 3 3 3 3
    3 3 4 0 0 3
    3 3 3 0 0 4 3
    3 4 3 3 4 3 3 3
    2 3 4 3 3 4 3 4 3
    1 2 3 3 3 3 3 3 2 1


```

```

BWR 10 1.3 13.4 0.19 0.74 0.73 1.3 1/0.30 3.9
PIN 1 0.44 0.45 0.51
PIN 2 1.17 1.25/'MOD' 'BOX'//4
LPI 1
    1 1
    1 1 1
    1 1 1 1
    1 1 1 1 1
    1 1 1 2 2 1
    1 1 1 2 2 1 1
    1 1 1 1 1 1 1 1
    1 1 1 1 1 1 1 1 1
    1 1 1 1 1 1 1 1 1
PDE 54.0 'KWL'
STA
END

```

Fig. 2.11 FSS/FSC Example



2.8.9 Pn Scattering Sample Input

```

TTL * Ex21, 8x8 BWR WITH GD AND PN ORDER=3
* REQUIRES ADVANCED E6 DATA LIBRARY
TFU=790 TMO=559 VOI=40 IDE='EX21'
SIM 'SEGNAME' 2.74 5.0 4 4 * See note below
PNO 3 * Set Pn scattering order=3
BWR 8 1.63 13.4 .23 1. .5 1.2
FUE 1 10.15/1.6
FUE 2 10.15/2.3
FUE 3 10.15/3.2
FUE 4 9.98/2.9 64016=5 * 2.9% enr, 5 % GD203
SPA 2.22
PIN 1 .53 .54 .61 * Fuel rod
PIN 2 .54 .61/'MOD' 'BOX' * Water rod
LPI * Layout of pins
1
1 1
1 1 1
1 1 1 1
1 1 1 1 2
1 1 1 1 1 1
1 1 1 1 1 1 1
1 1 1 1 1 1 1 1
LFU * Layout of FUE
1
1 2
2 2 4
2 3 3 3
2 3 4 3 0
2 3 3 3 3 3
2 2 3 4 3 3 4
1 2 2 3 3 3 2 2
PDE 20 * Power density
DEP -50
STA
END

```

3 MxN Description

| Section | Title | Page |
|---------|-------------------------------------------|------|
| 3.1 | General Description of MxN Capability | 3 |
| 3.2 | MxN Methodology | 4 |
| 3.3 | MxN Depletion Calculations | 5 |
| 3.4 | MxN Boundary Conditions | 5 |
| 3.5 | Empty Locations: Autogenerated Reflectors | 5 |
| 3.6 | Using Single Assembly CASMO Restart Files | 6 |
| 3.7 | Boron Letdown During MxN Depletion | 7 |
| 3.8 | Axis Spanning Assemblies | 7 |
| 3.9 | MxN Shuffle Capability | 7 |
| 3.10 | B.P. Shuffle Model | 8 |
| 3.11 | Shutdown Cooling Calculation | 8 |
| 3.12 | Baffle/Barrel/Pad Automation | 9 |
| 3.13 | MxN Output Edits | 10 |
| 3.14 | MxN SUMMARY File | 10 |
| 3.15 | Maximum MxN Problem Size and Resources | 11 |

| Figure | Title | Page |
|----------|------------------------------------------------|------|
| Fig. 3.1 | MxN Segment Numbering | 3 |
| Fig. 3.2 | Placement of Segments into MxN Background Mesh | 4 |
| Fig. 3.3 | MxN Axis Spanning Assemblies | 7 |


This section describes the MxN module of CASMO-4E for modeling arbitrary arrays of assemblies.

3.1 General Description of MxN Capability

The MxN multi-segment option of CASMO-4E is a general extension of the CASMO 2x2 color set calculation in which an arbitrary array of assemblies may be modeled. In the MxN calculation each assembly may have its own individual design and rotation. Control rods may be inserted in any location and each assembly may be modeled at separate conditions (e.g., fuel temperature, void fraction, etc.). Assemblies may be defined via card input or through the attachment of a restart file, allowing for the placement of depleted assemblies among fresh assemblies. In addition, the MxN calculation provides for the easy inclusion of empty locations, which are filled with material MOD (typically unvoiced water). The method of characteristics (MOC) is used to solve for the 2D flux distribution for the entire problem. Furthermore, the full depletion capability of single assembly calculations is available as well as gamma calculations.

The MxN option is based on the assembly grid illustrated in Fig. 3.1. For purposes of clarity, "M" is the number of assembly mesh along the x-axis and "N" is the number of assembly mesh along the y-axis. CASMO-4 segment numbering starts in the lower left hand corner with segment 1 and proceeds left to right and then up. Understanding this numbering scheme is crucial in order to interpret the MxN output as edits and warning messages will frequently reference "Segment N" where N is the segment's location in the background mesh. In 1 below, the MxN layout is a 4x4 array of assemblies (also referred to as segments). The user specifies the segment type residing in each location via the LSE card (see description of input) and the corresponding rotation of each segment via the LRO card. The individual segments are then defined under the SEG cards in a way similar to that used for the standard 2x2 color set option.


Fig. 3.1 MxN Segment Numbering



Note that the background mesh must align with their neighbors and that this restriction requires that the segments have a common assembly pitch. However, segments may be of completely different designs (e.g., BWR assemblies with differing number of pins may occupy adjacent

segment locations as illustrated in Fig. 3.2.). However, if using the axis spanning assembly option, if an axis spanning assembly has an odd number of pin, then **all axis spanning assemblies must have the same number of pins.**

Fig. 3.2 Placement of Segments into MxN Background Mesh



In this example, there are two different segment designs present in the problem, plus two empty locations. It is not necessary for the user to specifically define the empty segment - CASMO will do that automatically (referred to as "auto-generated reflector segments"). If the user wishes to skew a particular segment to one corner of the background mesh then this may be accomplished by redefining the original segment and using the GAP card to reposition the assembly within the cell. Note that the presence of the control blade does not require the user to re-define segments. Control blades (and control rods of PWRs) may be inserted and withdrawn via the LCR input map.

For square problems exhibiting diagonal symmetry, the user may choose to perform the calculation on only the lower left triangular half of the problem. This reduces the overall size and memory requirements of the calculation and roughly cuts the execution time in half. There are no other symmetry options available for the MxN calculation (e.g., the inner eighth and quarter symmetry options for 2x2 color set PWRs are unavailable for the MxN calculation).

3.2 MxN Methodology

The calculation sequence flows in a manner similar to that of the 2x2 color set calculation. Each segment is processed on an individual basis until the 2D MOC transport module is reached, at which time the complete problem is constructed. Following the 2D calculation, the segments are de-coupled and once again treated on an individual basis for edits and burnup.

More specifically, pin cell calculations (i.e., the micro-group calculation) and the two-dimensional macro group calculation are performed on an individual segment basis. Following the pin cell calculations and two-dimensional macro group calculation, cross sections are condensed to the 2D group structure and the 2D MOC transport calculation is performed on the entire multi-segment problem. It is at this point that the segments are rotated into their proper orientation and placed into the appropriate location. The 2D transport calculation is then performed with the same detail as is used in single segment applications. Also as with the standard 2x2 calculation, the fundamental mode calculation is skipped (FUM,,3). If a gamma calculation has been requested then it is performed at this point before taking any burnup steps.

3.3 MxN Depletion Calculations

The MxN option is capable of performing depletion calculations, however, **stacked depletions are not allowed** (this is also true of the 2x2 color set option). Unlike single segment or 2x2 color set depletion calculations, the MxN option will not generate card image files (cax files) for the segments and will generate restart files only if specifically requested. All MxN problems are depleted using the new SSP proprietary gadolinium-depletion model which has been found to be more accurate and efficient for spatially large problems when compared with fine time-step analysis.

3.4 MxN Boundary Conditions

Either mirror or periodic boundary conditions may be applied to the outer edge of the MxN problem. Rotational symmetry is not available for the MxN calculation (nor for the 2x2 calculation). The periodic boundary condition is applied only during the 2D transport calculation. When performing an MxN calculation, mirror boundary conditions are always used for the two-dimensional macro group calculation.

3.5 Empty Locations: Autogenerated Reflectors

The MxN option makes available the easy modeling of empty assembly locations. CASMO will automatically generate the necessary data for such empty locations and the user does not to define an additional segment type. In such applications, CASMO gathers the necessary information for the empty location from the global data, i.e., input data which exists between the BAS card and the first SEG card. This includes such information as material temperatures, boron content (if any), definition of control rods which might be present in the empty location cell, etc. Users should take care that they define all necessary parameters in the proper location, otherwise, the code may not have enough information to construct the empty location properly. A PWR/BWR card must be present in the BAS input in order for CASMO to properly build an autogenerated reflector segment. Also a TFU and a TMO card must appear in the BAS part of the input.

Data for an auto-generated reflector segment will look something like:

```
SEG 1 *SEGMENT TYPE: 0 POSITION (LSE) (X,Y) : ( 1 1)
FUE 1 0.01/0.1
PIN 1 .4 /'MOD'
PIN 2 .4 .41 .42 .43/'MOD' '1' 'CAN' 'COO' 'MOD'
PWR 17 1.25980 0.00000 0.00000 0.00000 0.00000 0.00000 1 0
LPI 288*2 1 LFU 288*0 1

LST 1 1 0 SPA 0 VOI 0 PDE 0 MCO 1 1
```

3.6 Using Single Assembly CASMO Restart Files

Restart files generated from single segment depletion analyses may be attached for use in an MxN application, e.g., for interactions between depleted and fresh fuel. For 2x2 color set applications, restart files may be attached via the system JCL (typically the cas4 script) for each of the three or four segments being modeled. For MxN applications this method is impractical, since the number of restart files needed may much greater than 4 and may vary from case to case. To resolve this problem, the FIL card has been created which allows the user to declare the name of the restart file directly within the input deck. To function properly, the FIL card must follow the SEG card and precede the RES card, as illustrated e.g.,

```
TTL * Example of the FIL card
MXN 1
. . .
SEG 1
FIL '../single.assy.depl.res' * attach this file
RES , , 20.0 * at this exposure
. . .
```

Users must also be aware that CASMO can only expand data on a restart file from octant to quarter symmetry or from half to full symmetry. This is true of all CASMO applications, not just the MxN option. Since the MxN option can only accommodate half and full symmetry, all restart files must be generated using at least half symmetry during the single segment depletion analysis. This is irrelevant for BWR applications, but it is important to note for PWR applications, where single segment analyses are typically performed on only an octant of the problem. Therefore it is recommended to run single assembly cases in full geometry if the restart file is to be used in an MxN calculation.

Users should also exercise caution when defining global parameters immediately following the BAS card and prior to the first SEG card (this also applies to the 2x2 option). Any input cards present between the BAS and the first SEG card will overwrite the corresponding data from the restart file. To this end, it is sometimes safer to simply define each segment under its own SEG

card, even though this method may be somewhat more cumbersome to implement than defining global values for all segments under the BAS card.

3.7 Boron Letdown During MxN Depletion

Boron letdown during an MxN depletion maybe accomplished through use of a PVD card inserted in the BAS part of the input. The other PVD parameters are available as well, e.g., TFU, TMO, etc. PVD parameters are interpreted in terms of cycle exposure for an MxN calculation.

3.8 Axis Spanning Assemblies

Specially developed for modeling PWR 1/4 cores is the capability to model half assemblies on the north and west major axes ("axis spanning assemblies"). This modeling is applied to both axes simultaneously and hence this capability is limited to 1/4 core (not available for 1/2 core). In the following diagram representing the lower right hand quadrant of a 7x7 core the axis spanning assemblies are shaded. One caveat when using the axis spanning assembly option is that if an axis spanning assembly has an odd number of pin, then **all axis spanning assemblies must have the same number of pins**.

Fig. 3.3 MxN Axis Spanning Assemblies

| | | | |
|----|----|----|----|
| 13 | 14 | 15 | 16 |
| 9 | 10 | 11 | 12 |
| 5 | 6 | 7 | 8 |
| 1 | 2 | 3 | 4 |

0

3.9 MxN Shuffle Capability

It is possible to save CASMO restart files from one MxN calculation for use in a subsequent MxN calculation. If a WRI card is included in the input, e.g., WRI -100/'RES' then restart files will be generated for each segment (except for auto-generated segments). The restart files will be named: inputfile.name.seg1.res, inputfile.name.seg2.res, up to inputfile.name.segN.res. The

segments are numbered according to **position** in the background mesh with segment #1 in the lower left hand corner and proceeding across the bottom row (see Figure 1). Numbers on the SEG card are not used here since they may not be unique in the LSE map. Care must be taken that a job that is going to use the restart files generated in a previous run not overwrite the restart files being read, i.e., the input file name should be different from the run that generated the restart files (or they should be manually re-named).

When restart files are being written from an MxN case they are "marked" with the current cycle exposure and the individual assembly exposures. When reading the restart files back, there is an option on the MXN card (IBUNEXP) which determines whether the restart files are interpreted as being marked with the cycle exposure or assembly average exposure.

Any restart files that are being read, must have been generated with the exact version of CASMO that is reading them (this is true for any CASMO and not specific to CASMO-4E). Also, because CASMO has the tendency to append to previously existing restart files (even if partially written), if an MxN case which writes restart files is prematurely terminated, then the user should make sure to remove any partially written restart files before starting the job again. Otherwise, the job will append to the partially written restart files and this will cause CASMO trouble later when it tries to read these restarts in another job, e.g. shuffle to next cycle.

No MxN data is written to CASMO restart files, so that the entire MxN input section must be present for any cases using restart files. Furthermore, if a fresh fuel segment is being introduced, then it must contain all the data needed for its description, this includes quantities that might typically appear under the BAS segment, in other words the fresh fuel segment is not going to pick up any of that data from the restart files --the segment must stand on its own.

When performing an MxN depletion, the DEP card is in terms of cycle exposure and not core average exposure.

Saving CASMO restart files from a 1/4 core or full core depletion represents a significant amount of information and adequate disk space must be available.

Examples provided later in this document demonstrate a 1/4 core PWR base depletion and a shuffle.

3.10 B.P. Shuffle Model

The CASMO-4E MxN model has the capability to shuffle B.P.'s via the use of CASMO-4E restart files. This includes the ability to shuffle depleted B.P.'s into depleted or fresh assemblies (in addition to the simple requirement of pulling the B.P.

3.11 Shutdown Cooling Calculation

To model long outages or intervals between cycles, the code has the capability to accept a map of shutdown cooling times (in delta days or hours) in the MxN section of the input. The code

will perform an initialization statepoint (limited to 1 iteration) and then performs the shutdown cooling statepoint using a PDE of 1.0E-6, and then proceeds with any normal full power depletion.

3.12 Baffle/Barrel/Pad Automation

The BAF card will relieve the user from having to manually generate baffle/reflector segments around the edge of the problem (and any rotations of said baffle segments). The SSA correction can also be turned ON/OFF for all baffle segments via this card.

If the code is to auto-generate the baffle segments the LSE map must still provide segments (zeroes) for the baffle segments. Zeroes next to fuel will be a baffle segment, zeroes out away from the core will be standard auto-generated reflector segments. A full core LSE map might look like:

```
LSE
0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0
0 0 0 0 0 0 6 7 6 7 6 7 6 0 0 0 0 0
0 0 0 6 6 6 9 2 10 1 10 2 9 6 6 0 0 0
0 0 6 8 5 2 4 2 5 2 4 2 5 8 6 0 0 0
0 0 6 5 1 4 2 3 1 3 2 4 1 5 6 0 0 0
0 6 9 2 4 4 4 2 4 2 4 4 4 2 9 6 0 0
0 7 2 4 2 4 1 4 2 4 1 4 2 4 2 7 0 0
0 6 10 2 3 2 4 2 4 2 4 2 3 2 10 6 0 0
0 7 1 5 1 4 2 4 1 4 2 4 1 5 1 7 0 0
0 6 10 2 3 2 4 2 4 2 4 2 3 2 10 6 0 0
0 7 2 4 2 4 1 4 2 4 1 4 2 4 2 7 0 0
0 6 9 2 4 4 4 2 4 2 4 4 4 2 9 6 0 0
0 0 6 5 1 4 2 3 1 3 2 4 1 5 6 0 0 0
0 0 6 8 5 2 4 2 5 2 4 2 5 8 6 0 0 0
0 0 0 6 6 9 2 10 1 10 2 9 6 6 0 0 0
0 0 0 0 0 6 7 6 7 6 7 6 0 0 0 0 0 0
0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 / 17 17
```

A typical auto-generated baffle segment will look something like:

```
SEG 49 *SEGMENT TYPE: 0 POSITION (LSE) (X,Y) : (15 3)
PWR 17 1.26000 0.00000 0.00000 0.00000 0.00000 0.00000 1 1
FUE 1 0.01/0.1
PIN 1 .4 /'MOD'
PIN 2 .4 .41 .42 .43/'MOD' '1' 'CAN' 'COO' 'MOD'
PIN 3 0.5 /'CRS' 'CRS'
LPI
3 3 3 3 3 3 3 3 3 3 3 3 3 3 3 3
3 3 3 3 3 3 3 3 3 3 3 3 3 3 3 3
3 3 1 1 1 1 1 1 1 1 1 1 1 1 1 1
3 3 1 1 1 1 1 1 1 1 1 1 1 1 1 1
3 3 1 1 1 1 1 1 1 1 1 1 1 1 1 1
3 3 1 1 1 1 1 1 1 1 1 1 1 1 1 1
3 3 1 1 1 1 1 1 1 1 1 1 1 1 1 1
3 3 1 1 1 1 1 1 1 1 1 1 1 1 1 1
3 3 1 1 1 1 1 1 1 1 1 1 1 1 1 1
3 3 1 1 1 1 1 1 1 1 1 1 1 1 1 1
3 3 1 1 1 1 1 1 1 1 1 1 1 1 1 1
3 3 1 1 1 1 1 1 1 1 1 1 1 1 1 1
3 3 1 1 1 1 1 1 1 1 1 1 1 1 1 1
3 3 1 1 1 1 1 1 1 1 1 1 1 1 1 1
3 3 1 1 1 1 1 1 1 1 1 1 1 1 1 1
3 3 1 1 1 1 1 1 1 1 1 1 1 1 1 1
3 3 1 1 1 1 1 1 1 1 1 1 1 1 1 1
3 3 1 1 1 1 1 1 1 1 1 1 1 1 1 1
3 3 1 1 1 1 1 1 1 1 1 1 1 1 1 1
3 3 1 1 1 1 1 1 1 1 1 1 1 1 1 1
```

In this case there is baffle along the left side and the top of the segment. The code can generate up to 12 different appropriate baffle segments (top only, bottom only, left only, right only, left and top, left and bottom, right and top, right and bottom, notch NW corner, notch NE corner, notch SE corner, notch SW corner). The code will build the baffle segment with correct number of pins and pin pitch and uses a baffle three pins thick.

The barrel model simply takes the inner and outer radius of the core barrel and then sweeps through the position of all the pins outside the core. If the center of the pin is between the inner and outer radius of the barrel, that pin will be converted to barrel material. This will make a “ragged” model of the barrel on the pin level, but it should be sufficiently accurate for the application. The pad model is constructed similarly. This model can also be used to model BWR ex-core regions.

3.13 MxN Output Edits

Any parameter which can be edited for single segment applications is also available for editing during an MxN calculation. However, users should be aware that most information is edited on a single segment basis. For instance, the magnitude of the flux distribution gets normalized on a per segment basis, rather than on a global basis. To this end, it is sometimes difficult to directly compare edits from one segment against similar edits from other segments because the normalization factor may be different for each segment. However, this does provide the advantage of making comparisons to single assembly calculations much easier. Specifically for MxN calculations, there are some wrap-up edits printed at the conclusion of the calculation which are designed for easy comparison to SIMULATE-3, e.g., 2EXP, 2RPF etc. In order to reduce the size of the output, by default only minimal assembly oriented data is edited during an MxN calculation, however there is a flag on the MXN card to produce more detailed data for each assembly if that level of detail is desired.

3.14 MxN SUMMARY File

A machine readable summary file summarizing the results is produced if a SUM card is present. The file is roughly structured into various blocks which start with STA, and terminate with END. This structure makes it easy to write post-processing programs to extract data from this file.

A typical file MxN summary might look like:

```
CASMO-4E MxN Summary File
-----
Executable file       : \rhodesii\C4QAF\c4.exe
Neutron data library  : /CMSNT/CasLib/library/e41b170
CASMO-4E version      : 2.10.00
CASMO-4E creation date : 01/06/12
Execution date (start) : 01/06/19
Execution time (start) : 19:48:18
CPU Time (seconds)    : 254.1
Case Title            : MxN PWR depletion Test Case with 2 mox assemblies
Statepoints           : 1
END=====

STA MXN INPUT SUMMARY=====
MxN Input maps
END INPUT=====

STA STATEPOINT SUMMARY=====

Various Scalar Statepoint results
VOID   TFU   TMO   BOR   CORE AVE.   CYCLE   K-INF
(%)    (K)   (K)   (PPM)  (MWD/KG)  (MWD/KG)
```



```

-----
1 0.0 840.0 560.0 0.0 0.000 0.000 1.27157
END CORE STATEPOINT SUMMARY=====

STA CORE MAPS=====
CORE MAPS STATEPOINT: 1-----

STA STATEPOINT SUMMARY=====
VOID   TFU   TMO   BOR   CORE AVE.   CYCLE   K-INF
(%)    (K)   (K)   (PPM)  (MWD/KG)  (MWD/KG)
-----
1 0.0 840.0 560.0 0.0 0.000 0.000 1.27157
END CORE STATEPOINT SUMMARY=====
STA CORE MAPS=====

CORE MAPS STATEPOINT: 1-----

STA
SUMMARY=====
SEG SP VOID TFU TMO TCO BOR ROD BURNUP K-INF K-INF M2 PIN U-235 FISS PU TOT PU MAC KRM CYC.
MWD/KG TWO-GROUP PEAK WT % WT % WT % ITS ITS EXP.
-----
9 1 0.0 840.0 560.0 560.0 0.0 0.000 1.36634 1.36471 53.32 1.427 3.500 0.000 0.000 0 7 0.000
10 1 0.0 840.0 560.0 560.0 0.0 0.000 1.37147 1.36481 53.30 1.576 3.500 0.000 0.000 0 7 0.000
11 1 0.0 840.0 560.0 560.0 0.0 0.000 1.36808 1.36469 53.16 1.781 3.500 0.000 0.000 0 7 0.000
17 1 0.0 840.0 560.0 560.0 0.0 0.000 1.37520 1.36489 53.40 1.226 3.500 0.000 0.000 0 7 0.000
-----

END SEGMENT SUMMARY=====
STA SEGMENT 9 9
DETAIL=====
Detailed pinxpin data by segment and statepoint
SEGMENT 9 XS BLOCK Pos:001,002 Statepoints: 1
Cyc. Exp. Bun. Exp. D1 D2 SIGR SIGA1 SIGA2 SIGNUF1 SIGNUF2 KAPPA/NU
1 0.000 0.000 1.356571 0.325580 0.017311 0.009918 0.088172 0.007600 0.150556 1.326070E-11/
-----
SEGMENT 9 ADF BLOCK POS:001,002 Statepoint: 1 Cyc. Exp: 0.000 Bun. Exp: 0.000
ADFS, 2 Group XS, Surface Fluxes,
Maps of PinxPin power distribution
Maps of PinxPin exposures

END SEGMENT 9
DETAIL=====
STA SEGMENT 10 10
DETAIL=====
SEGMENT 10 XS BLOCK Pos:002,002 Statepoints: 1
Cyc. Exp. Bun. Exp. D1 D2 SIGR SIGA1 SIGA2 SIGNUF1 SIGNUF2 KAPPA/NU
1 0.000 0.000 1.356583 0.325698 0.017315 0.009924 0.088291 0.007606 0.150783 1.326312E-11/
-----

```

Although the file is ASCII, it does not represent a lot of data (about 1.2 megabytes per statepoint for a full core PWR MxN calculation) and file size should not be a problem.

3.15 Maximum MxN Problem Size and Resources

CASMO-4E as delivered is dimensioned to handle a maximum MxN problem size of 20x20 assemblies. To run problems larger than 20x20, the parameter NBUNM needs to be increased and the code recompiled. It should be noted that to run a 17x17 problem in diagonal symmetry requires roughly 1 gigabyte of RAM and approximately 1.5 gigabytes of free disk space. Memory use will of course increase if the number of angles (polar and azimuthal), mesh and/or number of energy groups is greater than default. The **MEM** card which controls the CASMO-4E dynamic memory is required for most MxN applications.

When running large MxN problems it is recommended that the Fortran scratch files (temporary files generated by the job) be placed in the working directory instead of in /tmp (since if /tmp is memory mapped, then the files will compete with the job for system memory). If the /tmp directory is memory mapped, and files are not directed to the working directory, then the machine must have enough memory (RAM) for both the scratch files and the memory required

to run job (typically a combined total of around 2 gigabytes for a 1/4 core calculation). See -T option of the cas4 script.

For very large MxN problems (> 2 gigabytes) executables must be compiled in 64-bit mode.

4 Fuel Storage Rack

| Sec. | Title | Page |
|-------------|---------------------------------------------|-------------|
| 4.1 | General Description of FSS/FSC Capability | 3 |
| 4.2 | Special Features of the FSS/FSC Calculation | 3 |

| Fig. | Title | Page |
|-------------|---------------------------------|-------------|
| Fig. 4.1 | Example FSS/FSC fuel rack model | 4 |

This section describes the generalized fuel storage rack capability of CASMO-4E.

4.1 General Description of FSS/FSC Capability

Previous versions of CASMO-3, CASMO-4 and CASMO-4E have included a rudimentary fuel storage rack calculation via the FST card. However, the FST capability is limited in its ability to model modern more complicated rack geometries. The old FST calculation is limited to 16 regions (2 slabs per side and 2 regions in each corner). To extend the capability of CASMO-4E to more general rack geometries, the FSS/FSC fuel storage rack model has been implemented.

The new model allows up to 10 slabs of arbitrary thickness on each side of the segment, each of which may be sub-divided into up to 40 arbitrary lengths and unique compositions. The model is implemented through two new CASMO-4E input cards: FSS (Fuel Storage Side) and FSC (Fuel Storage Corner).

The **FSS card** describes a single "side" of the rack in terms of slabs of various thicknesses, lengths and compositions. These lengths must all sum to the width of the segment (out to, and including the outer gaps). By projecting the slab dimensions out into a corner, the discretization of the corner regions (intersection of two sides) is automatically defined by the intersection of the slabs. The user then simply uses the **FSC card** to specify the compositions of these corner regions. This provides quite a bit more flexibility in terms of geometry than the old FST calculation.

Racks are frequently symmetric. Therefore, the input allows the same FSS/FSC cards to be used for all four sides. However, by providing multiple FSS/FSC cards each side/corner is allowed to be unique.

4.2 Special Features of the FSS/FSC Calculation

The FSS/FSC fuel storage rack model is intended to produce a "high-fidelity" transport solution. The calculation is performed in 40 energy groups (which helps model high energy leakage). The macro-group calculation is not performed, thermal expansion is OFF and the fundamental mode calculation is omitted.

As FSS/FSC cases can be of many different sizes (some small, most large), most FSS/FSC calculations will require the **MEM** (Memory) card to be given as the first card of the input (for example, MEM 50 10). For further discussion of the MEM card see the base CASMO-4 manual.


The FSS/FSC model is supported for MxN applications for clients who have the optional MxN (multi-segment) capability.

The user is also recommended to use the **PSC** (color graphic of geometry) card to 'verify' the geometry of the model.

The FSC/FSS model is only supported in full geometry (ISYM=1).

The figure below is an example of a fuel storage racked modeled with FSS/FSC. Note that what looks like a boxwall (the black regions) around the assembly is actually an FSS slab. This is notables since some old FST models actually used boxwall and slab CRD's to model "extra" FST regions. This type of "trick" is no longer necessary with the FSS/FSC fuel storage rack model.

Fig. 4.1 Example FSS/FSC fuel rack model



5 Hexagonal Model Description

| Sec. | Title | Page |
|------|---------------------------------------------|------|
| 5.1 | General Description of Hexagonal Capability | 3 |

This section describes the hexagonal capability of CASMO-4E for analyzing VVER-440 and VVER-1000 type reactors.

5.1 General Description of Hexagonal Capability

CASMO is a multigroup two-dimensional transport theory code for burnup calculations on BWR and PWR assemblies. The HEX option allows CASMO to extend its application to assembly designs of the Russian VVER-440 and VVER-1000 type.

Features of the CASMO hexagonal option are:

- The two-dimensional transport calculation is performed in the heterogeneous geometry using the Method of Characteristics (MOC).
- Gd depletion and other absorber depletions are done automatically within CASMO without the need for auxiliary codes.
- Multi-depletion and coefficient capability for easy generation of complete nuclear data for advanced nodal codes in one execution.

Some programming limitations to the CASMO hexagonal option exist and include:

- Inability to move pins around in the cell, i.e., pins must be centered.
- Colorset (2x2) and MxN is not available for hexagonal geometry.
- Size of the outer water gaps are limited by the pin pitch.
- Inability to model pins which occupy more than one pin cell location.
- Equivalent one-dimensional annular geometry for generating data associated with the absorber control cell of a VVER-440.

The flow of the hexagonal calculation is identical to the program flow for standard CASMO with the exception that no macrogroup calculation is performed.

6 Pn-Scattering Model Description

| Sec. | Title | Page |
|------|-------------------------------------------------|------|
| 6.1 | General Description of Pn-Scattering Capability | 3 |

This section describes the Pn-scattering capability of CASMO-4E.

6.1 General Description of Pn-Scattering Capability

Anisotropic scattering of neutrons in CASMO-4E is normally handled by using a special transport corrected total scattering cross section. This works quite well for single assembly problems (such as those typically run for cross section generation for use in a 3D nodal code), where the flux is relatively isotropic, but for larger problems, e.g., multi-assembly MxN, critical experiments, reflector calculations, or any other problem where neutron leakage is high, the use of a transport corrected scattering cross section may not give sufficiently accurate results. By implementing a higher order scattering model in CASMO-4E one can achieve several goals:

1. It is possible to use a more accurate method directly to calculate neutronic parameters.
2. It is possible to extend the range of problems to which CASMO-4E may be applied, e.g., deep penetration problems.
3. It is possible to estimate the error that is introduced by using transport corrected cross sections.

A theoretically attractive calculational scheme to model anisotropic scattering is to expand the scattering cross sections into a more general sum of Legendre polynomials than that used for the calculation of normal transport corrected scattering cross sections (where only orders of 0 and 1 are used) and extend the method to higher orders, e.g., 2, 3, 4, etc., to form the basis of the "Pn-Scattering model":

$$\sigma_{s, tot}^{x, (E' \rightarrow E, \Omega' \rightarrow \Omega)} = \sum_{l=0}^{\infty} \frac{(2l+1)}{4\pi} \cdot \sigma_{s, tot, l}^{(x, E' \rightarrow E)} \cdot P_l(\mu_0)$$

where x is the spatial position, E' , Ω' and E , Ω are the energy and angular direction of the neutron before and after the scattering process, $\mu_0 = \cos$ of the scattering angle, and the P_l 's are the Legendre polynomials of order l .

The SSP E6 advanced data library contains anisotropic scattering data (matrices) for the following 20 idents: (H in H₂O), O, Al, Si, Cr, Mn, Fe, Ni, Zr, Nb, U-235, U-238, Pu-239, Zirc-2, Zirc-4, ZIRLO, Stainless Steel, Inconel-718, Inconel-750 with Pn data available up to order 7 for most of the idents (the heavy isotopes have data only up to order 5). These idents cover most of the important contributors to higher order scattering.

The higher order anisotropic scattering (Pn-model) has been implemented in CASMO-4E uses the Method of Characteristics to solve the 2D Boltzmann transport equation.

This new transport solver uses a unified quadrature (same ray-spacing and number of azimuthal angles and polar angles for all energy groups). However, there are some limitations to the Pn-scattering model as implemented in CASMO-4E:

1. The Pn-scattering model is only implemented in **full geometry** in CASMO-4E.
2. The maximum Legendre order is available is order=7 (this is the current maximum on the neutron data library).
3. A Pn-scattering calculation is a computationally intensive calculation and CPU time and total memory use will be increased when using the Pn-scattering model.
4. Large Pn-scattering problems may require a 64-bit executable.

7 ENDF/B-VI Neutron Data Library

| Section | Title | Page |
|---------|--------------------------------|------|
| 7.1 | ENDF-B/VI Overview | 3 |
| 7.2 | Heavy Nuclide Chains in E6 | 30 |
| 7.3 | Fission Product Chains in E6 | 33 |
| 7.4 | Burnable Absorber Chains in E6 | 42 |

| Table | Title | Page |
|-----------|--------------------------------------------|------|
| Table 7.1 | Group Boundaries for the ENDF/B-VI Library | 5 |
| Table 7.2 | Nuclides for the ENDF/B-VI Library | 7 |
| Table 7.3 | Edited Fission Products | 19 |
| Table 7.4 | Lumped Fission Product Nuclides ID=401 | 19 |
| Table 7.5 | Lumped Fission Product Nuclides ID=402 | 19 |
| Table 7.6 | Lumped Fission Product Nuclides ID=403 | 20 |
| Table 7.7 | Temperatures for the ENDF/B-VI Library | 21 |

| Figure | Title | Page |
|-----------|-------------------------------------------|------|
| Fig. 7.1 | E6 Heavy Nuclides: Lower Part (to Am-244) | 31 |
| Fig. 7.2 | E6 Heavy Nuclides: Upper Part (to Cf-252) | 32 |
| Fig. 7.3 | E6 Fission Products Mass Numbers 76-87 | 34 |
| Fig. 7.4 | E6 Fission Products Mass Numbers 88-100 | 35 |
| Fig. 7.5 | E6 Fission Products Mass Numbers 100-110 | 36 |
| Fig. 7.6 | E6 Fission Products Mass Numbers 110-121 | 37 |
| Fig. 7.7 | E6 Fission Products Mass Numbers 122-132 | 38 |
| Fig. 7.8 | E6 Fission Products Mass Numbers 133-144 | 39 |
| Fig. 7.9 | E6 Fission Products Mass Numbers 142-151 | 40 |
| Fig. 7.10 | E6 Fission Products Mass Numbers 152-160 | 41 |
| Fig. 7.11 | E6 Burnable Absorbers: Ag, Cd, In | 42 |
| Fig. 7.12 | E6 Burnable Absorbers: Gd, Er, Hf | 43 |

This section describes the ENDF/B-VI neutron data library for CASMO-4E. The following description is applicable for the E60200 data library.

7.1 ENDF-B/VI Overview

A data library based on the evaluated data file ENDF/B-VI has been processed for CASMO-4 and CASMO-4E. The E6LIB data library is based on data from ENDF/B-VI, the evaluated neutron data file developed at the Brookhaven National Nuclear Data Center. In the following, the notation "E6" denotes the ENDF/B-VI library.

The library contains cross sections, decay constants and fission yields for 337 materials, most of which are individual nuclides. Some materials are elements with natural isotopic composition, and cross sections for these were obtained by adding cross sections for the constituent nuclides according to their natural abundance. Other materials, such as construction materials, are mixtures of elements. Cross sections for these materials are obtained by adding the cross sections of the constituent elements, according to the composition of the material.

The program NJOY-94.105, originally from Los Alamos, but with Studsvik Scandpower modifications, was used to generate the library into the CASMO format. Other Studsvik Scandpower programs were then used to calculate cross sections for complex materials, and to extract and handle decay constants and fission yields.

Microscopic cross sections are tabulated in 70 energy groups. The energy group structure is shown in Table 7.1 and is the same as the standard 70 group, SSP L-library. This group structure fulfills the following requirements:

- The 14 fast groups give enough detail in the fast energy region to calculate the leakage and fast fission accurately.
- The 13 resonance groups (down to 4.0 eV) provide correct flux levels as a function of energy for the calculation of resonance absorption. Some nuclides have "extended" resonance data down to 0.625 eV (an additional 19 groups for 32 total resonance groups).
- The 43 thermal groups (below 4 eV, which is the cut off for up-scattering) make the thermal cross sections independent of the weighting spectrum used for their generation. Groups are concentrated around the 0.3 eV resonance in Pu-239 and the 1 eV resonance in Pu-240.

The E6 library contains absorption, fission, nu*fission, transport and scattering cross sections. Data are tabulated as functions of temperature when needed. Shielded resonance integrals versus effective potential background cross section and temperature are tabulated for resonance absorbers.

The E6 library further contains decay constants for fission products and heavy nuclides, and fission product yield values. The structure of the fission product representation determines whether independent or cumulative yield shall be used for each fission product. The selected structure and yield values give yield sums for each fission precursor very close to 2.0.

Nuclides are identified by a five digit (or less) **ID**, which in general is chosen such that the **first digit(s) are equal to the atomic number of the nuclide and the last three digits show the isotope number**. Three zeros (000) are used in the place of the isotope number for elements of natural composition. Nuclides, elements, compositions and artificial nuclides are identified by the ID numbers as shown in Table 7.2. In some instances the reader is referred to special comments following the table. The temperatures at which each ID is evaluated are given in Table 7.7.

Table 7.1 Group Boundaries for the ENDF/B-VI Library

| Group | Upper energy boundary | Energy Width | Lethargy Width |
|--------------|--------------------------------------|-------------------------|---------------------------|
| 1 | 10.0 MeV | 3.9345 MeV | 0.49997 |
| 2 | 6.0655 | 2.3865 | 0.49998 |
| 3 | 3.679 | 1.448 | 0.50019 |
| 4 | 2.231 | 0.878 | 0.50013 |
| 5 | 1.353 | 0.532 | 0.49956 |
| 6 | 0.821 | 0.321 | 0.49592 |
| 7 | 0.500 | 0.1975 | 0.50253 |
| 8 | 0.3025 | 0.1195 | 0.50260 |
| 9 | 0.183 | 0.072 | 0.49996 |
| 10 | 0.1110 | 0.04366 | 0.49978 |
| 11 | 0.06734 | 0.02649 | 0.49985 |
| 12 | 0.04085 | 0.01607 | 0.49987 |
| 13 | 0.02478 | 0.00975 | 0.49999 |
| 14 | 0.01503 | 0.005912 | 0.49980 |
| 15 | 9118.0 eV | 3588.0 eV | 0.50006 |
| 16 | 5530.0 | 2010.9 | 0.45198 |
| 17 | 3519.1 | 1279.65 | 0.45198 |
| 18 | 2239.45 | 814.35 | 0.45199 |
| 19 | 1425.1 | 518.202 | 0.45197 |
| 20 | 906.898 | 539.636 | 0.90395 |
| 21 | 367.262 | 218.534 | 0.90396 |
| 22 | 148.728 | 73.2266 | 0.67797 |
| 23 | 75.5014 | 27.4494 | 0.45187 |
| 24 | 48.052 | 20.352 | 0.55085 |
| 25 | 27.700 | 11.732 | 0.55085 |
| 26 | 15.968 | 6.091 | 0.48038 |
| 27 | 9.877 | 5.877 | 0.90391 |
| 28 | 4.00 | 0.700 | 0.19237 |
| 29 | 3.30 | 0.700 | 0.23841 |
| 30 | 2.60 | 0.500 | 0.21357 |
| 31 | 2.10 | 0.245 | 0.12405 |
| 32 | 1.855 | 0.355 | 0.21242 |
| 33 | 1.50 | 0.200 | 0.14310 |
| 34 | 1.30 | 0.150 | 0.12260 |
| 35 | 1.150 | 0.027 | 0.02376 |
| 36 | 1.123 | 0.026 | 0.02342 |
| 37 | 1.097 | 0.026 | 0.02399 |

Table 7.1 Group Boundaries for the ENDF/B-VI Library

| Group | Upper energy boundary | Energy Width | Lethargy Width |
|--------------|--------------------------------------|-------------------------|---------------------------|
| 38 | 1.071 | 0.026 | 0.02458 |
| 39 | 1.045 | 0.025 | 0.02421 |
| 40 | 1.020 | 0.024 | 0.02381 |
| 41 | 0.996 | 0.024 | 0.02439 |
| 42 | 0.972 | 0.022 | 0.02289 |
| 43 | 0.950 | 0.040 | 0.04302 |
| 44 | 0.910 | 0.060 | 0.06821 |
| 45 | 0.850 | 0.070 | 0.08594 |
| 46 | 0.780 | 0.155 | 0.22154 |
| 47 | 0.625 | 0.125 | 0.22314 |
| 48 | 0.500 | 0.100 | 0.22314 |
| 49 | 0.400 | 0.050 | 0.13353 |
| 50 | 0.350 | 0.030 | 0.08961 |
| 51 | 0.320 | 0.020 | 0.06454 |
| 52 | 0.300 | 0.020 | 0.06899 |
| 53 | 0.280 | 0.030 | 0.11333 |
| 54 | 0.250 | 0.030 | 0.12783 |
| 55 | 0.220 | 0.040 | 0.20067 |
| 56 | 0.180 | 0.040 | 0.25131 |
| 57 | 0.140 | 0.040 | 0.33647 |
| 58 | 0.100 | 0.020 | 0.22314 |
| 59 | 0.080 | 0.013 | 0.17733 |
| 60 | 0.067 | 0.009 | 0.14425 |
| 61 | 0.058 | 0.008 | 0.14842 |
| 62 | 0.050 | 0.008 | 0.17435 |
| 63 | 0.042 | 0.007 | 0.18232 |
| 64 | 0.035 | 0.005 | 0.15415 |
| 65 | 0.030 | 0.005 | 0.18232 |
| 66 | 0.025 | 0.005 | 0.22314 |
| 67 | 0.020 | 0.005 | 0.28768 |
| 68 | 0.015 | 0.005 | 0.40547 |
| 69 | 0.010 | 0.005 | 0.69315 |
| 70 | 0.005 | 0.005 | |

Shading indicates the resonance groups (lighter shading indicates the extended resonance groups).

Table 7.2 Nuclides for the ENDF/B-VI Library

| ID | Description | Reson. Data | XS Model | # Temps | Pn Data | File 5 Data | Com- ment |
|-----------|--------------------|------------------------|-----------------|--------------------|--------------------|------------------------|----------------------|
| 1 | 1/v absorber | No | Absorption only | 1 | No | No | 4 |
| 2 | Unit absorber | No | Absorption only | 1 | No | No | 4 |
| 3 | Unit scatterer | No | Full set | 1 | No | No | 4 |
| 302 | Zircaloy-2 | No | Full set | 4 | Yes | No | 3 |
| 304 | Zircaloy-4 | No | Full set | 4 | Yes | No | 3 |
| 306 | Nb-added Zy-4 | No | Full set | 4 | Yes | No | 3 |
| 347 | Stainless steel | No | Full set | 2 | Yes | No | 2 |
| 718 | Inconel-718 | No | Full set | 2 | Yes | No | 2 |
| 750 | Inconel-750 | No | Full set | 2 | Yes | No | 2 |
| 1001 | H | No | Full set | 6 | Yes | No | |
| 1002 | D | No | Full set | 5 | No | No | |
| 1107 | H in ZrH | No | Full set | 6 | No | No | 10 |
| 2003 | He-3 | No | Full set | 1 | No | No | |
| 3000 | Li | No | Full set | 1 | No | No | |
| 4000 | Be-9 | No | Full set | 2 | No | No | |
| 5000 | B | No | Full set | 2 | No | Yes | 1 |
| 5010 | B-10 | No | Full set | 2 | No | Yes | 1 |
| 5011 | B-11 | No | Full set | 2 | No | No | 1 |
| 6000 | C | No | Full set | 4 | No | No | |
| 6001 | Graphite | No | Full set | 6 | No | No | |
| 7000 | N | No | Full set | 1 | No | No | |
| 8000 | O | No | Full set | 8 | Yes | No | |
| 9000 | F | No | Full set | 1 | No | No | |
| 11000 | Na | No | Full set | 1 | No | No | |
| 12000 | Mg | No | Full set | 2 | No | No | |
| 13000 | Al | No | Full set | 2 | Yes | No | |
| 14000 | Si | No | Full set | 2 | Yes | No | |
| 15000 | P | No | Full set | 1 | No | No | |
| 16000 | S | No | Full set | 1 | No | No | |
| 17000 | Cl | No | Full set | 1 | No | No | 10 |
| 19000 | K | No | Full set | 1 | No | No | |
| 20000 | Ca | No | Full set | 1 | No | No | |
| 23000 | V | No | Absorption only | 2 | No | No | |
| 24000 | Cr | No | Full set | 2 | Yes | No | |
| 25000 | Mn | No | Full set | 2 | Yes | No | |
| 26000 | Fe | No | Full set | 2 | Yes | No | |
| 26054 | Fe-54 | No | Full set | 4 | No | Yes | |

Table 7.2 Nuclides for the ENDF/B-VI Library

| ID | Description | Reson. Data | XS Model | # Temps | Pn Data | File 5 Data | Com- ment |
|-----------|--------------------|------------------------|------------------|--------------------|--------------------|------------------------|----------------------|
| 26055 | Fe-55 | No | Yield/Decay only | 1 | No | Yes | 7 |
| 27059 | Co-59 | No | Full set | 1 | No | No | |
| 28000 | Ni | No | Full set | 2 | Yes | No | |
| 28058 | Ni-58 | No | Full set | 2 | No | No | |
| 28062 | Ni-62 | No | Full set | 2 | No | No | |
| 29000 | Cu | No | Full set | 1 | No | No | |
| 29063 | Cu-63 | No | Absorption only | 1 | No | No | |
| 30064 | Zn-64 | No | Absorption only | 1 | No | No | |
| 31000 | Ga | No | Full set | 2 | No | No | |
| 32000 | Ge | No | Absorption only | 1 | No | No | |
| 32076 | Ge-76 | No | Absorption only | 1 | No | Yes | |
| 32077 | Ge-77 | No | Yield/Decay only | 1 | No | Yes | 7 |
| 33000 | As | No | Absorption only | 1 | No | No | |
| 33077 | As-77 | No | Yield/Decay only | 1 | No | Yes | 7 |
| 34000 | Se | No | Absorption only | 1 | No | No | |
| 34077 | Se-77 | No | Absorption only | 1 | No | Yes | |
| 34078 | Se-78 | No | Absorption only | 1 | No | Yes | |
| 34079 | Se-79 | No | Yield/Decay only | 1 | No | Yes | 7 |
| 34080 | Se-80 | No | Absorption only | 1 | No | Yes | |
| 34081 | Se-81 | No | Yield/Decay only | 1 | No | Yes | 7 |
| 34082 | Se-82 | No | Absorption only | 1 | No | Yes | |
| 34083 | Se-83 | No | Yield/Decay only | 1 | No | Yes | 7 |
| 35081 | Br-81 | No | Absorption only | 1 | No | Yes | |
| 35082 | Br-82 | No | Yield/Decay only | 1 | No | Yes | 7 |
| 35083 | Br-83 | No | Yield/Decay only | 1 | No | Yes | 7 |
| 36082 | Kr-82 | No | Absorption only | 1 | No | Yes | |
| 36083 | Kr-83 | No | Absorption only | 4 | No | Yes | |
| 36084 | Kr-84 | No | Absorption only | 1 | No | Yes | |
| 36085 | Kr-85 | No | Absorption only | 1 | No | Yes | |
| 36086 | Kr-86 | No | Absorption only | 1 | No | Yes | |
| 36087 | Kr-87 | No | Yield/Decay only | 1 | No | Yes | 7 |
| 36985 | Kr-85m | No | Yield/Decay only | 1 | No | Yes | 7 |
| 37085 | Rb-85 | No | Absorption only | 1 | No | Yes | |
| 37087 | Rb-87 | No | Absorption only | 1 | No | Yes | |
| 38088 | Sr-88 | No | Absorption only | 1 | No | Yes | |
| 38089 | Sr-89 | No | Absorption only | 1 | No | Yes | |
| 38090 | Sr-90 | No | Absorption only | 1 | No | Yes | |
| 38091 | Sr-91 | No | Yield/Decay only | 1 | No | Yes | 7 |
| 39089 | Y-89 | No | Absorption only | 1 | No | Yes | |

Table 7.2 Nuclides for the ENDF/B-VI Library

| ID | Description | Reson. Data | XS Model | # Temps | Pn Data | File 5 Data | Com- ment |
|-----------|--------------------|------------------------|------------------|--------------------|--------------------|------------------------|----------------------|
| 39090 | Y-90 | No | Absorption only | 1 | No | Yes | |
| 39091 | Y-91 | No | Absorption only | 1 | No | Yes | |
| 40000 | Zr | No | Full set | 4 | Yes | No | |
| 40090 | Zr-90 | No | Absorption only | 1 | No | Yes | |
| 40091 | Zr-91 | No | Absorption only | 1 | No | Yes | |
| 40092 | Zr-92 | No | Absorption only | 1 | No | Yes | |
| 40093 | Zr-93 | No | Absorption only | 1 | No | Yes | |
| 40094 | Zr-94 | No | Absorption only | 1 | No | Yes | |
| 40095 | Zr-95 | No | Absorption only | 1 | No | Yes | |
| 40096 | Zr-96 | No | Absorption only | 1 | No | Yes | |
| 40097 | Zr-97 | No | Yield/Decay only | 1 | No | Yes | 7 |
| 40158 | Zr in ZrH | No | Full set | 4 | No | No | 10 |
| 41000 | Nb | No | Full set | 2 | Yes | No | |
| 41095 | Nb-95 | No | Absorption only | 1 | No | Yes | |
| 41096 | Nb-96 | No | Yield/Decay only | 1 | No | Yes | 7 |
| 41097 | Nb-97 | No | Yield/Decay only | 1 | No | Yes | 7 |
| 42000 | Mo | No | Absorption only | 1 | No | No | |
| 42095 | Mo-95 | No | Absorption only | 1 | No | Yes | |
| 42096 | Mo-96 | No | Absorption only | 1 | No | Yes | |
| 42097 | Mo-97 | No | Absorption only | 1 | No | Yes | |
| 42098 | Mo-98 | No | Absorption only | 1 | No | Yes | |
| 42099 | Mo-99 | No | Absorption only | 1 | No | Yes | |
| 42100 | Mo-100 | No | Absorption only | 1 | No | Yes | |
| 42101 | Mo-101 | No | Yield/Decay only | 1 | No | Yes | 7 |
| 43099 | Tc-99 | No | Absorption only | 1 | No | Yes | |
| 43100 | Tc-100 | No | Yield/Decay only | 1 | No | Yes | 7 |
| 43101 | Tc-101 | No | Yield/Decay only | 1 | No | Yes | 7 |
| 44100 | Ru-100 | No | Absorption only | 1 | No | Yes | |
| 44101 | Ru-101 | No | Absorption only | 1 | No | Yes | |
| 44102 | Ru-102 | No | Absorption only | 1 | No | Yes | |
| 44103 | Ru-103 | No | Absorption only | 1 | No | Yes | |
| 44104 | Ru-104 | No | Absorption only | 1 | No | Yes | |
| 44105 | Ru-105 | No | Absorption only | 1 | No | Yes | |
| 44106 | Ru-106 | No | Absorption only | 1 | No | Yes | |
| 45103 | Rh-103 | No | Full set | 4 | No | Yes | |
| 45104 | Rh-104 | No | Yield/Decay only | 1 | No | Yes | 7 |
| 45105 | Rh-105 | No | Absorption only | 1 | No | Yes | |
| 45106 | Rh-106 | No | Yield/Decay only | 1 | No | Yes | 7 |
| 46104 | Pd-104 | No | Absorption only | 1 | No | Yes | |

Table 7.2 Nuclides for the ENDF/B-VI Library

| ID | Description | Reson. Data | XS Model | # Temps | Pn Data | File 5 Data | Com- ment |
|-----------|--------------------|------------------------|------------------|--------------------|--------------------|------------------------|----------------------|
| 46105 | Pd-105 | No | Absorption only | 1 | No | Yes | |
| 46106 | Pd-106 | No | Absorption only | 1 | No | Yes | |
| 46107 | Pd-107 | No | Absorption only | 1 | No | Yes | |
| 46108 | Pd-108 | No | Absorption only | 1 | No | Yes | |
| 46109 | Pd-109 | No | Yield/Decay only | 1 | No | Yes | 7 |
| 46110 | Pd-110 | No | Absorption only | 1 | No | Yes | |
| 46111 | Pd-111 | No | Yield/Decay only | 1 | No | Yes | 7 |
| 47000 | Ag (natural) | | | | | | 6 |
| 47107 | Ag-107 | Yes | Full Set | 4 | No | No | 5, 13 |
| 47109 | Ag-109 | Yes | Full Set | 4 | No | Yes | 5, 13 |
| 47110 | Ag-110 | No | Yield/Decay only | 1 | No | Yes | 7 |
| 47111 | Ag-111 | No | Absorption only | 1 | No | Yes | |
| 47910 | Ag-110m | No | Yield/Decay only | 1 | No | Yes | 7 |
| 48000 | Cd (natural) | | | | | | 6 |
| 48106 | Cd-106 | No | Absorption only | 1 | No | No | |
| 48108 | Cd-108 | No | Absorption only | 1 | No | No | 10 |
| 48110 | Cd-110 | No | Absorption only | 1 | No | Yes | |
| 48111 | Cd-111 | No | Absorption only | 1 | No | Yes | |
| 48112 | Cd-112 | No | Absorption only | 1 | No | Yes | |
| 48113 | Cd-113 | No | Full set | 2 | No | Yes | 10 |
| 48114 | Cd-114 | No | Absorption only | 1 | No | Yes | |
| 48115 | Cd-115 | No | Yield/Decay only | 1 | No | Yes | 7 |
| 48116 | Cd-116 | No | Absorption only | 1 | No | Yes | |
| 48117 | Cd-117 | No | Yield/Decay only | 1 | No | Yes | 7 |
| 49113 | In-113 | No | Absorption only | 2 | No | No | |
| 49115 | In-115 | Yes | Full Set | 2 | No | Yes | 5, 13 |
| 49116 | In-116 | No | Yield/Decay only | 1 | No | Yes | 7 |
| 49117 | In-117 | No | Yield/Decay only | 1 | No | Yes | 7 |
| 50000 | Sn | No | Full set | 2 | Yes | No | |
| 50116 | Sn-116 | No | Absorption only | 1 | No | Yes | |
| 50117 | Sn-117 | No | Absorption only | 1 | No | Yes | |
| 50118 | Sn-118 | No | Absorption only | 1 | No | Yes | |
| 50119 | Sn-119 | No | Absorption only | 1 | No | Yes | |
| 50120 | Sn-120 | No | Absorption only | 1 | No | Yes | |
| 50121 | Sn-121 | No | Yield/Decay only | 1 | No | Yes | 7 |
| 50122 | Sn-122 | No | Absorption only | 1 | No | Yes | |
| 50123 | Sn-123 | No | Absorption only | 1 | No | Yes | |
| 50124 | Sn-124 | No | Absorption only | 1 | No | Yes | |
| 50125 | Sn-125 | No | Absorption only | 1 | No | Yes | |

Table 7.2 Nuclides for the ENDF/B-VI Library

| ID | Description | Reson. Data | XS Model | # Temps | Pn Data | File 5 Data | Com- ment |
|-----------|--------------------|------------------------|------------------|--------------------|--------------------|------------------------|----------------------|
| 50126 | Sn-126 | No | Absorption only | 1 | No | Yes | |
| 51121 | Sb-121 | No | Absorption only | 1 | No | Yes | |
| 51122 | Sb-122 | No | Yield/Decay only | 1 | No | Yes | 7 |
| 51123 | Sb-123 | No | Absorption only | 1 | No | Yes | |
| 51124 | Sb-124 | No | Absorption only | 1 | No | Yes | |
| 51125 | Sb-125 | No | Absorption only | 1 | No | Yes | |
| 51126 | Sb-126 | No | Absorption only | 1 | No | Yes | |
| 51127 | Sb-127 | No | Yield/Decay only | 1 | No | Yes | 7 |
| 52122 | Te-122 | No | Absorption only | 1 | No | Yes | |
| 52123 | Te-123 | No | Absorption only | 1 | No | Yes | |
| 52124 | Te-124 | No | Absorption only | 1 | No | Yes | |
| 52125 | Te-125 | No | Absorption only | 1 | No | Yes | |
| 52126 | Te-126 | No | Absorption only | 1 | No | Yes | |
| 52127 | Te-127 | No | Yield/Decay only | 1 | No | Yes | 7 |
| 52927 | Te-127m | No | Absorption only | 1 | No | Yes | |
| 52128 | Te-128 | No | Absorption only | 1 | No | Yes | |
| 52129 | Te-129 | No | Yield/Decay only | 1 | No | Yes | 7 |
| 52929 | Te-129m | No | Absorption only | 1 | No | Yes | |
| 52130 | Te-130 | No | Absorption only | 1 | No | Yes | |
| 52131 | Te-131 | No | Yield/Decay only | 1 | No | Yes | 7 |
| 52132 | Te-132 | No | Absorption only | 1 | No | Yes | |
| 53127 | I-127 | No | Absorption only | 1 | No | Yes | |
| 53128 | I-128 | No | Yield/Decay only | 1 | No | Yes | 7 |
| 53129 | I-129 | No | Absorption only | 1 | No | Yes | |
| 53130 | I-130 | No | Absorption only | 1 | No | Yes | |
| 53131 | I-131 | No | Absorption only | 1 | No | Yes | |
| 53135 | I-135 | No | Absorption only | 1 | No | Yes | |
| 54128 | Xe-128 | No | Absorption only | 1 | No | Yes | |
| 54129 | Xe-129 | No | Absorption only | 1 | No | Yes | |
| 54130 | Xe-130 | No | Absorption only | 1 | No | Yes | |
| 54131 | Xe-131 | No | Absorption only | 1 | No | Yes | |
| 54132 | Xe-132 | No | Absorption only | 1 | No | Yes | |
| 54133 | Xe-133 | No | Absorption only | 1 | No | Yes | |
| 54134 | Xe-134 | No | Absorption only | 1 | No | Yes | |
| 54135 | Xe-135 | No | Absorption only | 1 | No | Yes | |
| 54136 | Xe-136 | No | Absorption only | 1 | No | Yes | |
| 54137 | Xe-137 | No | Yield/Decay only | 1 | No | Yes | 7 |
| 55133 | Cs-133 | No | Absorption only | 1 | No | Yes | |
| 55134 | Cs-134 | No | Absorption only | 1 | No | Yes | |

Table 7.2 Nuclides for the ENDF/B-VI Library

| ID | Description | Reson. Data | XS Model | # Temps | Pn Data | File 5 Data | Com- ment |
|-----------|--------------------|------------------------|------------------|--------------------|--------------------|------------------------|----------------------|
| 55135 | Cs-135 | No | Absorption only | 1 | No | Yes | |
| 55136 | Cs-136 | No | Absorption only | 1 | No | Yes | |
| 55137 | Cs-137 | No | Absorption only | 1 | No | Yes | |
| 55138 | Cs-138 | No | Yield/Decay only | 1 | No | Yes | 7 |
| 56134 | Ba-134 | No | Absorption only | 1 | No | Yes | |
| 56135 | Ba-135 | No | Absorption only | 1 | No | Yes | |
| 56136 | Ba-136 | No | Absorption only | 1 | No | Yes | |
| 56137 | Ba-137 | No | Absorption only | 1 | No | Yes | |
| 56138 | Ba-138 | No | Absorption only | 1 | No | Yes | |
| 56139 | Ba-139 | No | Yield/Decay only | 1 | No | Yes | 7 |
| 56140 | Ba-140 | No | Absorption only | 1 | No | Yes | |
| 57139 | La-139 | No | Absorption only | 1 | No | Yes | |
| 57140 | La-140 | No | Absorption only | 1 | No | Yes | |
| 58140 | Ce-140 | No | Absorption only | 1 | No | Yes | |
| 58141 | Ce-141 | No | Absorption only | 1 | No | Yes | |
| 58142 | Ce-142 | No | Absorption only | 1 | No | Yes | |
| 58143 | Ce-143 | No | Absorption only | 1 | No | Yes | |
| 58144 | Ce-144 | No | Absorption only | 1 | No | Yes | |
| 59141 | Pr-141 | No | Absorption only | 1 | No | Yes | |
| 59142 | Pr-142 | No | Absorption only | 1 | No | Yes | |
| 59143 | Pr-143 | No | Absorption only | 1 | No | Yes | |
| 59144 | Pr-144 | No | Yield/Decay only | 1 | No | Yes | 7 |
| 60142 | Nd-142 | No | Absorption only | 1 | No | Yes | |
| 60143 | Nd-143 | No | Absorption only | 1 | No | Yes | |
| 60144 | Nd-144 | No | Absorption only | 1 | No | Yes | |
| 60145 | Nd-145 | No | Absorption only | 1 | No | Yes | |
| 60146 | Nd-146 | No | Absorption only | 1 | No | Yes | |
| 60147 | Nd-147 | No | Absorption only | 1 | No | Yes | |
| 60148 | Nd-148 | No | Absorption only | 1 | No | Yes | |
| 60149 | Nd-149 | No | Yield/Decay only | 1 | No | Yes | 7 |
| 60150 | Nd-150 | No | Absorption only | 1 | No | Yes | |
| 60151 | Nd-151 | No | Yield/Decay only | 1 | No | Yes | 7 |
| 61147 | Pm-147 | No | Absorption only | 1 | No | Yes | |
| 61148 | Pm-148 | No | Absorption only | 1 | No | Yes | |
| 61948 | Pm-148m | No | Absorption only | 1 | No | Yes | |
| 61149 | Pm-149 | No | Absorption only | 1 | No | Yes | |
| 61150 | Pm-150 | No | Yield/Decay only | 1 | No | Yes | 7 |
| 61151 | Pm-151 | No | Absorption only | 1 | No | Yes | |
| 62147 | Sm-147 | No | Absorption only | 4 | No | Yes | |

Table 7.2 Nuclides for the ENDF/B-VI Library

| ID | Description | Reson. Data | XS Model | # Temps | Pn Data | File 5 Data | Com- ment |
|-------|--------------|----------------|------------------|------------|------------|----------------|--------------|
| 62148 | Sm-148 | No | Absorption only | 1 | No | Yes | |
| 62149 | Sm-149 | No | Absorption only | 4 | No | Yes | |
| 62150 | Sm-150 | No | Absorption only | 4 | No | Yes | |
| 62151 | Sm-151 | No | Absorption only | 4 | No | Yes | |
| 62152 | Sm-152 | No | Absorption only | 4 | No | Yes | |
| 62153 | Sm-153 | No | Absorption only | 1 | No | Yes | |
| 62154 | Sm-154 | No | Absorption only | 1 | No | Yes | |
| 62155 | Sm-155 | No | Yield/Decay only | 1 | No | Yes | 7 |
| 63151 | Eu-151 | Yes | Absorption only | 4 | No | No | 5, 13 |
| 63152 | Eu-152 | No | Absorption only | 4 | No | No | 10 |
| 63153 | Eu-153 | Yes | Absorption only | 4 | No | Yes | 13 |
| 63154 | Eu-154 | No | Absorption only | 4 | No | Yes | 10 |
| 63155 | Eu-155 | No | Absorption only | 4 | No | Yes | 10 |
| 63156 | Eu-156 | No | Absorption only | 1 | No | Yes | |
| 63157 | Eu-157 | No | Absorption only | 1 | No | Yes | |
| 63158 | Eu-158 | No | Yield/Decay only | 1 | No | Yes | 7 |
| 64000 | Gd (natural) | | | | | | 6,9 |
| 64152 | Gd-152 | No | Absorption only | 1 | No | No | |
| 64154 | Gd-154 | No | Absorption only | 1 | No | No | |
| 64155 | Gd-155 | Yes | Full set | 1 | No | No | 5, 13 |
| 64156 | Gd-156 | Yes | Absorption only | 1 | No | No | 5 |
| 64157 | Gd-157 | Yes | Full set | 1 | No | No | 5, 13 |
| 64158 | Gd-158 | Yes | Absorption only | 1 | No | No | 5 |
| 64160 | Gd-160 | No | Absorption only | 1 | No | No | |
| 64254 | Gd-154 F.P. | No | Absorption only | 1 | No | Yes | 5,8 |
| 64255 | Gd-155 F.P. | Yes | Full set | 1 | No | Yes | 5,8 |
| 64256 | Gd-156 F.P. | Yes | Absorption only | 1 | No | Yes | 5,8 |
| 64257 | Gd-157 F.P. | Yes | Full set | 1 | No | Yes | 5,8,13 |
| 64258 | Gd-158 F.P. | Yes | Absorption only | 1 | No | Yes | 5,8 |
| 64259 | Gd-159 F.P. | No | Yield/Decay only | 1 | No | Yes | 7,8 |
| 65159 | Tb-159 | No | Absorption only | 1 | No | Yes | |
| 65160 | Tb-160 | No | Absorption only | 1 | No | Yes | |
| 66164 | Dy-164 | No | Absorption only | 1 | No | No | |
| 68000 | Er (natural) | | | | | | 6 |
| 68162 | Er-162 | No | Absorption only | 1 | No | No | |
| 68163 | Er-163 | No | Yield/Decay only | 1 | No | Yes | 7 |
| 68164 | Er-164 | No | Absorption only | 1 | No | No | |
| 68165 | Er-165 | No | Yield/Decay only | 1 | No | Yes | 7 |
| 68166 | Er-166 | No | Absorption only | 1 | No | No | |

Table 7.2 Nuclides for the ENDF/B-VI Library

| ID | Description | Reson. Data | XS Model | # Temps | Pn Data | File 5 Data | Com- ment |
|-------|--------------|----------------|------------------|------------|------------|----------------|--------------|
| 68167 | Er-167 | Yes | Absorption only | 4 | No | No | 5 |
| 68168 | Er-168 | No | Absorption only | 1 | No | No | |
| 68169 | Er-169 | No | Yield/Decay only | 1 | No | Yes | 7 |
| 68170 | Er-170 | No | Absorption only | 1 | No | No | |
| 68171 | Er-171 | No | Absorption only | 1 | No | Yes | |
| 69169 | Tm-169 | No | Absorption only | 1 | No | No | |
| 69170 | Tm-170 | No | Absorption only | 1 | No | Yes | |
| 69171 | Tm-171 | No | Absorption only | 1 | No | Yes | |
| 71176 | Lu-176 | No | Absorption only | 1 | No | No | |
| 72000 | Hf (natural) | | | | | | 6 |
| 72174 | Hf-174 | No | Absorption only | 2 | No | No | |
| 72176 | Hf-176 | Yes | Absorption only | 2 | No | No | 5, 13 |
| 72177 | Hf-177 | Yes | Absorption only | 2 | No | No | 5, 13 |
| 72178 | Hf-178 | Yes | Absorption only | 2 | No | No | 5, 13 |
| 72179 | Hf-179 | Yes | Absorption only | 2 | No | No | 5, 179 |
| 72180 | Hf-180 | Yes | Absorption only | 2 | No | No | 5, 180 |
| 74000 | W | No | Absorption only | 2 | No | No | |
| 78195 | Pt-195 | No | Absorption only | 1 | No | No | |
| 79000 | Au | No | Absorption only | 1 | No | No | |
| 82000 | Pb | No | Full set | 1 | No | No | 10 |
| 83000 | Bi | No | Absorption only | 1 | No | No | |
| 90230 | Th-230 | Yes | Full set | 4 | No | Yes | 5 |
| 90231 | Th-231 | No | Yield/Decay only | 1 | No | Yes | 7 |
| 90232 | Th-232 | Yes | Full set | 4 | No | Yes | 5,12 |
| 90233 | Th-233 | No | Yield/Decay only | 1 | No | Yes | 7 |
| 91231 | Pa-231 | No | Full set | 1 | No | Yes | |
| 91232 | Pa-232 | No | Absorption only | 1 | No | Yes | |
| 91233 | Pa-233 | No | Full set | 1 | No | Yes | |
| 91234 | Pa-234 | No | Yield/Decay only | 1 | No | Yes | 7 |
| 92232 | U-232 | No | Full set | 1 | No | Yes | |
| 92233 | U-233 | Yes | Full set | 4 | No | Yes | 5,12 |
| 92234 | U-234 | Yes | Full set | 4 | No | Yes | 5,12 |
| 92235 | U-235 | Yes | Full set | 6 | Yes | Yes | 5,11,12 |
| 92236 | U-236 | Yes | Full set | 1 | No | Yes | 5,12 |
| 92237 | U-237 | No | Full set | 1 | No | Yes | |
| 92238 | U-238 | Yes | Full set | 6 | Yes | Yes | 5,11,12 |
| 92239 | U-239 | No | Yield/Decay only | 1 | No | Yes | 7 |
| 93236 | Np-236 | No | Yield/Decay only | 1 | No | Yes | 7 |
| 93237 | Np-237 | No | Full set | 1 | No | Yes | 12 |

Table 7.2 Nuclides for the ENDF/B-VI Library

| ID | Description | Reson. Data | XS Model | # Temps | Pn Data | File 5 Data | Com- ment |
|-----------|--------------------|------------------------|------------------|--------------------|--------------------|------------------------|----------------------|
| 93238 | Np-238 | No | Full set | 1 | No | Yes | 12 |
| 93239 | Np-239 | No | Full set | 1 | No | Yes | |
| 94236 | Pu-236 | No | Full set | 4 | No | Yes | |
| 94238 | Pu-238 | No | Full set | 1 | No | Yes | 12 |
| 94239 | Pu-239 | Yes | Full set | 6 | Yes | Yes | 5,11,12 |
| 94240 | Pu-240 | Yes | Full set | 6 | No | Yes | 5,12 |
| 94241 | Pu-241 | Yes | Full set | 6 | No | Yes | 5,12 |
| 94242 | Pu-242 | Yes | Full set | 6 | No | Yes | 5,12,13 |
| 94243 | Pu-243 | No | Full set | 1 | No | Yes | |
| 95241 | Am-241 | Yes | Full set | 4 | No | Yes | 5,12 |
| 95242 | Am-242 | No | Full set | 1 | No | Yes | |
| 95942 | Am-242m | Yes | Full set | 4 | No | Yes | 5,12 |
| 95243 | Am-243 | No | Full set | 4 | No | Yes | 12 |
| 95244 | Am-244 | No | Yield/Decay only | 1 | No | Yes | 7 |
| 96242 | Cm-242 | No | Full set | 1 | No | Yes | |
| 96243 | Cm-243 | No | Full set | 1 | No | Yes | |
| 96244 | Cm-244 | No | Full set | 1 | No | Yes | 12 |
| 96245 | Cm-245 | No | Full set | 1 | No | Yes | 12 |
| 96246 | Cm-246 | No | Full set | 1 | No | Yes | |
| 96247 | Cm-247 | No | Full set | 1 | No | Yes | |
| 96248 | Cm-248 | No | Full set | 1 | No | Yes | |
| 96249 | Cm-249 | No | Yield/Decay only | 1 | No | Yes | 7 |
| 97249 | Bk-249 | No | Full set | 1 | No | Yes | |
| 97250 | Bk-250 | No | Yield/Decay only | 1 | No | Yes | 7 |
| 98249 | Cf-249 | No | Full set | 1 | No | Yes | |
| 98250 | Cf-250 | No | Full set | 1 | No | Yes | |
| 98251 | Cf-251 | No | Full set | 1 | No | Yes | |
| 98252 | Cf-252 | No | Full set | 1 | No | Yes | |

Comments to the list of nuclides (Table 7.2)

For many nuclides, such as fission products, cross sections are given for absorption only and at 600 K only. Cross sections have been included in the library for two or more temperatures only if the temperature dependence is of importance for LWR analysis, and CASMO then interpolates in the data for different temperatures. Table 7.7 provides the temperatures at which each nuclide is tabulated on the library.

1. ID = 5000 represents natural boron and must be used when boron should not be depleted, e.g. as soluble boron in water. It can also be used in control rods.
ID = 5010 represents **B-10 and must be used when boron is to be depleted**, e.g. in burnable poison rods. CASMO also accepts ID = -5000 for depletable boron. The input processor will split the natural boron up into its components: 18.3 w% B-10 and 81.7 w% B-11.
- 2 The compositions of stainless steel (ID = 347), Inconel-718 (ID = 718) and Inconel-750 (ID = 750) are in weight percent:

| Nuclide | 347 | 718 | 750 |
|------------|-------|-------|-------|
| Al (13000) | 0 | 0 | 0.98 |
| Si (14000) | 0.51 | 0.35 | 0 |
| Cr (24000) | 17.40 | 18.96 | 20.14 |
| Mn (25000) | 1.99 | 0.87 | 0.99 |
| Fe (26000) | 68.35 | 27.93 | 8.88 |
| Ni (28000) | 11.70 | 51.19 | 69.02 |

- 3 The compositions of Zircaloy-2 (ID = 302), Zircaloy-4 (ID = 304) and Zirlo (ID = 306) are in weight percent:

| Nuclide | 302 | 304 | 306 |
|------------|--------|--------|--------|
| O (8000) | 0.125 | 0.125 | 0.125 |
| Cr (24000) | 0.10 | 0.10 | 0.10 |
| Fe (26000) | 0.135 | 0.21 | 0.21 |
| Ni (28000) | 0.055 | - | - |
| Zr (40000) | 98.135 | 98.115 | 97.115 |
| Nb (41000) | - | - | 1.00 |
| Sn (50000) | 1.45 | 1.45 | 1.45 |

4. The dummy nuclide ID = 0 can be added to any composition in order to make the total weight percentage add up to 100%. ID = 0 has no influence on the results and cannot be used in FUE materials.
The 1/v-absorber (ID = 1) is normalized to 1 barn at 2200 m/sec.
The unit absorber (ID = 2) has a constant 1 barn absorption cross section.
-

The unit scatterer (ID = 3) has a constant 1 barn in-group scattering cross section and zero absorption. The atomic weight for nuclides 1, 2, and 3 is also unity.

5. Shielded resonance data are tabulated versus background cross section and temperature. The temperatures are normally 293 K, 600 K, 900 K and 1500 K. For U-235, U-238, Pu-239, Pu-240, Pu-241 and Pu-242 two additional temperatures 2100 K and 2700 K are tabulated.
6. Cross sections for the following natural elements are not tabulated in the library, but CASMO accepts their ID numbers. The CASMO input processor will split up an element into its individual components and calculate the cross section for the element from the composition and the cross sections of the components:

| | ID | Component weight percents | | |
|----|-------|---------------------------|---------------|---------------|
| Ag | 47000 | 47107 = 51.36 | 47109 = 48.64 | |
| Cd | 48000 | 48106 = 1.178 | 48108 = 0.854 | 48110 = 12.21 |
| | | 48111 = 12.63 | 48112 = 24.02 | 48113 = 12.30 |
| | | 48114 = 29.11 | 48115 = 7.723 | |
| In | 49000 | 49113 = 4.21 | 49115 = 95.79 | |
| Gd | 64000 | 64152 = 0.20 | 64154 = 2.10 | 64155 = 14.51 |
| | | 64156 = 20.30 | 64157 = 15.64 | 64158 = 24.98 |
| | | 64160 = 22.27 | | |
| Er | 68000 | 68162 = 0.136 | 68164 = 1.529 | 68166 = 33.13 |
| | | 68167 = 22.85 | 68168 = 27.21 | 68170 = 15.14 |
| Hf | 72000 | 72174 = 0.166 | 72176 = 5.13 | 72177 = 18.35 |
| | | 72178 = 27.13 | 72179 = 13.84 | 72180 = 35.40 |

For Gd₂O₃ use 64016. For Er₂O₃ use 68016.

7. Identifiers with only fission yields and decay constants (zero cross sections) are included in the depletion chains and are tracked by number density, but are not involved neutronically in the calculation. These nuclides can be specified in input, however, they are not available for reaction rate edits, e.g., RRI, FRR, or RRX, edits.
8. Gd-15n (n = 4, 5, 6, 7, 8) as fission product (ID = 6425n) is treated separately from Gd-15n as a burnable absorber (ID = 6415n).
9. Idents 64016 and 68016 represent Gd₂O₃ and Er₂O₃ respectively. CASMO will calculate the concentrations of the individual isotopes according to the description in the comment to the FUE Card.
10. Pn data only to order 5 for this nuclide.
11. Fission data present for this nuclide.

-
12. Extended resonance data (32 groups) present for this nuclide.
 13. Gamma data for the gamma data library have not yet been processed from the ENDF/B-VI data files.
 14. **Lumped Fission Product edits (ID=401, 402, and 403):**
For E6 data library, (unlike previous CASMO libraries, e.g., the L-library), lumped fission products, **ID=401** (LFP1, non-saturating), and **ID=402** (LFP2, slowly saturating), are not present on the data libraries, but rather **are edited as a summation of the number densities of the constituent nuclides**. Also edited is an extended LFP, **ID=403** (EXTFP) which is the sum of the number densities of all additional fission product nuclides which **do not** appear in the explicit number density edit, or in ID's 401 or 402. **Note, although not all nuclides are explicitly edited, CASMO tracks all the constituent nuclides individually.** Also note that LFP ID's: 401, 402 and 403, **may not be** used to define materials. Tables 7.3 through 7.6 show the disposition by nuclide of the edited fission products, and LFP ID's, 401, 402 and 403.

Table 7.3 Edited Fission Products

| (29 Nuclides + 3 LFPs) | | | | | | | |
|-------------------------------|--------|-------|--------|-------|--------|-------|--------|
| 36083 | Kr-83 | 55134 | Cs-134 | 61148 | Pm-148 | 63153 | Eu-153 |
| 45103 | Rh-103 | 55135 | Cs-135 | 61149 | Pm-149 | 63154 | Eu-154 |
| 45105 | Rh-105 | 55137 | Cs-137 | 61948 | Pm148m | 63155 | Eu-155 |
| 47109 | Ag-109 | 56140 | Ba-140 | 62147 | Sm-147 | 63156 | Eu-156 |
| 53135 | I-135 | 57140 | La-140 | 62149 | Sm-149 | 64255 | Gd155F |
| 54131 | Xe-131 | 60143 | Nd-143 | 62150 | Sm-150 | 401 | LFP1 |
| 54135 | Xe-135 | 60145 | Nd-145 | 62151 | Sm-151 | 402 | LFP2 |
| 55133 | Cs-133 | 61147 | Pm-147 | 62152 | Sm-152 | 403 | EXTFP |

Table 7.4 Lumped Fission Product Nuclides ID=401

| ID=401 (45 Nuclides) | | | | | | | |
|-----------------------------|-------|-------|--------|-------|--------|-------|---------|
| 32076 | Ge-76 | 40092 | Zr-92 | 48111 | Cd-111 | 54136 | Xe-136 |
| 34078 | Se-78 | 40093 | Zr-93 | 48112 | Cd-112 | 56138 | Ba-138 |
| 34080 | Se-80 | 40094 | Zr-94 | 48114 | Cd-114 | 58140 | Ce-140 |
| 35081 | Br-81 | 40096 | Zr-96 | 48116 | Cd-116 | 60144 | Nd-144 |
| 36084 | Kr-84 | 42097 | Mo-97 | 50117 | Sn-117 | 60148 | Nd-148 |
| 36085 | Kr-85 | 42098 | Mo-98 | 50119 | Sn-119 | 60150 | Nd-150 |
| 36086 | Kr-86 | 42100 | Mo-100 | 50120 | Sn-120 | 62154 | Sm-154 |
| 37085 | Rb-85 | 44101 | Ru-101 | 50122 | Sn-122 | 64256 | Gd-156F |
| 37087 | Rb-87 | 44102 | Ru-102 | 52128 | Te-128 | 64258 | Gd-158F |
| 38090 | Sr-90 | 44104 | Ru-104 | 52130 | Te-130 | | |
| 39089 | Y-89 | 44106 | Ru-106 | 54132 | Xe-132 | | |
| 40091 | Zr-91 | 46110 | Pd-110 | 54134 | Xe-134 | | |

Table 7.5 Lumped Fission Product Nuclides ID=402

| ID=402 (15 Nuclides) | | | | | | | |
|-----------------------------|-------|-------|--------|-------|--------|-------|--------|
| 34077 | Se-77 | 46107 | Pd-107 | 51123 | Sb-123 | 59141 | Pr-141 |
| 34079 | Se-79 | 46108 | Pd-108 | 53127 | I-127 | 60146 | Nd-146 |
| 42095 | Mo-95 | 49115 | In-115 | 53129 | I-129 | 65159 | Tb-159 |
| 43099 | Tc-99 | 51121 | Sb-121 | 57139 | La-139 | | |

Table 7.6 Lumped Fission Product Nuclides ID=403

| ID=403 (105 Nuclides) | | | | | | | |
|------------------------------|--------|-------|--------|-------|--------|-------|--------|
| 32077 | Ge-77 | 44103 | Ru-103 | 51126 | Sb-126 | 56137 | Ba-137 |
| 33077 | As-77 | 44105 | Ru-105 | 51127 | Sb-127 | 56139 | Ba-139 |
| 34081 | Se-81 | 45104 | Rh-104 | 52122 | Te-122 | 58141 | Ce-141 |
| 34082 | Se-82 | 45106 | Rh-106 | 52123 | Te-123 | 58142 | Ce-142 |
| 34083 | Se-83 | 46104 | Pd-104 | 52124 | Te-124 | 58143 | Ce-143 |
| 35082 | Br-82 | 46105 | Pd-105 | 52125 | Te-125 | 58144 | Ce-144 |
| 35083 | Br-83 | 46106 | Pd-106 | 52126 | Te-126 | 59142 | Pr-142 |
| 36082 | Kr-82 | 46109 | Pd-109 | 52127 | Te-127 | 59143 | Pr-143 |
| 36985 | Kr-85m | 47110 | Ag-110 | 52927 | Te127m | 59144 | Pr-144 |
| 36087 | Kr-87 | 47111 | Ag-111 | 52129 | Te-129 | 60142 | Nd-142 |
| 38088 | Sr-88 | 47910 | Ag110m | 52929 | Te129m | 60147 | Nd-147 |
| 38089 | Sr-89 | 48110 | Cd-110 | 52131 | Te-131 | 60149 | Nd-149 |
| 38091 | Sr-91 | 48113 | Cd-113 | 52132 | Te-132 | 60151 | Nd-151 |
| 39090 | Y-90 | 48115 | Cd-115 | 53128 | I-128 | 61150 | Pm-150 |
| 39091 | Y-91 | 48117 | Cd-117 | 53130 | I-130 | 61151 | Pm-151 |
| 40090 | Zr-90 | 49116 | In-116 | 53131 | I-131 | 62148 | Sm-148 |
| 40095 | Zr-95 | 49117 | In-117 | 54128 | Xe-128 | 62153 | Sm-153 |
| 40097 | Zr-97 | 50116 | Sn-116 | 54128 | Xe-128 | 62155 | Sm-155 |
| 41095 | Nb-95 | 50118 | Sn-118 | 54129 | Xe-129 | 63157 | Eu-157 |
| 41096 | Nb-96 | 50121 | Sn-121 | 54130 | Xe-130 | 63158 | Eu-158 |
| 41097 | Nb-97 | 50123 | Sn-123 | 54133 | Xe-133 | 64254 | Gd154F |
| 42096 | Mo-96 | 50124 | Sn-124 | 54137 | Xe-137 | 64257 | Gd157F |
| 42099 | Mo-99 | 50125 | Sn-125 | 55136 | Cs-136 | 64259 | Gd159F |
| 43100 | Tc-100 | 50126 | Sn-126 | 55138 | Cs-138 | 65160 | Tb-160 |
| 44100 | Ru-100 | 51122 | Sb-122 | 56134 | Ba-134 | | |
| 42101 | Mo-101 | 51124 | Sb-124 | 56135 | Ba-135 | | |
| 43101 | Tc-101 | 51125 | Sb-125 | 56136 | Ba-136 | | |

Table 7.7 Temperatures for the ENDF/B-VI Library

| ID | Description | Temperature(s) K | | | | | | | |
|-------|-------------|------------------|-------|-------|--------|--------|--------|-------|--------|
| 1 | 1/V AB | 293.6 | | | | | | | |
| 2 | UNAB | 293.6 | | | | | | | |
| 3 | UNSC | 293.6 | | | | | | | |
| 302 | Zr-2 | 293.0 | 600.0 | 900.0 | 1500.0 | | | | |
| 304 | Zr-4 | 293.0 | 600.0 | 900.0 | 1500.0 | | | | |
| 306 | ZIRLO | 293.0 | 600.0 | 900.0 | 1500.0 | | | | |
| 347 | SS | 293.0 | 600.0 | | | | | | |
| 718 | INC718 | 293.0 | 600.0 | | | | | | |
| 750 | INC750 | 293.0 | 600.0 | | | | | | |
| 1001 | H | 293.6 | 373.6 | 473.6 | 523.6 | 573.6 | 623.6 | | |
| 1002 | D | 293.6 | 373.6 | 473.6 | 573.6 | 673.6 | | | |
| 1107 | H-ZRH | 296.0 | 400.0 | 500.0 | 600.0 | 800.0 | 1200.0 | | |
| 2003 | He-3 | 293.0 | | | | | | | |
| 3000 | Li | 293.0 | | | | | | | |
| 4000 | Be | 293.6 | 400.0 | | | | | | |
| 5000 | B | 293.0 | 600.0 | | | | | | |
| 5010 | B-10 | 293.0 | 600.0 | | | | | | |
| 5011 | B-11 | 293.0 | 600.0 | | | | | | |
| 6000 | C | 293.0 | 400.0 | 500.0 | 600.0 | | | | |
| 6001 | C-gr | 293.6 | 500.0 | 800.0 | 1200.0 | 1600.0 | 2000.0 | | |
| 8000 | O | 293.6 | 373.6 | 473.6 | 523.6 | 573.6 | 623.6 | 900.0 | 1500.0 |
| 7000 | N | 293.0 | | | | | | | |
| 9000 | F | 293.0 | | | | | | | |
| 11000 | Na | 293.0 | | | | | | | |
| 12000 | Mg | 293.0 | 600.0 | | | | | | |
| 13000 | Al | 293.0 | 600.0 | | | | | | |
| 14000 | Si | 293.0 | 600.0 | | | | | | |
| 15000 | P | 293.0 | | | | | | | |
| 16000 | S | 293.0 | | | | | | | |
| 17000 | Cl | 293.0 | | | | | | | |
| 19000 | K | 293.0 | | | | | | | |
| 20000 | Ca | 293.0 | | | | | | | |
| 23000 | V | 293.0 | 600.0 | | | | | | |
| 24000 | Cr | 293.0 | 600.0 | | | | | | |
| 25000 | Mn | 293.0 | 600.0 | | | | | | |
| 26000 | Fe | 293.0 | 600.0 | | | | | | |
| 26054 | Fe-54 | 293.0 | 600.0 | 900.0 | 1500.0 | | | | |
| 26055 | Fe-55 | 293.0 | | | | | | | |

Table 7.7 Temperatures for the ENDF/B-VI Library

| ID | Description | Temperature(s) K | | | | | | | |
|-------|-------------|------------------|-------|-------|--------|--|--|--|--|
| | | 293.0 | 600.0 | | | | | | |
| 27059 | Co-59 | 293.0 | 600.0 | | | | | | |
| 28000 | Ni | 293.0 | 600.0 | | | | | | |
| 28058 | Ni-58 | 293.0 | 600.0 | | | | | | |
| 28062 | Ni-62 | 293.0 | 600.0 | | | | | | |
| 29000 | Cu | 293.0 | | | | | | | |
| 29063 | Cu-63 | 300.0 | | | | | | | |
| 30064 | Zn-64 | 293.0 | | | | | | | |
| 31000 | Ga | 293.0 | 600.0 | | | | | | |
| 32000 | Ge | 293.0 | | | | | | | |
| 32076 | Ge-76 | 600.0 | | | | | | | |
| 32077 | Ge-77 | 600.0 | | | | | | | |
| 33000 | As | 293.0 | | | | | | | |
| 33077 | As-77 | 600.0 | | | | | | | |
| 34000 | Se | 293.0 | | | | | | | |
| 34077 | Se-77 | 600.0 | | | | | | | |
| 34078 | Se-78 | 600.0 | | | | | | | |
| 34079 | Se-79 | 600.0 | | | | | | | |
| 34080 | Se-80 | 600.0 | | | | | | | |
| 34081 | Se-81 | 600.0 | | | | | | | |
| 34082 | Se-82 | 600.0 | | | | | | | |
| 34083 | Se-83 | 600.0 | | | | | | | |
| 35081 | Br-81 | 600.0 | | | | | | | |
| 35082 | Br-82 | 600.0 | | | | | | | |
| 35083 | Br-83 | 600.0 | | | | | | | |
| 36083 | Kr-83 | 293.0 | 600.0 | 900.0 | 1500.0 | | | | |
| 36084 | Kr-84 | 600.0 | | | | | | | |
| 36085 | Kr-85 | 600.0 | | | | | | | |
| 36086 | Kr-86 | 600.0 | | | | | | | |
| 37085 | Rb-85 | 600.0 | | | | | | | |
| 37087 | Rb-87 | 600.0 | | | | | | | |
| 38088 | Sr-88 | 600.0 | | | | | | | |
| 38089 | Sr-89 | 600.0 | | | | | | | |
| 38090 | Sr-90 | 600.0 | | | | | | | |
| 39089 | Y-89 | 600.0 | | | | | | | |
| 36082 | Kr-82 | 600.0 | | | | | | | |
| 36985 | Kr-85m | 600.0 | | | | | | | |
| 36087 | Kr-87 | 600.0 | | | | | | | |
| 38091 | Sr-91 | 600.0 | | | | | | | |
| 39090 | Y-90 | 600.0 | | | | | | | |
| 39091 | Y-91 | 600.0 | | | | | | | |

Table 7.7 Temperatures for the ENDF/B-VI Library

| ID | Description | Temperature(s) K | | | | | | | |
|-------|-------------|------------------|-------|-------|--------|--|--|--|--|
| | | 293.0 | 600.0 | 900.0 | 1500.0 | | | | |
| 40000 | Zr | 293.0 | 600.0 | 900.0 | 1500.0 | | | | |
| 40090 | Zr-90 | 600.0 | | | | | | | |
| 40095 | Zr-95 | 600.0 | | | | | | | |
| 40097 | Zr-97 | 600.0 | | | | | | | |
| 40158 | Zr-ZRH | 296.0 | 500.0 | 800.0 | 1200.0 | | | | |
| 41000 | Nb | 293.0 | 600.0 | | | | | | |
| 41097 | Nb-97 | 600.0 | | | | | | | |
| 42096 | Mo-96 | 600.0 | | | | | | | |
| 42099 | Mo-99 | 600.0 | | | | | | | |
| 42101 | Mo-101 | 600.0 | | | | | | | |
| 43100 | Tc-100 | 600.0 | | | | | | | |
| 43101 | Tc-101 | 600.0 | | | | | | | |
| 45103 | Rh-103 | 293.0 | 600.0 | 900.0 | 1500.0 | | | | |
| 45105 | Rh-105 | 600.0 | | | | | | | |
| 47107 | Ag-107 | 293.0 | 600.0 | 900.0 | 1500.0 | | | | |
| 47109 | Ag-109 | 293.0 | 600.0 | 900.0 | 1500.0 | | | | |
| 40091 | Zr-91 | 600.0 | | | | | | | |
| 40092 | Zr-92 | 600.0 | | | | | | | |
| 40093 | Zr-93 | 600.0 | | | | | | | |
| 40094 | Zr-94 | 600.0 | | | | | | | |
| 40096 | Zr-96 | 600.0 | | | | | | | |
| 41095 | Nb-95 | 600.0 | | | | | | | |
| 41096 | Nb-96 | 600.0 | | | | | | | |
| 42000 | Mo | 293.0 | | | | | | | |
| 42095 | Mo-95 | 600.0 | | | | | | | |
| 42097 | Mo-97 | 600.0 | | | | | | | |
| 42098 | Mo-98 | 600.0 | | | | | | | |
| 42100 | Mo-100 | 600.0 | | | | | | | |
| 43099 | Tc-99 | 600.0 | | | | | | | |
| 44100 | Ru-100 | 600.0 | | | | | | | |
| 44101 | Ru-101 | 600.0 | | | | | | | |
| 44102 | Ru-102 | 600.0 | | | | | | | |
| 44103 | Ru-103 | 600.0 | | | | | | | |
| 44104 | Ru-104 | 600.0 | | | | | | | |
| 44105 | Ru-105 | 600.0 | | | | | | | |
| 44106 | Ru-106 | 600.0 | | | | | | | |
| 45104 | Rh-104 | 600.0 | | | | | | | |
| 45106 | Rh-106 | 600.0 | | | | | | | |
| 46104 | Pd-104 | 600.0 | | | | | | | |
| 46105 | Pd-105 | 600.0 | | | | | | | |

Table 7.7 Temperatures for the ENDF/B-VI Library

| ID | Description | Temperature(s) K | | | | | | | |
|-------|-------------|------------------|-------|--|--|--|--|--|--|
| 46106 | Pd-106 | 600.0 | | | | | | | |
| 46107 | Pd-107 | 600.0 | | | | | | | |
| 46108 | Pd-108 | 600.0 | | | | | | | |
| 46109 | Pd-109 | 600.0 | | | | | | | |
| 46110 | Pd-110 | 600.0 | | | | | | | |
| 46111 | Pd-111 | 600.0 | | | | | | | |
| 47110 | Ag-110 | 600.0 | | | | | | | |
| 47910 | Ag110m | 600.0 | | | | | | | |
| 47111 | Ag-111 | 600.0 | | | | | | | |
| 48106 | Cd-106 | 600.0 | | | | | | | |
| 48108 | Cd-108 | 600.0 | | | | | | | |
| 48110 | Cd-110 | 600.0 | | | | | | | |
| 48111 | Cd-111 | 600.0 | | | | | | | |
| 48112 | Cd-112 | 600.0 | | | | | | | |
| 48113 | Cd-113 | 293.0 | 600.0 | | | | | | |
| 48114 | Cd-114 | 600.0 | | | | | | | |
| 48115 | Cd-115 | 600.0 | | | | | | | |
| 48116 | Cd-116 | 600.0 | | | | | | | |
| 48117 | Cd-117 | 600.0 | | | | | | | |
| 49113 | In-113 | 293.0 | 600.0 | | | | | | |
| 49115 | In-115 | 293.0 | 600.0 | | | | | | |
| 49116 | In-116 | 600.0 | | | | | | | |
| 49117 | In-117 | 600.0 | | | | | | | |
| 50000 | Sn | 293.0 | 600.0 | | | | | | |
| 50116 | Sn-116 | 600.0 | | | | | | | |
| 50117 | Sn-117 | 600.0 | | | | | | | |
| 50118 | Sn-118 | 600.0 | | | | | | | |
| 50119 | Sn-119 | 600.0 | | | | | | | |
| 50120 | Sn-120 | 600.0 | | | | | | | |
| 50121 | Sn-121 | 600.0 | | | | | | | |
| 50122 | Sn-122 | 600.0 | | | | | | | |
| 50123 | Sn-123 | 600.0 | | | | | | | |
| 50124 | Sn-124 | 600.0 | | | | | | | |
| 50125 | Sn-125 | 600.0 | | | | | | | |
| 50126 | Sn-126 | 600.0 | | | | | | | |
| 51121 | Sb-121 | 600.0 | | | | | | | |
| 51122 | Sb-122 | 600.0 | | | | | | | |
| 51123 | Sb-123 | 600.0 | | | | | | | |
| 51124 | Sb-124 | 600.0 | | | | | | | |
| 51125 | Sb-125 | 600.0 | | | | | | | |

Table 7.7 Temperatures for the ENDF/B-VI Library

| ID | Description | Temperature(s) K | | | | | | | |
|-------|-------------|------------------|--|--|--|--|--|--|--|
| | | | | | | | | | |
| 51126 | Sb-126 | 600.0 | | | | | | | |
| 51127 | Sb-127 | 293.0 | | | | | | | |
| 52122 | Te-122 | 600.0 | | | | | | | |
| 52123 | Te-123 | 600.0 | | | | | | | |
| 52124 | Te-124 | 600.0 | | | | | | | |
| 52125 | Te-125 | 600.0 | | | | | | | |
| 52126 | Te-126 | 600.0 | | | | | | | |
| 52127 | Te-127 | 600.0 | | | | | | | |
| 52927 | Te127m | 600.0 | | | | | | | |
| 52128 | Te-128 | 600.0 | | | | | | | |
| 52129 | Te-129 | 600.0 | | | | | | | |
| 52929 | Te129m | 600.0 | | | | | | | |
| 52130 | Te-130 | 600.0 | | | | | | | |
| 52131 | Te-131 | 600.0 | | | | | | | |
| 52132 | Te-132 | 600.0 | | | | | | | |
| 53127 | I-127 | 600.0 | | | | | | | |
| 53128 | I-128 | 600.0 | | | | | | | |
| 53129 | I-129 | 600.0 | | | | | | | |
| 53130 | I-130 | 600.0 | | | | | | | |
| 53131 | I-131 | 600.0 | | | | | | | |
| 53135 | I-135 | 600.0 | | | | | | | |
| 54128 | Xe-128 | 600.0 | | | | | | | |
| 54129 | Xe-129 | 600.0 | | | | | | | |
| 54130 | Xe-130 | 600.0 | | | | | | | |
| 54131 | Xe-131 | 600.0 | | | | | | | |
| 54132 | Xe-132 | 600.0 | | | | | | | |
| 54133 | Xe-133 | 600.0 | | | | | | | |
| 54134 | Xe-134 | 600.0 | | | | | | | |
| 54135 | Xe-135 | 600.0 | | | | | | | |
| 54136 | Xe-136 | 600.0 | | | | | | | |
| 54137 | Xe-137 | 600.0 | | | | | | | |
| 55133 | Cs-133 | 600.0 | | | | | | | |
| 55134 | Cs-134 | 600.0 | | | | | | | |
| 55135 | Cs-135 | 600.0 | | | | | | | |
| 55136 | Cs-136 | 600.0 | | | | | | | |
| 55137 | Cs-137 | 600.0 | | | | | | | |
| 55138 | Cs-138 | 600.0 | | | | | | | |
| 56134 | Ba-134 | 600.0 | | | | | | | |
| 56135 | Ba-135 | 600.0 | | | | | | | |
| 56136 | Ba-136 | 600.0 | | | | | | | |

Table 7.7 Temperatures for the ENDF/B-VI Library

| ID | Description | Temperature(s) K | | | | | | | |
|-------|-------------|------------------|-------|-------|--------|--|--|--|--|
| | | 600.0 | | | | | | | |
| 56137 | Ba-137 | 600.0 | | | | | | | |
| 56138 | Ba-138 | 600.0 | | | | | | | |
| 56139 | Ba-139 | 600.0 | | | | | | | |
| 56140 | Ba-140 | 600.0 | | | | | | | |
| 57139 | La-139 | 600.0 | | | | | | | |
| 57140 | La-140 | 600.0 | | | | | | | |
| 58140 | Ce-140 | 600.0 | | | | | | | |
| 58141 | Ce-141 | 600.0 | | | | | | | |
| 58142 | Ce-142 | 600.0 | | | | | | | |
| 58143 | Ce-143 | 600.0 | | | | | | | |
| 58144 | Ce-144 | 600.0 | | | | | | | |
| 59141 | Pr-141 | 600.0 | | | | | | | |
| 59142 | Pr-142 | 600.0 | | | | | | | |
| 59143 | Pr-143 | 600.0 | | | | | | | |
| 59144 | Pr-144 | 600.0 | | | | | | | |
| 60142 | Nd-142 | 600.0 | | | | | | | |
| 60143 | Nd-143 | 600.0 | | | | | | | |
| 60144 | Nd-144 | 600.0 | | | | | | | |
| 60145 | Nd-145 | 600.0 | | | | | | | |
| 60146 | Nd-146 | 600.0 | | | | | | | |
| 60147 | Nd-147 | 600.0 | | | | | | | |
| 60148 | Nd-148 | 600.0 | | | | | | | |
| 60149 | Nd-149 | 600.0 | | | | | | | |
| 60150 | Nd-150 | 600.0 | | | | | | | |
| 60151 | Nd-151 | 600.0 | | | | | | | |
| 61147 | Pm-147 | 600.0 | | | | | | | |
| 61148 | Pm-148 | 600.0 | | | | | | | |
| 61948 | Pm148m | 600.0 | | | | | | | |
| 61149 | Pm-149 | 600.0 | | | | | | | |
| 61150 | Pm-150 | 600.0 | | | | | | | |
| 61151 | Pm-151 | 600.0 | | | | | | | |
| 62147 | Sm-147 | 293.0 | 600.0 | 900.0 | 1500.0 | | | | |
| 62148 | Sm-148 | 600.0 | | | | | | | |
| 62149 | Sm-149 | 293.0 | 600.0 | 900.0 | 1500.0 | | | | |
| 62150 | Sm-150 | 293.0 | 600.0 | 900.0 | 1500.0 | | | | |
| 62151 | Sm-151 | 293.0 | 600.0 | 900.0 | 1500.0 | | | | |
| 62152 | Sm-152 | 293.0 | 600.0 | 900.0 | 1500.0 | | | | |
| 62153 | Sm-153 | 600.0 | | | | | | | |
| 62154 | Sm-154 | 600.0 | | | | | | | |
| 62155 | Sm-155 | 600.0 | | | | | | | |

Table 7.7 Temperatures for the ENDF/B-VI Library

| ID | Description | Temperature(s) K | | | | | | | |
|-------|-------------|------------------|-------|-------|--------|--|--|--|--|
| | | 293.0 | 600.0 | 900.0 | 1500.0 | | | | |
| 63151 | Eu-151 | 293.0 | 600.0 | 900.0 | 1500.0 | | | | |
| 63152 | Eu-152 | 293.0 | 600.0 | 900.0 | 1500.0 | | | | |
| 63153 | Eu-153 | 293.0 | 600.0 | 900.0 | 1500.0 | | | | |
| 63154 | Eu-154 | 293.0 | 600.0 | 900.0 | 1500.0 | | | | |
| 63155 | Eu-155 | 293.0 | 600.0 | 900.0 | 1500.0 | | | | |
| 63156 | Eu-156 | 600.0 | | | | | | | |
| 63157 | Eu-157 | 600.0 | | | | | | | |
| 63158 | Eu-158 | 600.0 | | | | | | | |
| 64152 | Gd-152 | 600.0 | | | | | | | |
| 64154 | Gd-154 | 600.0 | | | | | | | |
| 64254 | Gd154F | 600.0 | | | | | | | |
| 64155 | Gd-155 | 600.0 | | | | | | | |
| 64255 | Gd155F | 600.0 | | | | | | | |
| 64156 | Gd-156 | 600.0 | | | | | | | |
| 64256 | Gd156F | 600.0 | | | | | | | |
| 64157 | Gd-157 | 600.0 | | | | | | | |
| 64257 | Gd157F | 600.0 | | | | | | | |
| 64158 | Gd-158 | 600.0 | | | | | | | |
| 64258 | Gd158F | 600.0 | | | | | | | |
| 64259 | Gd159F | 600.0 | | | | | | | |
| 64160 | Gd-160 | 600.0 | | | | | | | |
| 65159 | Tb-159 | 600.0 | | | | | | | |
| 65160 | Tb-160 | 600.0 | | | | | | | |
| 66164 | Dy-164 | 293.0 | | | | | | | |
| 68162 | Er-162 | 600.0 | | | | | | | |
| 68163 | Er-163 | 600.0 | | | | | | | |
| 68164 | Er-164 | 600.0 | | | | | | | |
| 68165 | Er-165 | 600.0 | | | | | | | |
| 68166 | Er-166 | 600.0 | | | | | | | |
| 68167 | Er-167 | 293.0 | 600.0 | 900.0 | 1500.0 | | | | |
| 68168 | Er-168 | 600.0 | | | | | | | |
| 68169 | Er-169 | 600.0 | | | | | | | |
| 68170 | Er-170 | 600.0 | | | | | | | |
| 68171 | Er-171 | 600.0 | | | | | | | |
| 69169 | Tm-169 | 600.0 | | | | | | | |
| 69170 | Tm-170 | 600.0 | | | | | | | |
| 69171 | Tm-171 | 600.0 | | | | | | | |
| 71176 | Lu-176 | 293.0 | | | | | | | |
| 72174 | Hf-174 | 293.0 | 600.0 | | | | | | |
| 72176 | Hf-176 | 293.0 | 600.0 | | | | | | |

Table 7.7 Temperatures for the ENDF/B-VI Library

| ID | Description | Temperature(s) K | | | | | | | |
|-------|-------------|------------------|-------|-------|--------|--------|--------|--|--|
| | | 293.0 | 600.0 | | | | | | |
| 72177 | Hf-177 | 293.0 | 600.0 | | | | | | |
| 72178 | Hf-178 | 293.0 | 600.0 | | | | | | |
| 72179 | Hf-179 | 293.0 | 600.0 | | | | | | |
| 72180 | Hf-180 | 293.0 | 600.0 | | | | | | |
| 74000 | W | 293.0 | 600.0 | | | | | | |
| 78195 | Pt-195 | 300.0 | | | | | | | |
| 79000 | Au | 293.0 | | | | | | | |
| 82000 | Pb | 293.0 | | | | | | | |
| 83000 | Bi | 293.0 | | | | | | | |
| 90230 | Th-230 | 293.0 | 600.0 | 900.0 | 1500.0 | | | | |
| 90231 | Th-231 | 600.0 | | | | | | | |
| 90232 | Th-232 | 293.0 | 600.0 | 900.0 | 1500.0 | | | | |
| 90233 | Th-233 | 600.0 | | | | | | | |
| 91231 | Pa-231 | 600.0 | | | | | | | |
| 91232 | Pa-232 | 600.0 | | | | | | | |
| 91233 | Pa-233 | 600.0 | | | | | | | |
| 91234 | Pa-234 | 600.0 | | | | | | | |
| 92232 | U-232 | 600.0 | | | | | | | |
| 92233 | U-233 | 293.0 | 600.0 | 900.0 | 1500.0 | | | | |
| 92234 | U-234 | 293.0 | 600.0 | 900.0 | 1500.0 | | | | |
| 92235 | U-235 | 293.0 | 600.0 | 900.0 | 1500.0 | 2100.0 | 2700.0 | | |
| 92236 | U-236 | 600.0 | | | | | | | |
| 92237 | U-237 | 600.0 | | | | | | | |
| 92238 | U-238 | 293.0 | 600.0 | 900.0 | 1500.0 | 2100.0 | 2700.0 | | |
| 92239 | U-239 | 600.0 | | | | | | | |
| 93236 | Np-236 | 600.0 | | | | | | | |
| 93237 | Np-237 | 600.0 | | | | | | | |
| 93238 | Np-238 | 600.0 | | | | | | | |
| 93239 | Np-239 | 600.0 | | | | | | | |
| 94236 | Pu-236 | 293.0 | 600.0 | 900.0 | 1500.0 | | | | |
| 94238 | Pu-238 | 600.0 | | | | | | | |
| 94239 | Pu-239 | 293.0 | 600.0 | 900.0 | 1500.0 | 2100.0 | 2700.0 | | |
| 94240 | Pu-240 | 293.0 | 600.0 | 900.0 | 1500.0 | 2100.0 | 2700.0 | | |
| 94241 | Pu-241 | 293.0 | 600.0 | 900.0 | 1500.0 | 2100.0 | 2700.0 | | |
| 94242 | Pu-242 | 293.0 | 600.0 | 900.0 | 1500.0 | 2100.0 | 2700.0 | | |
| 94243 | Pu-243 | 600.0 | | | | | | | |
| 95242 | Am-242 | 600.0 | | | | | | | |
| 95244 | Am-244 | 600.0 | | | | | | | |
| 95241 | Am-241 | 293.0 | 600.0 | 900.0 | 1500.0 | | | | |
| 95942 | Am242m | 293.0 | 600.0 | 900.0 | 1500.0 | | | | |

Table 7.7 Temperatures for the ENDF/B-VI Library

| ID | Description | Temperature(s) K | | | | | | | |
|-------|-------------|------------------|-------|-------|--------|--|--|--|--|
| | | 293.0 | 600.0 | 900.0 | 1500.0 | | | | |
| 95243 | Am-243 | 293.0 | 600.0 | 900.0 | 1500.0 | | | | |
| 96242 | Cm-242 | 600.0 | | | | | | | |
| 96243 | Cm-243 | 600.0 | | | | | | | |
| 96244 | Cm-244 | 600.0 | | | | | | | |
| 96245 | Cm-245 | 600.0 | | | | | | | |
| 96246 | Cm-246 | 600.0 | | | | | | | |
| 96247 | Cm-247 | 600.0 | | | | | | | |
| 96248 | Cm-248 | 600.0 | | | | | | | |
| 96249 | Cm-249 | 600.0 | | | | | | | |
| 97249 | Bk-249 | 600.0 | | | | | | | |
| 97250 | Bk-250 | 600.0 | | | | | | | |
| 98249 | Cf-249 | 600.0 | | | | | | | |
| 98250 | Cf-250 | 600.0 | | | | | | | |
| 98251 | Cf-251 | 600.0 | | | | | | | |
| 98252 | Cf-252 | 600.0 | | | | | | | |

7.2 Heavy Nuclide Chains in E6

The heavy nuclides are represented in a matrix form as shown in Figures 7.1 and 7.2. Specific sections of the periodic table have been selected to include all relevant uranium isotopes, and all significant transuranium nuclides being formed by the processes in a nuclear reactor up to, and including, Cf-252.

In the figure, transfers between nuclides have been indicated by arrows in a self-explanatory way. For many nuclides there is a "removal mode" by both an (n, γ) reaction and a radioactive decay (usually beta decay). To indicate to the user which reaction is dominant, only one removal mode has been shown where it is estimated to be at least 100 times as large as the other. Arrows which lead out of the system have been omitted.

The metastable state of Am-242 has also been explicitly represented (which is important for the production of higher nuclides).

Certain information on decay modes, half lives, cross sections, branching ratios etc., is also given in Figures 7.1 and 7.2. These data are approximate and do not necessarily agree with the data in the library.

The production rate of nuclide m due to capture in the predecessor m' is determined by

$$\begin{aligned}\gamma_{m'} &= I_{a,m'} - I_{f,m'} \\ &= \sum_g (\sigma_{a,m',g}^{lib} - \sigma_{f,m',g}^{lib}) \Phi_g f_p\end{aligned}\quad (7.1)$$

σ_a^{lib} and σ_f^{lib} are the cross sections tabulated in the library. (n,2n) cross sections are not listed in the library but (n,2n) reactions are taken into account by reducing the absorption cross section such that

$$\sigma_{a,g}^{lib} = \sigma_{c,g} + \sigma_{f,g} - \sigma_{(n,2n),g}\quad (7.2)$$

In order to find the (n,2n) reaction rates, the code uses the fact that $\sigma_{n,2n}$ is different from zero only in micro group 1 and that $\sigma_{n,\gamma}$ is negligible in this group. Therefore, $\sigma_{n,2n}$ can be determined by

$$\sigma_{(n,2n),1} = \sigma_{f,1}^{lib} - \sigma_{a,1}^{lib}\quad (7.3)$$

For nuclides with (n,2n) reactions Eq. (7.1) is replaced by

$$\gamma_{m'} = I_{a,m'} - I_{f,m'} + \sigma_{(n,2n),1} \Phi_1 f_p$$

Fig. 7.1 E6 Heavy Nuclides: Lower Part (to Am-244)





Fig. 7.2 E6 Heavy Nuclides: Upper Part (to Cf-252)



7.3 Fission Product Chains in E6

For fission products, a representation similar to the one for heavy nuclides has been chosen. The selected nuclides and their relations are shown in Figures 7.3 through 7.10. All significant fission products have been included. The position of a nuclide in the matrix determines whether cumulative or independent fission yield shall be used. For nuclides on the “southeast” edge of the matrix cumulative yield values are used. For all other nuclides (which lie “in the shadow” of those on the southeast edge) independent yield values are used. The selected structure and yield values give yield sums for each fission precursor very close to the theoretical value 2.0.

Certain information on decay modes, half lives, cross sections, branching ratios etc. is also given in Figures 7.3 through 7.10. When two half lives are given, they refer to metastable state and ground state respectively. Cross sections are (n, γ) 2200 m/s cross sections. Two cross sections with a comma between them refer to metastable state and ground state of the nuclide itself for production of the next higher nuclide. Two (or three) cross sections with plus sign(s) between them refer to production of metastable state(s) and ground state of the next higher nuclide.

The data given are approximate and do not necessarily agree with the data in the library.

Fig. 7.3 E6 Fission Products Mass Numbers 76-87




Fig. 7.4 E6 Fission Products Mass Numbers 88-100




Fig. 7.5 E6 Fission Products Mass Numbers 100-110





Fig. 7.6 E6 Fission Products Mass Numbers 110-121



7-37

Fig. 7.7 E6 Fission Products Mass Numbers 122-132





Fig. 7.8 E6 Fission Products Mass Numbers 133-144



Fig. 7.9 E6 Fission Products Mass Numbers 142-151

Fig. 7.10 E6 Fission Products Mass Numbers 152-160



7.4 Burnable Absorber Chains in E6

The burnable absorber depletion chains are shown in Fig. 7.11 and 7.12 below. In this figure arrows leading out of each system have been shown to indicate removal by (n, γ) reaction or radioactive decay.

Fig. 7.11 E6 Burnable Absorbers: Ag, Cd, In






Fig. 7.12 E6 Burnable Absorbers: Gd, Er, Hf**Gd****Er****Hf**