


NUCL 511

Nuclear Reactor Theory and Kinetics

Lecture Note 12

Prof. Won Sik Yang

Purdue University
School of Nuclear Engineering



Spatial Kinetics Equation and Solution Method

■ Neutron and precursor balance equation

$$\frac{1}{v} \frac{\partial \phi}{\partial t} = (F_p - M) \phi + S_d$$

$$\frac{\partial C_k}{\partial t} = -\lambda_k C_k + \beta_k \psi$$

where $\psi = \sum_{g=1}^G v \Sigma_{fg} \phi_g$ is the total fission source

■ Implicit temporal differencing

$$\frac{\phi_l - \phi_{l-1}}{v \Delta t_l} = (F_p^l - M_l) \phi_l + S_d^l \Rightarrow \left(M_l + \frac{I}{v \Delta t_l} - F_p^l \right) \phi_l = \frac{\phi_{l-1}}{v \Delta t_l} + S_d^l$$

■ Analytic solution of precursor balance equation

$$C_k^l = C_k^{l-1} e^{-\lambda_k \Delta t_l} + \beta_k \int_{t_{l-1}}^{t_l} \psi(t') e^{-\lambda_k (t-t')} dt'$$

Spatial Kinetics Solution Method

- Assumption of linear variation of fission source within the interval

$$\psi_l(t) = \psi_{l-1} + \frac{\psi_l - \psi_{l-1}}{\Delta t_l} (t - t_{l-1})$$

- Delayed neutron source after integration of fission source in the analytical precursor solution

$$S_d^l = \tilde{S}_d^{l-1} + \alpha \psi_l$$

- Neutron balance equation in terms of flux only

$$\left[M_l + \frac{I}{v\Delta t_l} - (1 + \tilde{\alpha}) F_p^l \right] \phi_l = \frac{\phi_{l-1}}{v\Delta t_l} + \tilde{S}_d^{l-1}$$

- Fixed source problem that can be solved by a steady-state solver which employs suitable spatial discretization method

Incorporation of Thermal Feedback

■ Cross section functionalization

$$\begin{aligned}\Sigma(\text{ppm}, T_f, \rho_m) = & \Sigma(\text{ppm}_0, T_{f0}, \rho_{m0}) + \frac{\partial \Sigma}{\partial \text{ppm}} (\text{ppm} - \text{ppm}_0) + \frac{\partial \Sigma}{\partial \sqrt{T_f}} (\sqrt{T_f} - \sqrt{T_{f0}}) \\ & + \frac{\partial \Sigma}{\partial \rho_m} (\rho_m - \rho_{m0})\end{aligned}$$

■ Iterative update of cross sections

- 1) Use the current temperature first and evaluate cross sections
- 2) Solve the FSP for flux with partial convergence
- 3) Update Power
- 4) Determine new temperature
- 5) Update cross section
- 6) Repeat steps 2 through 5 until convergence

Control Rod Ejection

■ Cause



- Rupture in control rod derive housing on the reactor vessel head
- Ejection of control rod due to high pressure of vessel

■ Consequence


- Super-prompt critical reactivity insertion
- Rapid power rise and formation of power peak by Doppler

■ Results (for 1.2\$ reactivity insertion in 0.1 sec, NEACRP C1)


- Initial power: 0.0001%



Power Distribution After Rod Ejection (NEACRP C1)



Main Steam Line Break (MSLB)



MSLB Progress Scenario – 1/2

- Break in one of the main steam lines (four or more)
 - Leak of high pressure steam through the break (critical flow)
 - Depressurization of SG and rapid evaporation
- Cool-down of primary coolant causing depressurization of primary loop
 - Initially coolant density decrease in the core
 - Core power **decrease** due to less moderation
- Transport of chilled coolant to core
 - Core reactivity increase due to negative MTC
 - Core power **increase**
- Overpower or **low** pressure trip
 - Control rod inserted, but with **one control rod stuck out**
 - Core power **decrease** to shutdown level
 - Turbine stop valve close
 - Feedwater block valve close


MSLB Progress Scenario – 2/2

- Continued evaporation of secondary coolant and overcooling of primary coolant in one loop
 - Asymmetric flow inlet flow
- Continued core reactivity increase
 - Subcritical neutron multiplication
 - Core power increase
 - Possibility of return-to-critical or return-to-power
- Dry-out of feedwater in broken side SG
 - No further decrease in coolant temperature
 - Core power decreases due to negative temperature coefficients

Considerations on MSLB

- Break flow rate → rate of evaporation
- Magnitude of moderator temperature coefficient (MTC)
 - Positive reactivity insertion due to negative MTC
 - Most limiting at **end of cycle** (least boron, most negative MTC)
- Shutdown margin
 - Total rod worth – largest **stuck rod** worth
 - Power defect
- Asymmetric flow condition
 - Flow mixing in lower plenum
 - Asymmetric radial coolant temperature distribution
- Localized power peaking
 - Stuck rod condition
 - Asymmetry due to asymmetric flow
- 3-D kinetics
 - Severe flux shape change during transient


MARS/MASTER Coupling Options



OECD MSLB Benchmark


- Assess performance of system T-H/spatial kinetics coupled codes
- Model plant: TMI-1
 - B&W designed TMI-1, 2772 MWth
 - Two once-through steam generators
 - *Superheated vapor*
 - *Less feedwater inventory in SG*
- Provided data
 - Neutronics data
 - *Geometry, cross section*
 - T/H component data
 - *Dimension, volume, material properties*
 - Initial operating conditions
 - Trip set points
 - *Over power trip at 114%*
 - *Low pressure trip at 13.41 Mpa*

MARS System Model of OECD MSLB




Core Modeling



Vessel Modeling



Core Modeling



Core Power and Reactivity



Subcritical Multiplication

- Prompt Jump Approximation solution with ρ in \$ ($\rho_{\$} = \rho / \beta$)

$$\dot{p}(t) = \frac{\lambda \rho_{\$}(t) + \dot{\rho}_{\$}(t)}{1 - \rho_{\$}(t)} p(t)$$


- The sign of power change is determined by numerator
 - Denominator always positive in the PJA application range ($\rho_{\$} << 1 \$$)
- If $\rho_{\$} < 0$ (Subcritical)

$$\dot{p}(t) > 0 \text{ if } \frac{\dot{\rho}_{\$}(t)}{|\rho_{\$}(t)|} > \lambda$$


- Reactor power can increase under subcritical condition if the logarithmic derivative of reactivity is larger than precursor decay constant
- Because the increase rate of prompt neutrons is greater than the reduction rate of delayed neutrons
- Or source multiplication factor increases faster than delayed neutron source decreases


Transient Results - II

Temperature




Pressure






Flow Condition near 60 sec

Inlet Flow Rate




Outlet Temperature




Transient Power Distribution Comparison

Coarse-Fine Difference, %



Peak Linear Power Density



*at the time of max. return-to-power

- Peak LPD is normalized to the nominal average value at full power