

RED-POWER ELECTRICAL ENGINEERING PTE LTD
BLK 16 DEFU LANE 10. #01 - 364. SINGAPORE 539197
TEL : 6 289 2298 FAX : 6 287 9635

TOWN COUNCIL	<u>NEE SOON TOWN COUNCIL</u>
LOCATION	<u>(NEE SOON SOUTH)</u>
DATE OF SERVICING	<u>5 /09/2025</u>

WEEKLY FIRE ALARM CHECKLIST REPORT

1. SIMULATED TEST

- 1.1 Carry out a stimulated fire alarm call
 - 1.2 Operate any Alarm Zone
 - 1.3 Transmit a Fire Alarm Signal to the monitoring station and reset the system

2. MONITORING STATION

- 2.1 Contact the monitoring system prior to the transmitting of the fire alarm signal
 - 2.2 To warn them of the simulated fire condition to be tested
 - 2.3 Check with them after completion of test to ensure the fire alarm signal was received
 - 2.4 Advise the monitoring station that the system has been reset

3 BATTERY CONDITION

- 3.1 Check the battery voltage
 - 3.2 Check the battery conditions

4 SWITCHES

- 4.1 Ensure that all switches are in the correct operating condition after completion of tests
 - 4.2 Take immediate steps to rectify the fault(s) should they exist.

5. DEFECTS

- 5.1 Record in the log any fault(s) identified and that the above test has been carried out.

Block No :

REMARKS

Name & signature of Technician(s)

Verified By :

1 pf.

(Name & signature)

2

RED-POWER ELECTRICAL ENGINEERING PTE LTD

BLK 16 DEFU LANE 10. #01 - 364. SINGAPORE 539197

TEL : 6 289 2298 FAX : 6 287 9635

TOWN COUNCIL	<u>NEE SOON TOWN COUNCIL</u>
LOCATION	<u>(NEE SOON SOUTH)</u>
DATE OF SERVICING	<u>6 /09/2025</u>

WEEKLY FIRE ALARM CHECKLIST REPORT

1. SIMULATED TEST

- 1.1 Carry out a stimulated fire alarm call
 - 1.2 Operate any Alarm Zone
 - 1.3 Transmit a Fire Alarm Signal to the monitoring station and reset the system

2. MONITORING STATION

- 2.1 Contact the monitoring system prior to the transmitting of the fire alarm signal
 - 2.2 To warn them of the simulated fire condition to be tested
 - 2.3 Check with them after completion of test to ensure the fire alarm signal was received

2.4 Advise the monitor

- ### 3. BATTERY CONDITION

3.2 Check the

4. SWITCHES
4.1 Ensure that all switches are in the correct operating condition after completion of tests

4.2 Take Im

- ### **5. DEFECTS**

Block No :

REMARKS

Name & signature of Technician(s)

Verified By :

1 

(Name & signature)

2

RED-POWER ELECTRICAL ENGINEERING PTE LTD

BLK 16 DEFU LANE 10. #01 - 364. SINGAPORE 539197

TEL : 6 289 2298 FAX : 6 287 9635

NEE SOON TOWN COUNCIL

LOCATION (NEE SOON SOUTH)

DATE OF SERVICING 11 /09/2025

WEEKLY FIRE ALARM CHECKLIST REPORT

1. SIMULATED TEST

- 1.1 Carry out a stimulated fire alarm call
 - 1.2 Operate any Alarm Zone
 - 1.3 Transmit a Fire Alarm Signal to the monitoring station and reset the system

2. MONITORING STATION

- 2.1 Contact the monitoring system prior to the transmitting of the fire alarm signal
 - 2.2 To warn them of the simulated fire condition to be tested
 - 2.3 Check with them after completion of test to ensure the fire alarm signal was received
 - 2.4 Advise the monitoring station that the system has been reset

3 BATTERY CONDITION

- ### 3.1 Check the battery voltage

4 SWITCHES

- 4.1 Ensure that all switches are in the correct operating condition after completion of tests
 - 4.2 Take immediate steps to rectify the fault(s) should they exist

5. DEFECTS

- 5.1 Record in the log any fault(s) identified and that the above test has been carried out

Block No :

REMARKS

Name & signature of Technician(s)

Verified By :

1 Diff.
2

(Name & signature)

RED-POWER ELECTRICAL ENGINEERING PTE LTD

BLK 16 DEFU LANE 10. #01 - 364. SINGAPORE 539197

TEL : 6 289 2298 FAX : 6 287 9635

FAX : 6 287 9635

TOWN COUNCIL

NEE SOON TOWN COUNCIL

LOCATION

(NEE SOON SOUTH)

DATE OF SERVICING

12/09/2025

WEEKLY FIRE ALARM CHECKLIST REPORT

1. SIMULATED TEST

- 1.1 Carry out a stimulated fire alarm call
 - 1.2 Operate any Alarm Zone
 - 1.3 Transmit a Fire Alarm Signal to the monitoring station and reset the system

2. MONITORING STATION

- 2.1 Contact the monitoring system prior to the transiting of the fire alarm signal
 - 2.2 To warn them of the simulated fire condition to be tested
 - 2.3 Check with them after completion of test to ensure the fire alarm signal was received
 - 2.4 Advise the monitoring station that the systm has been reset

3. BATTERY CONDITION

- 3.1 Check the battery voltage
 - 3.2 Check the battery condition

4. SWITCHES

- 4.1 Ensure that all switches are in the correct operating condition after completion of tests
 - 4.2 Take immediate steps to rectify the fault(s) should they exist.

5 DEFECTS

- 5.1 Record in the log any fault(s) identified and that the above test has been carried out.

Block No :

REMARKS

Name & signature of Technician(s)

Verified By :

1

(Name & signature)

2 _____

RED-POWER ELECTRICAL ENGINEERING PTE LTD
BLK 16 DEFU LANE 10. #01 - 364. SINGAPORE 539197
TEL : 6 289 2298 FAX : 6 287 9635

TOWN COUNCIL	<u>NEE SOON TOWN COUNCIL</u>
LOCATION	<u>(NEE SOON SOUTH)</u>
DATE OF SERVICING	<u>15 /09/2025</u>

WEEKLY FIRE ALARM CHECKLIST REPORT

1. SIMULATED TEST

- 1.1 Carry out a stimulated fire alarm call
 - 1.2 Operate any Alarm Zone
 - 1.3 Transmit a Fire Alarm Signal to the monitoring station and reset the system

2. MONITORING STATION

- 2.1 Contact the monitoring system prior to the transmitting of the fire alarm signal
 - 2.2 To warn them of the simulated fire condition to be tested
 - 2.3 Check with them after completion of test to ensure the fire alarm signal was received
 - 2.4 Advise the monitoring station that the system has been reset

3. BATTERY CONDITION

- ### 3.1 Check the battery voltage

3.2 Check the

4. SWITCHES
4.1 Ensure that all switches are in the correct operating condition after completion of tests

4.2 Take im

5. DEFECTS
5.1 Record in the log any fault(s) identified and that the above test has been carried out.

Block No :

REMARKS

Name & signature of Technician(s)

Verified By :

1 Dff

(Name & signature)

RED-POWER ELECTRICAL ENGINEERING PTE LTD

BLK 16 DEFU LANE 10. #01 - 364. SINGAPORE 539197

TEL : 6 289 2298 FAX : 6 287 9635

TOWN COUNCIL	<u>NEE SOON TOWN COUNCIL</u>
LOCATION	(<u>NEE SOON SOUTH</u>)
DATE OF SERVICING	<u>16</u> /09/2025

WEEKLY FIRE ALARM CHECKLIST REPORT

1. SIMULATED TEST

- 1.1 Carry out a stimulated fire alarm call
 - 1.2 Operate any Alarm Zone
 - 1.3 Transmit a Fire Alarm Signal to the monitoring station and reset the system

2. MONITORING STATION

- 2.1 Contact the monitoring system prior to the transmitting of the fire alarm signal
 - 2.2 To warn them of the simulated fire condition to be tested
 - 2.3 Check with them after completion of test to ensure the fire alarm signal was received
 - 2.4 Advise the monitoring station that the system has been reset

3. BATTERY CONDITION

- 3.1 Check the battery voltage
 - 3.2 Check the battery condition

4. SWITCHES

- 4.1 Ensure that all switches are in the correct operating condition after completion of tests
 - 4.2 Take immediate steps to rectify the fault(s) should they exist

5. DEFECTS

- 5.1 Record in the log any fault(s) identified and that the above test has been carried out.

Block No :

506	507	512	513	813	859
					
					
					
					
					
					
					
					
					
					
					
					
					
					
					
					
					
					
					
					
					
					
					
					

REMARKS

Name & signature of Technician(s)

Verified By :

1

(Name & signature)

2

RED-POWER ELECTRICAL ENGINEERING PTE LTD

BLK 16 DEFU LANE 10. #01 - 364. SINGAPORE 539197

TEL : 6 289 2298 FAX : 6 287 9635

TOWN COUNCIL	<u>NEE SOON TOWN COUNCIL</u>
LOCATION	<u>(NEE SOON SOUTH)</u>
DATE OF SERVICING	<u>22 /09/2025</u>

WEEKLY FIRE ALARM CHECKLIST REPORT

1. SIMULATED TEST

- 1.1 Carry out a stimulated fire alarm call
 - 1.2 Operate any Alarm Zone
 - 1.3 Transmit a Fire Alarm Signal to the monitoring station and reset the system

2. MONITORING STATION

- 2.1 Contact the monitoring system prior to the transmitting of the fire alarm signal
 - 2.2 To warn them of the simulated fire condition to be tested
 - 2.3 Check with them after completion of test to ensure the fire alarm signal was received
 - 2.4 Advise the monitoring station that the system has been reset

3 BATTERY CONDITION

- 3.1 Check the battery voltage
 - 3.2 Check the battery condition

4 SWITCHES

- 4.1 Ensure that all switches are in the correct operating condition after completion of tests
 - 4.2 Take immediate steps to rectify the fault(s) should they exist

5. DEFECTS

5.1 Record

Block No :

REMARKS

Name & signature of Technician(s)

Verified By :

1 Rlf

(Name & signature)

2

RED-POWER ELECTRICAL ENGINEERING PTE LTD

BLK 16 DEFU LANE 10. #01 - 364. SINGAPORE 539197

TEL : 6 289 2298

FAX : 6 287 9635

TOWN COUNCIL

NEE SOON TOWN COUNCIL

LOCATION

(NEE SOON SOUTH)

DATE OF SERVICING

22/09/2025

WEEKLY FIRE ALARM CHECKLIST REPORT

1. SIMULATED TEST

- 1.1 Carry out a stimulated fire alarm call
 - 1.2 Operate any Alarm Zone
 - 1.3 Transmit a Fire Alarm Signal to the monitoring station and reset the system

2. MONITORING STATION

- 2.1 Contact the monitoring system prior to the transiting of the fire alarm signal
 - 2.2 To warn them of the simulated fire condition to be tested
 - 2.3 Check with them after completion of test to ensure the fire alarm signal was received
 - 2.4 Advise the monitoring station that the systm has been reset

3. BATTERY CONDITION

- 3.1 Check the battery voltage
3.2 Check the battery condition

4 SWITCHES

- 4.1 Ensure that all switches are in the correct operating condition after completion of tests
 - 4.2 Take immediate steps to rectify the fault(s) should they exist

5. DEFECTS

- 5.1 Record in the log any fault(s) identified and that the above test has been carried out

Block No :

REMARKS

Name & signature of Technician(s)

Verified By :

1

(Name & signature)

2 _____

RED-POWER ELECTRICAL ENGINEERING PTE LTD

BLK 16 DEFU LANE 10. #01 - 364. SINGAPORE 539197

TEL : 6 289 2298

FAX : 6 287 9635

TOWN COUNCIL

NEE SOON TOWN COUNCIL

LOCATION

YISHUN RING RD (NEE SOON SOUTH)

DATE OF SERVICING

6 /09/2025

WEEKLY GENERATOR CHECKLIST REPORT

1. BATTERY & ENGINE

- 1.1 Check starter battery condition and top up electrolyte where necessary
 - 1.1a Start engine and bring unit up to normal operating temperature
 - 1.1b To allow the engine to run for half an hour
 - 1.1c Record log book this information: Before starting of engine -
 - 1.1d(i) Battery charging current ampere
 - 1.1d(ii) Battery voltage
 - 1.1d(iii) Engine fuel tank level
 - 1.1e Record in the log book this information: After engine been running half an hour -
 - 1.1f(i) Engine lubricating oil pressure
 - 1.1f(ii) Engine rpm (tachometer reading)
 - 1.1f(iii) Engine cooling water temperature
 - 1.1f(iv) Generator output voltage
 - 1.1f(v) Generator output frequency
 - 1.1g Any irregularities detected and remarks
 - 1.1h Ensure controls are set for automatic operation

Block No :

REMARKS

Name & signature of Technician(s)

1 PL.

2

RED-POWER ELECTRICAL ENGINEERING PTE LTD

BLK 16 DEFU LANE 10. #01 - 364. SINGAPORE 539197

TEL : 6 289 2298

FAX : 6 287 9635

TOWN COUNCIL

NEE SOON TOWN COUNCIL

LOCATION

YISHUN RING RD (NEE SOON SOUTH)

DATE OF SERVICING

10 /09/2025

WEEKLY GENERATOR CHECKLIST REPORT

1. BATTERY & ENGINE

- 1.1 Check starter battery condition and top up electrolyte where necessary
 - 1.1a Start engine and bring unit up to normal operating temperature
 - 1.1b To allow the engine to run for half an hour
 - 1.1c Record log book this information: Before starting of engine -
 - 1.1d(i) Battery charging current ampere
 - 1.1d(ii) Battery voltage
 - 1.1d(iii) Engine fuel tank level
 - 1.1e Record in the log book this information: After engine been running half an hour -
 - 1.1f(i) Engine lubricating oil pressure
 - 1.1f(ii) Engine rpm (tachometer reading)
 - 1.1f(iii) Engine cooling water temperature
 - 1.1f(iv) Generator output voltage
 - 1.1f(v) Generator output frequency
 - 1.1g Any irregularities detected and remarks
 - 1.1h Ensure controls are set for automatic operation

10 /09/2025

Block No :

REMARKS

Name & signature of Technician(s)

1 PLK.

2

RED-POWER ELECTRICAL ENGINEERING PTE LTD

BLK 16 DEFU LANE 10. #01 - 364. SINGAPORE 539197

TEL : 6 289 2298

FAX : 6 287 9635

TOWN COUNCIL

NEE SOON TOWN COUNCIL

LOCATION

YISHUN RING RD (NEE SOON SOUTH)

16 /09/2025

WEEKLY GENERATOR CHECKLIST REPORT

1. BATTERY & ENGINE

- 1.1 Check starter battery condition and top up electrolyte where necessary
 - 1.1a Start engine and bring unit up to normal operating temperature
 - 1.1b To allow the engine to run for half an hour
 - 1.1c Record log book this information: Before starting of engine -
 - 1.1d(i) Battery charging current ampere
 - 1.1d(ii) Battery voltage
 - 1.1d(iii) Engine fuel tank level
 - 1.1e Record in the log book this information: After engine been running half an hour -
 - 1.1f(i) Engine lubricating oil pressure
 - 1.1f(ii) Engine rpm (tachometer reading)
 - 1.1f(iii) Engine cooling water temperature
 - 1.1f(iv) Generator output voltage
 - 1.1f(v) Generator output frequency
 - 1.1g Any irregularities detected and remarks
 - 1.1h Ensure controls are set for automatic operation

Block No :

REMARKS

Name & signature of Technician(s)

1 P.M.

2

RED-POWER ELECTRICAL ENGINEERING PTE LTD

BLK 16 DEFU LANE 10. #01 - 364. SINGAPORE 539197

TEL : 6 289 2298

FAX : 6 287 9635

TOWN COUNCIL

NEE SOON TOWN COUNCIL

LOCATION

YISHUN RING RD (NEE SOON SOUTH)

DATE OF SERVICING

25 /09/2025

WEEKLY GENERATOR CHECKLIST REPORT

1. BATTERY & ENGINE

- 1.1 Check starter battery condition and top up electrolyte where necessary
 - 1.1a Start engine and bring unit up to normal operating temperature
 - 1.1b To allow the engine to run for half an hour
 - 1.1c Record log book this information: Before starting of engine -
 - 1.1d(i) Battery charging current ampere
 - 1.1d(ii) Battery voltage
 - 1.1d(iii) Engine fuel tank level
 - 1.1e Record in the log book this information: After engine been running half an hour -
 - 1.1f(i) Engine lubricating oil pressure
 - 1.1f(ii) Engine rpm (tachometer reading)
 - 1.1f(iii) Engine cooling water temperature
 - 1.1f(iv) Generator output voltage
 - 1.1f(v) Generator output frequency
 - 1.1g Any irregularities detected and remarks
 - 1.1h Ensure controls are set for automatic operation

YISHUN RING RD (NEE SOON SOUTH)

Block No :

REMARKS

Name & signature of Technician(s)

1 DY

2

RED-POWER ELECTRICAL ENGINEERING PTE LTD

BLK 16 DEFU LANE 10. #01 - 364. SINGAPORE 539197

TEL : 6 289 2298

FAX : 6 287 9635

TOWN COUNCIL

NEE SOON TOWN COUNCIL

LOCATION

NEE SOON SOUTH DIVISION

DATE OF SERVICING

3 /09/2025

WEEKLY PRESSURE TANK CHECKLIST REPORT

1. Test run of pumps
2. Check pump and motor running condition
3. Check coupling set, baseplate and spring isolator
4. Check mechanical seal / gland-packing and bearings
5. Check all pipe work, check valve, gate valve, expansion joint, strainer
6. Check correct function of pump system in auto and manual mode
7. Check control panel and electrical isolator
8. Check electrical components in control panel
9. Check all indicator lamps
10. Check conduit and wiring
11. Check electrode holder and sensor
12. Check ball float valve / pilot valve and motorised valve
13. Check pump running ampere
14. Check pressure switch setting and pressure gauge

Block No :

501	501A	501B	502A	502B	502C	502D	504	504A
/	/	/	/	/	/	/	/	/
/	/	/	/	/	/	/	/	/
/	/	/	/	/	/	/	/	/
/	/	/	/	/	/	/	/	/
/	/	/	/	/	/	/	/	/
/	/	/	/	/	/	/	/	/
/	/	/	/	/	/	/	/	/
/	/	/	/	/	/	/	/	/
/	/	/	/	/	/	/	/	/
/	/	/	/	/	/	/	/	/
3.0	3.5	3.5	4.0	4.0	4.5	3.5	3.0	3.0
/	/	/	/	/	/	/	/	/

REMARKS

Name & signature of Technician(s)

1 Selvin Ed.

Verified By :

(Name & signature)

2 _____

RED-POWER ELECTRICAL ENGINEERING PTE LTD

BLK 16 DEFU LANE 10. #01 - 364. SINGAPORE 539197

TEL : 6 289 2298

FAX : 6 287 9635

TOWN COUNCIL

NEE SOON TOWN COUNCIL

LOCATION

NEE SOON SOUTH DIVISION

DATE OF SERVICING

3 /09/2025

WEEKLY PRESSURE TANK CHECKLIST REPORT

1. Test run of pumps
2. Check pump and motor running condition
3. Check coupling set, baseplate and spring isolator
4. Check mechanical seal / gland-packing and bearings
5. Check all pipe work, check valve, gate valve, expansion joint, strainer
6. Check correct function of pump system in auto and manual mode
7. Check control panel and electrical isolator
8. Check electrical components in control panel
9. Check all indicator lamps
10. Check conduit and wiring
11. Check electrode holder and sensor
12. Check ball float valve / pilot valve and motorised valve
13. Check pump running ampere
14. Check pressure switch setting and pressure gauge

Block No :

504B	504C	504D	505A	505B	505C	505D	506	506A
/	/	/	/	/	/	/	/	/
/	/	/	/	/	/	/	/	/
/	/	/	/	/	/	/	/	/
/	/	/	/	/	/	/	/	/
/	/	/	/	/	/	/	/	/
/	/	/	/	/	/	/	/	/
/	/	/	/	/	/	/	/	/
/	/	/	/	/	/	/	/	/
/	/	/	/	/	/	/	/	/
/	/	/	/	/	/	/	/	/
4.5	4.0	4.0	3.0	3.5	4.5	4.5	3.0	3.5
/	/	/	/	/	/	/	/	/

REMARKS

Name & signature of Technician(s)

1 Selma

2 _____

Verified By :

(Name & signature)

RED-POWER ELECTRICAL ENGINEERING PTE LTD

BLK 16 DEFU LANE 10. #01 - 364. SINGAPORE 539197

TEL : 6 289 2298

FAX : 6 287 9635

TOWN COUNCIL

NEE SOON TOWN COUNCIL

LOCATION

NEE SOON SOUTH DIVISION

DATE OF SERVICING

3 /09/2025

WEEKLY PRESSURE TANK CHECKLIST REPORT

1. Test run of pumps
2. Check pump and motor running condition
3. Check coupling set, baseplate and spring isolator
4. Check mechanical seal / gland-packing and bearings
5. Check all pipe work, check valve, gate valve, expansion joint, strainer
6. Check correct function of pump system in auto and manual mode
7. Check control panel and electrical isolator
8. Check electrical components in control panel
9. Check all indicator lamps
10. Check conduit and wiring
11. Check electrode holder and sensor
12. Check ball float valve / pilot valve and motorised valve
13. Check pump running ampere
14. Check pressure switch setting and pressure gauge

Block No :

506B	506C	507	507A	508A	508B	509A	509B	509C
/	/	/	/	/	/	/	/	/
/	/	/	/	/	/	/	/	/
/	/	/	/	/	/	/	/	/
/	/	/	/	/	/	/	/	/
/	/	/	/	/	/	/	/	/
/	/	/	/	/	/	/	/	/
/	/	/	/	/	/	/	/	/
/	/	/	/	/	/	/	/	/
/	/	/	/	/	/	/	/	/
/	/	/	/	/	/	/	/	/
4.0	4.5	3.0	3.5	2.5	4.5	3.0	3.0	3.5
/	/	/	/	/	/	/	/	/

REMARKS

Name & signature of Technician(s)

1 Selva M.

Verified By :

(Name & signature)

2 _____

RED-POWER ELECTRICAL ENGINEERING PTE LTD

BLK 16 DEFU LANE 10. #01 - 364. SINGAPORE 539197

TEL : 6 289 2298

FAX : 6 287 9635

TOWN COUNCIL

NEE SOON TOWN COUNCIL

LOCATION

NEE SOON SOUTH DIVISION

DATE OF SERVICING

4 /09/2025

WEEKLY PRESSURE TANK CHECKLIST REPORT

1. Test run of pumps
2. Check pump and motor running condition
3. Check coupling set, baseplate and spring isolator
4. Check mechanical seal / gland-packing and bearings
5. Check all pipe work, check valve, gate valve, expansion joint, strainer
6. Check correct function of pump system in auto and manual mode
7. Check control panel and electrical isolator
8. Check electrical components in control panel
9. Check all indicator lamps
10. Check conduit and wiring
11. Check electrode holder and sensor
12. Check ball float valve / pilot valve and motorised valve
13. Check pump running ampere
14. Check pressure switch setting and pressure gauge

Block No :

510A	510B	511A	511B	511C	512	512A	512B	512C
/	/	/	/	/	/	/	/	/
/		/	/	/	/	/	/	/
/	/	/	/	/	/	/	/	/
/	/	/	/	/	/	/	/	/
/	/	/	/	/	/	/	/	/
/	/	/	/	/	/	/	/	/
/	/	/	/	/	/	/	/	/
/	/	/	/	/	/	/	/	/
3.0	3.8	3.5	3.5	3.0	4.0	4.5	3.8	3.5
/	/	/	/	/	/	/	/	/

Selvaraj.

RED-POWER ELECTRICAL ENGINEERING PTE LTD

BLK 16 DEFU LANE 10. #01 - 364. SINGAPORE 539197

TEL : 6 289 2298

FAX : 6 287 9635

TOWN COUNCIL

NEE SOON TOWN COUNCIL

LOCATION

NEE SOON SOUTH DIVISION

DATE OF SERVICING

4 /09/2025

WEEKLY PRESSURE TANK CHECKLIST REPORT

1. Test run of pumps
2. Check pump and motor running condition
3. Check coupling set, baseplate and spring isolator
4. Check mechanical seal / gland-packing and bearings
5. Check all pipe work, check valve, gate valve, expansion joint, strainer
6. Check correct function of pump system in auto and manual mode
7. Check control panel and electrical isolator
8. Check electrical components in control panel
9. Check all indicator lamps
10. Check conduit and wiring
11. Check electrode holder and sensor
12. Check ball float valve / pilot valve and motorised valve
13. Check pump running ampere
14. Check pressure switch setting and pressure gauge

Block No :

513	513A	513B	513C	513D	813	813A	813B	840A
/	/	/	/	/	/	/	/	/
/	/	/	/	/	/	/	/	/
/	/	/	/	/	/	/	/	/
/	/	/	/	/	/	/	/	/
/	/	/	/	/	/	/	/	/
/	/	/	/	/	/	/	/	/
/	/	/	/	/	/	/	/	/
/	/	/	/	/	/	/	/	/
/	/	/	/	/	/	/	/	/
30	3.8	3.0	40	48	475	50	30	35
/	/	/	/	/	/	/	/	/

REMARKS

Name & signature of Technician(s)

1 Selvaraj.

Verified By :

(Name & signature)

2 _____

RED-POWER ELECTRICAL ENGINEERING PTE LTD

BLK 16 DEFU LANE 10. #01 - 364. SINGAPORE 539197

TEL : 6 289 2298

FAX : 6 287 9635

TOWN COUNCIL

NEE SOON TOWN COUNCIL

LOCATION

NEE SOON SOUTH DIVISION

DATE OF SERVICING

4 /09/2025

WEEKLY PRESSURE TANK CHECKLIST REPORT

1. Test run of pumps
2. Check pump and motor running condition
3. Check coupling set, baseplate and spring isolator
4. Check mechanical seal / gland-packing and bearings
5. Check all pipe work, check valve, gate valve, expansion joint, strainer
6. Check correct function of pump system in auto and manual mode
7. Check control panel and electrical isolator
8. Check electrical components in control panel
9. Check all indicator lamps
10. Check conduit and wiring
11. Check electrode holder and sensor
12. Check ball float valve / pilot valve and motorised valve
13. Check pump running ampere
14. Check pressure switch setting and pressure gauge

Block No :

846	848A	849	-	-	-	-	-	-	-
/	/	/	-	-	-	-	-	-	-
/	/	/	-	-	-	-	-	-	-
/	/	/	-	-	-	-	-	-	-
/	/	/	-	-	-	-	-	-	-
/	/	/	-	-	-	-	-	-	-
/	/	/	-	-	-	-	-	-	-
/	/	/	-	-	-	-	-	-	-
/	/	/	-	-	-	-	-	-	-
/	/	/	-	-	-	-	-	-	-
4.0	3.0	3.8	-	-	-	-	-	-	-
/	/	/	-	-	-	-	-	-	-

REMARKS

Name & signature of Technician(s)

1 Selva

Verified By :

(Name & signature)

2 _____

RED-POWER ELECTRICAL ENGINEERING PTE LTD

BLK 16 DEFU LANE 10. #01 - 364. SINGAPORE 539197

TEL : 6 289 2298

FAX : 6 287 9635

TOWN COUNCIL

NEE SOON TOWN COUNCIL

LOCATION

NEE SOON SOUTH DIVISION

DATE OF SERVICING

10 /09/2025

WEEKLY PRESSURE TANK CHECKLIST REPORT

1. Test run of pumps
2. Check pump and motor running condition
3. Check coupling set, baseplate and spring isolator
4. Check mechanical seal / gland-packing and bearings
5. Check all pipe work, check valve, gate valve, expansion joint, strainer
6. Check correct function of pump system in auto and manual mode
7. Check control panel and electrical isolator
8. Check electrical components in control panel
9. Check all indicator lamps
10. Check conduit and wiring
11. Check electrode holder and sensor
12. Check ball float valve / pilot valve and motorised valve
13. Check pump running ampere
14. Check pressure switch setting and pressure gauge

Block No :

501	501A	501B	502A	502B	502C	502D	504	504A
/	/	/	/	/	/	/	/	/
/	/	/	/	/	/	/	/	/
/	/	/	/	/	/	/	/	/
/	/	/	/	/	/	/	/	/
/	/	/	/	/	/	/	/	/
/	/	/	/	/	/	/	/	/
/	/	/	/	/	/	/	/	/
/	/	/	/	/	/	/	/	/
/	/	/	/	/	/	/	/	/
/	/	/	/	/	/	/	/	/
/	/	/	/	/	/	/	/	/
3.0	3.5	4.5	4.0	4.0	3.5	3.0	4.5	4.0
/	/	/	/	/	/	/	/	/

REMARKS

Name & signature of Technician(s)

1 selva -

Verified By :

(Name & signature)

2 _____

RED-POWER ELECTRICAL ENGINEERING PTE LTD

BLK 16 DEFU LANE 10. #01 - 364. SINGAPORE 539197

TEL : 6 289 2298

FAX : 6 287 9635

TOWN COUNCIL

NEE SOON TOWN COUNCIL

LOCATION

NEE SOON SOUTH DIVISION

DATE OF SERVICING

10 /09/2025

WEEKLY PRESSURE TANK CHECKLIST REPORT

1. Test run of pumps
2. Check pump and motor running condition
3. Check coupling set, baseplate and spring isolator
4. Check mechanical seal / gland-packing and bearings
5. Check all pipe work, check valve, gate valve, expansion joint, strainer
6. Check correct function of pump system in auto and manual mode
7. Check control panel and electrical isolator
8. Check electrical components in control panel
9. Check all indicator lamps
10. Check conduit and wiring
11. Check electrode holder and sensor
12. Check ball float valve / pilot valve and motorised valve
13. Check pump running ampere
14. Check pressure switch setting and pressure gauge

Block No :

504B	504C	504D	505A	505B	505C	505D	506	506A
/	/	/	/	/	/	/	/	/
/	/	/	/	/	/	/	/	/
/	/	/	/	/	/	/	/	/
/	/	/	/	/	/	/	/	/
/	/	/	/	/	/	/	/	/
/	/	/	/	/	/	/	/	/
/	/	/	/	/	/	/	/	/
/	/	/	/	/	/	/	/	/
/	/	/	/	/	/	/	/	/
/	/	/	/	/	/	/	/	/
30	3.5	40	4.5	4.5	40	3.5	30	45
/	/	/	/	/	/	/	/	/

REMARKS

Name & signature of Technician(s)

1 Sehak A.

Verified By :

(Name & signature)

2 _____

RED-POWER ELECTRICAL ENGINEERING PTE LTD

BLK 16 DEFU LANE 10. #01 - 364. SINGAPORE 539197

TEL : 6 289 2298

FAX : 6 287 9635

TOWN COUNCIL

NEE SOON TOWN COUNCIL

LOCATION

NEE SOON SOUTH DIVISION

DATE OF SERVICING

10 /09/2025

WEEKLY PRESSURE TANK CHECKLIST REPORT

1. Test run of pumps
2. Check pump and motor running condition
3. Check coupling set, baseplate and spring isolator
4. Check mechanical seal / gland-packing and bearings
5. Check all pipe work, check valve, gate valve, expansion joint, strainer
6. Check correct function of pump system in auto and manual mode
7. Check control panel and electrical isolator
8. Check electrical components in control panel
9. Check all indicator lamps
10. Check conduit and wiring
11. Check electrode holder and sensor
12. Check ball float valve / pilot valve and motorised valve
13. Check pump running ampere
14. Check pressure switch setting and pressure gauge

Block No :

506B	506C	507	507A	508A	508B	509A	509B	509C
/	/	/	/	/	/	/	/	/
/	/	/	/	/	/	/	/	/
/	/	/	/	/	/	/	/	/
/	/	/	/	/	/	/	/	/
/	/	/	/	/	/	/	/	/
/	/	/	/	/	/	/	/	/
/	/	/	/	/	/	/	/	/
/	/	/	/	/	/	/	/	/
/	/	/	/	/	/	/	/	/
/	/	/	/	/	/	/	/	/
/	/	/	/	/	/	/	/	/
3.5	3.5	3.0	4.0	4.5	4.0	4.5	4.0	4.5
/	/	/	/	/	/	/	/	/

REMARKS

Name & signature of Technician(s)

1 Selva Selvam

2 _____

Verified By :

(Name & signature)

RED-POWER ELECTRICAL ENGINEERING PTE LTD

BLK 16 DEFU LANE 10. #01 - 364. SINGAPORE 539197

TEL : 6 289 2298

FAX : 6 287 9635

TOWN COUNCIL

NEE SOON TOWN COUNCIL

LOCATION

NEE SOON SOUTH DIVISION

DATE OF SERVICING

11 /09/2025

WEEKLY PRESSURE TANK CHECKLIST REPORT

1. Test run of pumps
2. Check pump and motor running condition
3. Check coupling set, baseplate and spring isolator
4. Check mechanical seal / gland-packing and bearings
5. Check all pipe work, check valve, gate valve, expansion joint, strainer
6. Check correct function of pump system in auto and manual mode
7. Check control panel and electrical isolator
8. Check electrical components in control panel
9. Check all indicator lamps
10. Check conduit and wiring
11. Check electrode holder and sensor
12. Check ball float valve / pilot valve and motorised valve
13. Check pump running ampere
14. Check pressure switch setting and pressure gauge

Block No :

510A	510B	511A	511B	511C	512	512A	512B	512C
/	/	/	/	/	/	/	/	/
/	/	/	/	/	/	/	/	/
/	/	/	/	/	/	/	/	/
/	/	/	/	/	/	/	/	/
/	/	/	/	/	/	/	/	/
/	/	/	/	/	/	/	/	/
/	/	/	/	/	/	/	/	/
/	/	/	/	/	/	/	/	/
/	/	/	/	/	/	/	/	/
4.5	4.0	3.5	3.0	4.5	3.0	3.5	4.0	3.5
/	/	/	/	/	/	/	/	/

Selva A.

RED-POWER ELECTRICAL ENGINEERING PTE LTD

BLK 16 DEFU LANE 10. #01 - 364. SINGAPORE 539197

TEL : 6 289 2298

FAX : 6 287 9635

TOWN COUNCIL

NEE SOON TOWN COUNCIL

LOCATION

NEE SOON SOUTH DIVISION

DATE OF SERVICING

11 /09/2025

WEEKLY PRESSURE TANK CHECKLIST REPORT

1. Test run of pumps
2. Check pump and motor running condition
3. Check coupling set, baseplate and spring isolator
4. Check mechanical seal / gland-packing and bearings
5. Check all pipe work, check valve, gate valve, expansion joint, strainer
6. Check correct function of pump system in auto and manual mode
7. Check control panel and electrical isolator
8. Check electrical components in control panel
9. Check all indicator lamps
10. Check conduit and wiring
11. Check electrode holder and sensor
12. Check ball float valve / pilot valve and motorised valve
13. Check pump running ampere
14. Check pressure switch setting and pressure gauge

Block No :

513	513A	513B	513C	513D	813	813A	813B	840A
/	/	/	/	/	/	/	/	/
/	/	/	/	/	/	/	/	/
/	/	/	/	/	/	/	/	/
/	/	/	/	/	/	/	/	/
/	/	/	/	/	/	/	/	/
/	/	/	/	/	/	/	/	/
/	/	/	/	/	/	/	/	/
/	/	/	/	/	/	/	/	/
/	/	/	/	/	/	/	/	/
35	4.8	3.0	4.0	4.5	3.0	3.5	3.5	3.0
/	/	/	/	/	/	/	/	/

REMARKS

Name & signature of Technician(s)

1 Selvin Rd.

Verified By :

(Name & signature)

2 _____

RED-POWER ELECTRICAL ENGINEERING PTE LTD

BLK 16 DEFU LANE 10. #01 - 364. SINGAPORE 539197

TEL : 6 289 2298

FAX : 6 287 9635

TOWN COUNCIL

NEE SOON TOWN COUNCIL

LOCATION

NEE SOON SOUTH DIVISION

DATE OF SERVICING

11 /09/2025

WEEKLY PRESSURE TANK CHECKLIST REPORT

1. Test run of pumps
2. Check pump and motor running condition
3. Check coupling set, baseplate and spring isolator
4. Check mechanical seal / gland-packing and bearings
5. Check all pipe work, check valve, gate valve, expansion joint, strainer
6. Check correct function of pump system in auto and manual mode
7. Check control panel and electrical isolator
8. Check electrical components in control panel
9. Check all indicator lamps
10. Check conduit and wiring
11. Check electrode holder and sensor
12. Check ball float valve / pilot valve and motorised valve
13. Check pump running ampere
14. Check pressure switch setting and pressure gauge

Block No :

846	848A	849	-	-	-	-	-	-	-
/	/	/	-	-	-	-	-	-	-
/	/	/	-	-	-	-	-	-	-
/	/	/	-	-	-	-	-	-	-
/	/	/	-	-	-	-	-	-	-
/	/	/	-	-	-	-	-	-	-
/	/	/	-	-	-	-	-	-	-
/	/	/	-	-	-	-	-	-	-
/	/	/	-	-	-	-	-	-	-
/	/	/	-	-	-	-	-	-	-
3.5	3.0	4.5	-	-	-	-	-	-	-
/	/	/	-	-	-	-	-	-	-

REMARKS

Name & signature of Technician(s)

1 Selva M.

Verified By :

(Name & signature)

2 _____

RED-POWER ELECTRICAL ENGINEERING PTE LTD

BLK 16 DEFU LANE 10. #01 - 364. SINGAPORE 539197

TEL : 6 289 2298

FAX : 6 287 9635

TOWN COUNCIL

NEE SOON TOWN COUNCIL

LOCATION

NEE SOON SOUTH DIVISION

DATE OF SERVICING

17 /09/2025

WEEKLY PRESSURE TANK CHECKLIST REPORT

1. Test run of pumps
2. Check pump and motor running condition
3. Check coupling set, baseplate and spring isolator
4. Check mechanical seal / gland-packing and bearings
5. Check all pipe work, check valve, gate valve, expansion joint, strainer
6. Check correct function of pump system in auto and manual mode
7. Check control panel and electrical isolator
8. Check electrical components in control panel
9. Check all indicator lamps
10. Check conduit and wiring
11. Check electrode holder and sensor
12. Check ball float valve / pilot valve and motorised valve
13. Check pump running ampere
14. Check pressure switch setting and pressure gauge

Block No :

501	501A	501B	502A	502B	502C	502D	504	504A
/	/	/	/	/	/	/	/	/
/	/	/	/	/	/	/	/	/
/	/	/	/	/	/	/	/	/
/	/	/	/	/	/	/	/	/
/	/	/	/	/	/	/	/	/
/	/	/	/	/	/	/	/	/
/	/	/	/	/	/	/	/	/
/	/	/	/	/	/	/	/	/
/	/	/	/	/	/	/	/	/
3.0	3.5	4.5	4.0	4.5	4.8	4.0	4.5	3.5
/	/	/	/	/	/	/	/	/

REMARKS

Name & signature of Technician(s)

Verified By :

1 selva A -

(Name & signature)

2 _____

RED-POWER ELECTRICAL ENGINEERING PTE LTD

BLK 16 DEFU LANE 10. #01 - 364. SINGAPORE 539197

TEL : 6 289 2298

FAX : 6 287 9635

TOWN COUNCIL

NEE SOON TOWN COUNCIL

LOCATION

NEE SOON SOUTH DIVISION

DATE OF SERVICING

17/09/2025

WEEKLY PRESSURE TANK CHECKLIST REPORT

1. Test run of pumps
2. Check pump and motor running condition
3. Check coupling set, baseplate and spring isolator
4. Check mechanical seal / gland-packing and bearings
5. Check all pipe work, check valve, gate valve, expansion joint, strainer
6. Check correct function of pump system in auto and manual mode
7. Check control panel and electrical isolator
8. Check electrical components in control panel
9. Check all indicator lamps
10. Check conduit and wiring
11. Check electrode holder and sensor
12. Check ball float valve / pilot valve and motorised valve
13. Check pump running ampere
14. Check pressure switch setting and pressure gauge

Block No :

504B	504C	504D	505A	505B	505C	505D	506	506A
/	/	/	/	/	/	/	/	/
/	/	/	/	/	/	/	/	/
/	/	/	/	/	/	/	/	/
/	/	/	/	/	/	/	/	/
/	/	/	/	/	/	/	/	/
/	/	/	/	/	/	/	/	/
/	/	/	/	/	/	/	/	/
/	/	/	/	/	/	/	/	/
3.0	3.5	4.0	4.0	4.5	3.0	3.8	3.0	4.5
/	/	/	/	/	/	/	/	/

REMARKS

Name & signature of Technician(s)

Verified By :

1 Seha Ali .

(Name & signature)

2 _____

RED-POWER ELECTRICAL ENGINEERING PTE LTD

BLK 16 DEFU LANE 10. #01 - 364. SINGAPORE 539197

TEL : 6 289 2298

FAX : 6 287 9635

TOWN COUNCIL

NEE SOON TOWN COUNCIL

LOCATION

NEE SOON SOUTH DIVISION

DATE OF SERVICING

17 /09/2025

WEEKLY PRESSURE TANK CHECKLIST REPORT

1. Test run of pumps
2. Check pump and motor running condition
3. Check coupling set, baseplate and spring isolator
4. Check mechanical seal / gland-packing and bearings
5. Check all pipe work, check valve, gate valve, expansion joint, strainer
6. Check correct function of pump system in auto and manual mode
7. Check control panel and electrical isolator
8. Check electrical components in control panel
9. Check all indicator lamps
10. Check conduit and wiring
11. Check electrode holder and sensor
12. Check ball float valve / pilot valve and motorised valve
13. Check pump running ampere
14. Check pressure switch setting and pressure gauge

Block No :

506B	506C	507	507A	508A	508B	509A	509B	509C
/	/	/	/	/	/	/	/	/
/	/	/	/	/	/	/	/	/
/	/	/	/	/	/	/	/	/
/	/	/	/	/	/	/	/	/
/	/	/	/	/	/	/	/	/
/	/	/	/	/	/	/	/	/
/	/	/	/	/	/	/	/	/
/	/	/	/	/	/	/	/	/
/	/	/	/	/	/	/	/	/
/	/	/	/	/	/	/	/	/
3.0	3.5	4.5	2.0	4.0	4.5	3.5	3.0	4.5
/	/	/	/	/	/	/	/	/

REMARKS

Name & signature of Technician(s)

1 Selma A.

Verified By :

(Name & signature)

2 _____

RED-POWER ELECTRICAL ENGINEERING PTE LTD

BLK 16 DEFU LANE 10. #01 - 364. SINGAPORE 539197

TEL : 6 289 2298

FAX : 6 287 9635

TOWN COUNCIL

NEE SOON TOWN COUNCIL

LOCATION

NEE SOON SOUTH DIVISION

DATE OF SERVICING

18 /09/2025

WEEKLY PRESSURE TANK CHECKLIST REPORT

1. Test run of pumps
2. Check pump and motor running condition
3. Check coupling set, baseplate and spring isolator
4. Check mechanical seal / gland-packing and bearings
5. Check all pipe work, check valve, gate valve, expansion joint, strainer
6. Check correct function of pump system in auto and manual mode
7. Check control panel and electrical isolator
8. Check electrical components in control panel
9. Check all indicator lamps
10. Check conduit and wiring
11. Check electrode holder and sensor
12. Check ball float valve / pilot valve and motorised valve
13. Check pump running ampere
14. Check pressure switch setting and pressure gauge

Block No :

510A	510B	511A	511B	511C	512	512A	512B	512C
/	/	/	/	/	/	/	/	/
/	/	/	/	/	/	/	/	/
/	/	/	/	/	/	/	/	/
/	/	/	/	/	/	/	/	/
/	/	/	/	/	/	/	/	/
/	/	/	/	/	/	/	/	/
/	/	/	/	/	/	/	/	/
/	/	/	/	/	/	/	/	/
/	/	/	/	/	/	/	/	/
/	/	/	/	/	/	/	/	/
3.5	3.0	4.5	4.0	4.5	3.5	3.5	3.0	3.0
/	/	/	/	/	/	/	/	/

Selva A.

RED-POWER ELECTRICAL ENGINEERING PTE LTD

BLK 16 DEFU LANE 10. #01 - 364. SINGAPORE 539197

TEL : 6 289 2298

FAX : 6 287 9635

TOWN COUNCIL

NEE SOON TOWN COUNCIL

LOCATION

NEE SOON SOUTH DIVISION

DATE OF SERVICING

18 /09/2025

WEEKLY PRESSURE TANK CHECKLIST REPORT

1. Test run of pumps
2. Check pump and motor running condition
3. Check coupling set, baseplate and spring isolator
4. Check mechanical seal / gland-packing and bearings
5. Check all pipe work, check valve, gate valve, expansion joint, strainer
6. Check correct function of pump system in auto and manual mode
7. Check control panel and electrical isolator
8. Check electrical components in control panel
9. Check all indicator lamps
10. Check conduit and wiring
11. Check electrode holder and sensor
12. Check ball float valve / pilot valve and motorised valve
13. Check pump running ampere
14. Check pressure switch setting and pressure gauge

Block No :

513	513A	513B	513C	513D	813	813A	813B	840A
/	/	/	/	/	/	/	/	/
/	/	/	/	/	/	/	/	/
/	/	/	/	/	/	/	/	/
/	/	/	/	/	/	/	/	/
/	/	/	/	/	/	/	/	/
/	/	/	/	/	/	/	/	/
/	/	/	/	/	/	/	/	/
/	/	/	/	/	/	/	/	/
3.0	3.5	4.5	4.0	4.5	4.0	4.5	4.5	3.0
/	/	/	/	/	/	/	/	/

REMARKS

Name & signature of Technician(s)

1 Selva A.

Verified By :

(Name & signature)

2 _____

RED-POWER ELECTRICAL ENGINEERING PTE LTD

BLK 16 DEFU LANE 10. #01 - 364. SINGAPORE 539197

TEL : 6 289 2298

FAX : 6 287 9635

TOWN COUNCIL

NEE SOON TOWN COUNCIL

LOCATION

NEE SOON SOUTH DIVISION

DATE OF SERVICING

18 /09/2025

WEEKLY PRESSURE TANK CHECKLIST REPORT

1. Test run of pumps
2. Check pump and motor running condition
3. Check coupling set, baseplate and spring isolator
4. Check mechanical seal / gland-packing and bearings
5. Check all pipe work, check valve, gate valve, expansion joint, strainer
6. Check correct function of pump system in auto and manual mode
7. Check control panel and electrical isolator
8. Check electrical components in control panel
9. Check all indicator lamps
10. Check conduit and wiring
11. Check electrode holder and sensor
12. Check ball float valve / pilot valve and motorised valve
13. Check pump running ampere
14. Check pressure switch setting and pressure gauge

Block No :

846	848A	849	-	-	-	-	-	-	-
/	/	/	-	-	-	-	-	-	-
/	/	/	-	-	-	-	-	-	-
/	/	/	-	-	-	-	-	-	-
/	/	/	-	-	-	-	-	-	-
/	/	/	-	-	-	-	-	-	-
/	/	/	-	-	-	-	-	-	-
/	/	/	-	-	-	-	-	-	-
/	/	/	-	-	-	-	-	-	-
/	/	/	-	-	-	-	-	-	-
3.5	3.5	3.0	-	-	-	-	-	-	-
/	/	/	-	-	-	-	-	-	-

REMARKS

Name & signature of Technician(s)

1 Selva MN

2 _____

Verified By :

(Name & signature)

RED-POWER ELECTRICAL ENGINEERING PTE LTD

BLK 16 DEFU LANE 10. #01 - 364. SINGAPORE 539197

TEL : 6 289 2298

FAX : 6 287 9635

TOWN COUNCIL

NEE SOON TOWN COUNCIL

LOCATION

NEE SOON SOUTH DIVISION

DATE OF SERVICING

24 /09/2025

WEEKLY PRESSURE TANK CHECKLIST REPORT

1. Test run of pumps
2. Check pump and motor running condition
3. Check coupling set, baseplate and spring isolator
4. Check mechanical seal / gland-packing and bearings
5. Check all pipe work, check valve, gate valve, expansion joint, strainer
6. Check correct function of pump system in auto and manual mode
7. Check control panel and electrical isolator
8. Check electrical components in control panel
9. Check all indicator lamps
10. Check conduit and wiring
11. Check electrode holder and sensor
12. Check ball float valve / pilot valve and motorised valve
13. Check pump running ampere
14. Check pressure switch setting and pressure gauge

Block No :

501	501A	501B	502A	502B	502C	502D	504	504A
/	/	/	/	/	/	/	/	/
/	/	/	/	/	/	/	/	/
/	/	/	/	/	/	/	/	/
/	/	/	/	/	/	/	/	/
/	/	/	/	/	/	/	/	/
/	/	/	/	/	/	/	/	/
/	/	/	/	/	/	/	/	/
/	/	/	/	/	/	/	/	/
/	/	/	/	/	/	/	/	/
/	/	/	/	/	/	/	/	/
3.0	4.0	4.0	3.5	3.0	3.5	4.0	3.0	4.5
/	/	/	/	/	/	/	/	/

REMARKS

Name & signature of Technician(s)

1 Sohna Ali

Verified By :

(Name & signature)

2 _____

RED-POWER ELECTRICAL ENGINEERING PTE LTD

BLK 16 DEFU LANE 10. #01 - 364. SINGAPORE 539197

TEL : 6 289 2298

FAX : 6 287 9635

TOWN COUNCIL

NEE SOON TOWN COUNCIL

LOCATION

NEE SOON SOUTH DIVISION

DATE OF SERVICING

24 /09/2025

WEEKLY PRESSURE TANK CHECKLIST REPORT

1. Test run of pumps
2. Check pump and motor running condition
3. Check coupling set, baseplate and spring isolator
4. Check mechanical seal / gland-packing and bearings
5. Check all pipe work, check valve, gate valve, expansion joint, strainer
6. Check correct function of pump system in auto and manual mode
7. Check control panel and electrical isolator
8. Check electrical components in control panel
9. Check all indicator lamps
10. Check conduit and wiring
11. Check electrode holder and sensor
12. Check ball float valve / pilot valve and motorised valve
13. Check pump running ampere
14. Check pressure switch setting and pressure gauge

Block No :

504B	504C	504D	505A	505B	505C	505D	506	506A
/	/	/	/	/	/	/	/	/
/	/	/	/	/	/	/	/	/
/	/	/	/	/	/	/	/	/
/	/	/	/	/	/	/	/	/
/	/	/	/	/	/	/	/	/
/	/	/	/	/	/	/	/	/
/	/	/	/	/	/	/	/	/
/	/	/	/	/	/	/	/	/
3.5	3.0	4.5	4.0	4.5	3.5	3.0	3.0	3.5
/	/	/	/	/	/	/	/	/

REMARKS

Name & signature of Technician(s)

1 Selva Raj.

2 _____

Verified By :

(Name & signature)

RED-POWER ELECTRICAL ENGINEERING PTE LTD

BLK 16 DEFU LANE 10. #01 - 364. SINGAPORE 539197

TEL : 6 289 2298

FAX : 6 287 9635

TOWN COUNCIL

NEE SOON TOWN COUNCIL

LOCATION

NEE SOON SOUTH DIVISION

DATE OF SERVICING

24 /09/2025

H.C.

WEEKLY PRESSURE TANK CHECKLIST REPORT

1. Test run of pumps
2. Check pump and motor running condition
3. Check coupling set, baseplate and spring isolator
4. Check mechanical seal / gland-packing and bearings
5. Check all pipe work, check valve, gate valve, expansion joint, strainer
6. Check correct function of pump system in auto and manual mode
7. Check control panel and electrical isolator
8. Check electrical components in control panel
9. Check all indicator lamps
10. Check conduit and wiring
11. Check electrode holder and sensor
12. Check ball float valve / pilot valve and motorised valve
13. Check pump running ampere
14. Check pressure switch setting and pressure gauge

Block No :

506B	506C	507	507A	508A	508B	509A	509B	509C
/	/	/	/	/	/	/	/	/
/	/	/	/	/	/	/	/	/
/	/	/	/	/	/	/	/	/
/	/	/	/	/	/	/	/	/
/	/	/	/	/	/	/	/	/
/	/	/	/	/	/	/	/	/
/	/	/	/	/	/	/	/	/
/	/	/	/	/	/	/	/	/
/	/	/	/	/	/	/	/	/
/	/	/	/	/	/	/	/	/
/	/	/	/	/	/	/	/	/
35	3.0	3.0	4.0	4.0	4.0	4.0	4.0	3.0
/	/	/	/	/	/	/	/	/

REMARKS

Name & signature of Technician(s)

1 Sohna Ali -

Verified By :

(Name & signature)

2 _____

RED-POWER ELECTRICAL ENGINEERING PTE LTD

BLK 16 DEFU LANE 10. #01 - 364. SINGAPORE 539197

TEL : 6 289 2298

FAX : 6 287 9635

TOWN COUNCIL

NEE SOON TOWN COUNCIL

LOCATION

NEE SOON SOUTH DIVISION

DATE OF SERVICING

25 /09/2025

WEEKLY PRESSURE TANK CHECKLIST REPORT

1. Test run of pumps
2. Check pump and motor running condition
3. Check coupling set, baseplate and spring isolator
4. Check mechanical seal / gland-packing and bearings
5. Check all pipe work, check valve, gate valve, expansion joint, strainer
6. Check correct function of pump system in auto and manual mode
7. Check control panel and electrical isolator
8. Check electrical components in control panel
9. Check all indicator lamps
10. Check conduit and wiring
11. Check electrode holder and sensor
12. Check ball float valve / pilot valve and motorised valve
13. Check pump running ampere
14. Check pressure switch setting and pressure gauge

Block No :

510A	510B	511A	511B	511C	512	512A	512B	512C
/	/	/	/	/	/	/	/	/
/	/	/	/	/	/	/	/	/
/	/	/	/	/	/	/	/	/
/	/	/	/	/	/	/	/	/
/	/	/	/	/	/	/	/	/
/	/	/	/	/	/	/	/	/
/	/	/	/	/	/	/	/	/
/	/	/	/	/	/	/	/	/
/	/	/	/	/	/	/	/	/
/	/	/	/	/	/	/	/	/
3.0	40	45	3.5	3.5	3.0	3.5	40	40
/	/	/	/	/	/	/	/	/

Selva A.

RED-POWER ELECTRICAL ENGINEERING PTE LTD

BLK 16 DEFU LANE 10. #01 - 364. SINGAPORE 539197

TEL : 6 289 2298

FAX : 6 287 9635

TOWN COUNCIL

NEE SOON TOWN COUNCIL

LOCATION

NEE SOON SOUTH DIVISION

DATE OF SERVICING

25 /09/2025

WEEKLY PRESSURE TANK CHECKLIST REPORT

1. Test run of pumps
2. Check pump and motor running condition
3. Check coupling set, baseplate and spring isolator
4. Check mechanical seal / gland-packing and bearings
5. Check all pipe work, check valve, gate valve, expansion joint, strainer
6. Check correct function of pump system in auto and manual mode
7. Check control panel and electrical isolator
8. Check electrical components in control panel
9. Check all indicator lamps
10. Check conduit and wiring
11. Check electrode holder and sensor
12. Check ball float valve / pilot valve and motorised valve
13. Check pump running ampere
14. Check pressure switch setting and pressure gauge

Block No :

513	513A	513B	513C	513D	813	813A	813B	840A
/	/	/	/	/	/	/	/	/
/	/	/	/	/	/	/	/	/
/	/	/	/	/	/	/	/	/
/	/	/	/	/	/	/	/	/
/	/	/	/	/	/	/	/	/
/	/	/	/	/	/	/	/	/
/	/	/	/	/	/	/	/	/
/	/	/	/	/	/	/	/	/
3.5	3.0	3.5	3.0	4.0	4.5	4.8	4.8	3.0
/	/	/	/	/	/	/	/	/

REMARKS

Name & signature of Technician(s)

1 Selvin M .

Verified By :

(Name & signature)

2 _____

RED-POWER ELECTRICAL ENGINEERING PTE LTD

BLK 16 DEFU LANE 10. #01 - 364. SINGAPORE 539197

TEL : 6 289 2298 FAX : 6 287 9635

TOWN COUNCIL NEE SOON TOWN COUNCIL
LOCATION NEE SOON SOUTH DIVISION
DATE OF SERVICING 25/09/2025

WEEKLY PRESSURE TANK CHECKLIST REPORT

1. Test run of pumps
2. Check pump and motor running condition
3. Check coupling set, baseplate and spring isolator
4. Check mechanical seal / gland-packing and bearings
5. Check all pipe work, check valve, gate valve, expansion joint, strainer
6. Check correct function of pump system in auto and manual mode
7. Check control panel and electrical isolator
8. Check electrical components in control panel
9. Check all indicator lamps
10. Check conduit and wiring
11. Check electrode holder and sensor
12. Check ball float valve / pilot valve and motorised valve
13. Check pump running ampere
14. Check pressure switch setting and pressure gauge

Block No :

846	848A	849	-	-	-	-	-	-	-	-
/	/	/	-	-	-	-	-	-	-	-
/	/	/	-	-	-	-	-	-	-	-
/	/	/	-	-	-	-	-	-	-	-
/	/	/	-	-	-	-	-	-	-	-
/	/	/	-	-	-	-	-	-	-	-
/	/	/	-	-	-	-	-	-	-	-
/	/	/	-	-	-	-	-	-	-	-
/	/	/	-	-	-	-	-	-	-	-
/	/	/	-	-	-	-	-	-	-	-
/	/	/	-	-	-	-	-	-	-	-
403.0	35		-	-	-	-	-	-	-	-
/	/	/	-	-	-	-	-	-	-	-

REMARKS

Name & signature of Technician(s)

Verified By :

1 Selva E.

(Name & signature)

2

RED-POWER ELECTRICAL ENGINEERING PTE LTD

BLK 16 DEFU LANE 10. #01 - 364. SINGAPORE 539197

TEL : 6 289 2298

FAX : 6 287 9635

TOWN COUNCIL

NEE SOON TOWN COUNCIL

LOCATION

NEE SOON SOUTH DIVISION

DATE OF SERVICING

29 /09/2025

WEEKLY PRESSURE TANK CHECKLIST REPORT

1. Test run of pumps
2. Check pump and motor running condition
3. Check coupling set, baseplate and spring isolator
4. Check mechanical seal / gland-packing and bearings
5. Check all pipe work, check valve, gate valve, expansion joint, strainer
6. Check correct function of pump system in auto and manual mode
7. Check control panel and electrical isolator
8. Check electrical components in control panel
9. Check all indicator lamps
10. Check conduit and wiring
11. Check electrode holder and sensor
12. Check ball float valve / pilot valve and motorised valve
13. Check pump running ampere
14. Check pressure switch setting and pressure gauge

Block No :

501	501A	501B	502A	502B	502C	502D	504	504A
/	/	/	/	/	/	/	/	/
/	/	/	/	/	/	/	/	/
/	/	/	/	/	/	/	/	/
/	/	/	/	/	/	/	/	/
/	/	/	/	/	/	/	/	/
/	/	/	/	/	/	/	/	/
/	/	/	/	/	/	/	/	/
/	/	/	/	/	/	/	/	/
/	/	/	/	/	/	/	/	/
/	/	/	/	/	/	/	/	/
3.0	4.0	4.5	3.5	3.5	3.0	3.0	4.5	4.0
/	/	/	/	/	/	/	/	/

REMARKS

Name & signature of Technician(s)

1 Selva .

Verified By :

(Name & signature)

2 _____

RED-POWER ELECTRICAL ENGINEERING PTE LTD

BLK 16 DEFU LANE 10. #01 - 364. SINGAPORE 539197

TEL : 6 289 2298

FAX : 6 287 9635

TOWN COUNCIL

NEE SOON TOWN COUNCIL

LOCATION

NEE SOON SOUTH DIVISION

DATE OF SERVICING

29 /09/2025

WEEKLY PRESSURE TANK CHECKLIST REPORT

1. Test run of pumps
2. Check pump and motor running condition
3. Check coupling set, baseplate and spring isolator
4. Check mechanical seal / gland-packing and bearings
5. Check all pipe work, check valve, gate valve, expansion joint, strainer
6. Check correct function of pump system in auto and manual mode
7. Check control panel and electrical isolator
8. Check electrical components in control panel
9. Check all indicator lamps
10. Check conduit and wiring
11. Check electrode holder and sensor
12. Check ball float valve / pilot valve and motorised valve
13. Check pump running ampere
14. Check pressure switch setting and pressure gauge

Block No :

504B	504C	504D	505A	505B	505C	505D	506	506A
/	/	/	/	/	/	/	/	/
/	/	/	/	/	/	/	/	/
/	/	/	/	/	/	/	/	/
/	/	/	/	/	/	/	/	/
/	/	/	/	/	/	/	/	/
/	/	/	/	/	/	/	/	/
/	/	/	/	/	/	/	/	/
/	/	/	/	/	/	/	/	/
/	/	/	/	/	/	/	/	/
4.0	4.5	3.5	3.5	3.0	4.5	4.0	3.5	2.0
/	/	/	/	/	/	/	/	/

REMARKS

Name & signature of Technician(s)

1 Selvaganesh

Verified By :

(Name & signature)

2 _____

RED-POWER ELECTRICAL ENGINEERING PTE LTD

BLK 16 DEFU LANE 10. #01 - 364. SINGAPORE 539197

TEL : 6 289 2298

FAX : 6 287 9635

TOWN COUNCIL

NEE SOON TOWN COUNCIL

LOCATION

NEE SOON SOUTH DIVISION

DATE OF SERVICING

29 /09/2025

WEEKLY PRESSURE TANK CHECKLIST REPORT

1. Test run of pumps
2. Check pump and motor running condition
3. Check coupling set, baseplate and spring isolator
4. Check mechanical seal / gland-packing and bearings
5. Check all pipe work, check valve, gate valve, expansion joint, strainer
6. Check correct function of pump system in auto and manual mode
7. Check control panel and electrical isolator
8. Check electrical components in control panel
9. Check all indicator lamps
10. Check conduit and wiring
11. Check electrode holder and sensor
12. Check ball float valve / pilot valve and motorised valve
13. Check pump running ampere
14. Check pressure switch setting and pressure gauge

Block No :

506B	506C	507	507A	508A	508B	509A	509B	509C
/	/	/	/	/	/	/	/	/
/	/	/	/	/	/	/	/	/
/	/	/	/	/	/	/	/	/
/	/	/	/	/	/	/	/	/
/	/	/	/	/	/	/	/	/
/	/	/	/	/	/	/	/	/
/	/	/	/	/	/	/	/	/
/	/	/	/	/	/	/	/	/
/	/	/	/	/	/	/	/	/
/	/	/	/	/	/	/	/	/
/	/	/	/	/	/	/	/	/
3.0	4.0	4.0	3.5	3.5	4.0	4.0	3.5	3.0
/	/	/	/	/	/	/	/	/

REMARKS

Name & signature of Technician(s)

1 Sohna M.

Verified By :

(Name & signature)

2 _____

RED-POWER ELECTRICAL ENGINEERING PTE LTD

BLK 16 DEFU LANE 10. #01 - 364. SINGAPORE 539197

TEL : 6 289 2298

FAX : 6 287 9635

TOWN COUNCIL

NEE SOON TOWN COUNCIL

LOCATION

NEE SOON SOUTH DIVISION

DATE OF SERVICING

30 /09/2025

WEEKLY PRESSURE TANK CHECKLIST REPORT

1. Test run of pumps
2. Check pump and motor running condition
3. Check coupling set, baseplate and spring isolator
4. Check mechanical seal / gland-packing and bearings
5. Check all pipe work, check valve, gate valve, expansion joint, strainer
6. Check correct function of pump system in auto and manual mode
7. Check control panel and electrical isolator
8. Check electrical components in control panel
9. Check all indicator lamps
10. Check conduit and wiring
11. Check electrode holder and sensor
12. Check ball float valve / pilot valve and motorised valve
13. Check pump running ampere
14. Check pressure switch setting and pressure gauge

Block No :

510A	510B	511A	511B	511C	512	512A	512B	512C
/	/	/	/	/	/	/	/	/
/	/	/	/	/	/	/	/	/
/	/	/	/	/	/	/	/	/
/	/	/	/	/	/	/	/	/
/	/	/	/	/	/	/	/	/
/	/	/	/	/	/	/	/	/
/	/	/	/	/	/	/	/	/
/	/	/	/	/	/	/	/	/
3.0	3.5	3.5	3.0	3.5	4.5	4.0	4.5	4.5
/	/	/	/	/	/	/	/	/

Selvaraj -

RED-POWER ELECTRICAL ENGINEERING PTE LTD

BLK 16 DEFU LANE 10. #01 - 364. SINGAPORE 539197

TEL : 6 289 2298

FAX : 6 287 9635

TOWN COUNCIL

NEE SOON TOWN COUNCIL

LOCATION

NEE SOON SOUTH DIVISION

DATE OF SERVICING

30/09/2025

WEEKLY PRESSURE TANK CHECKLIST REPORT

1. Test run of pumps
2. Check pump and motor running condition
3. Check coupling set, baseplate and spring isolator
4. Check mechanical seal / gland-packing and bearings
5. Check all pipe work, check valve, gate valve, expansion joint, strainer
6. Check correct function of pump system in auto and manual mode
7. Check control panel and electrical isolator
8. Check electrical components in control panel
9. Check all indicator lamps
10. Check conduit and wiring
11. Check electrode holder and sensor
12. Check ball float valve / pilot valve and motorised valve
13. Check pump running ampere
14. Check pressure switch setting and pressure gauge

Block No :

513	513A	513B	513C	513D	813	813A	813B	840A
/	/	/	/	/	/	/	/	/
/	/	/	/	/	/	/	/	/
/	/	/	/	/	/	/	/	/
/	/	/	/	/	/	/	/	/
/	/	/	/	/	/	/	/	/
/	/	/	/	/	/	/	/	/
/	/	/	/	/	/	/	/	/
/	/	/	/	/	/	/	/	/
/	/	/	/	/	/	/	/	/
/	/	/	/	/	/	/	/	/
3.0	4.5	4.0	3.0	3.5	3.0	3.5	3.5	3.0
/	/	/	/	/	/	/	/	/

REMARKS

Name & signature of Technician(s)

1 Selva AY

Verified By :

(Name & signature)

2 _____

RED-POWER ELECTRICAL ENGINEERING PTE LTD

BLK 16 DEFU LANE 10. #01 - 364. SINGAPORE 539197

TEL : 6 289 2298

FAX : 6 287 9635

TOWN COUNCIL

NEE SOON TOWN COUNCIL

LOCATION

NEE SOON SOUTH DIVISION

DATE OF SERVICING

30 /09/2025

WEEKLY PRESSURE TANK CHECKLIST REPORT

1. Test run of pumps
2. Check pump and motor running condition
3. Check coupling set, baseplate and spring isolator
4. Check mechanical seal / gland-packing and bearings
5. Check all pipe work, check valve, gate valve, expansion joint, strainer
6. Check correct function of pump system in auto and manual mode
7. Check control panel and electrical isolator
8. Check electrical components in control panel
9. Check all indicator lamps
10. Check conduit and wiring
11. Check electrode holder and sensor
12. Check ball float valve / pilot valve and motorised valve
13. Check pump running ampere
14. Check pressure switch setting and pressure gauge

Block No :

846	848A	849	-	-	-	-	-	-	-
/	/	/	-	-	-	-	-	-	-
/	/	/	-	-	-	-	-	-	-
/	/	/	-	-	-	-	-	-	-
/	/	/	-	-	-	-	-	-	-
/	/	/	-	-	-	-	-	-	-
/	/	/	-	-	-	-	-	-	-
/	/	/	-	-	-	-	-	-	-
/	/	/	-	-	-	-	-	-	-
/	/	/	-	-	-	-	-	-	-
/	/	/	-	-	-	-	-	-	-
/	/	/	-	-	-	-	-	-	-
30	3.8	40	-	-	-	-	-	-	-
/	/	/	-	-	-	-	-	-	-

REMARKS

Name & signature of Technician(s)

1 Selva

Verified By :

(Name & signature)

2 _____