

RED-POWER ELECTRICAL ENGINEERING PTE LTD  
BLK 16 DEFU LANE 10. #01 - 364. SINGAPORE 539197  
TEL : 6 289 2298 FAX : 6 287 9635

TOWN COUNCIL	<u>NEE SOON TOWN COUNCIL</u>
LOCATION	<u>NEE SOON EAST DIVISION</u>
DATE OF SERVICING	5 /09/2025

## WEEKLY FIRE ALARM CHECKLIST REPORT

## 1. SIMULATED TEST

- 1.1 Carry out a stimulated fire alarm call
  - 1.2 Operate any Alarm Zone
  - 1.3 Transmit a Fire Alarm Signal to the monitoring station and reset the system

## 2. MONITORING STATION

- 2.1 Contact the monitoring system prior to the transmitting of the fire alarm signal
  - 2.2 To warn them of the simulated fire condition to be tested
  - 2.3 Check with them after completion of test to ensure the fire alarm signal was received
  - 2.4 Advise the monitoring station that the system has been reset

### 3 BATTERY CONDITION

- ### 3.1 Check the battery voltage

4 SWITCHES

- 4.1 Ensure that all switches are in the correct operating condition after completion of tests
  - 4.2 Take immediate steps to rectify the fault(s) should they exist

5. DEFECTS

  - 5.1 Record in the log any fault(s) identified and that the above test has been carried out

Block No :

REMARKS

Name & signature of Technician(s)

Verified By :

1 Rh

(Name & signature)

2

RED-POWER ELECTRICAL ENGINEERING PTE LTD

BLK 16 DEFU LANE 10. #01 - 364. SINGAPORE 539197

TEL : 6 289 2298 FAX : 6 287 9635

TOWN COUNCIL	<u>NEE SOON TOWN COUNCIL</u>
LOCATION	<u>NEE SOON EAST DIVISION</u>
DATE OF SERVICING	<u>5 /09/2025</u>

## WEEKLY FIRE ALARM CHECKLIST REPORT

## 1. SIMULATED TEST

- 1.1 Carry out a stimulated fire alarm call
  - 1.2 Operate any Alarm Zone
  - 1.3 Transmit a Fire Alarm Signal to the monitoring station and reset the system

## 2. MONITORING STATION

- 2.1 Contact the monitoring system prior to the transmitting of the fire alarm signal
  - 2.2 To warn them of the simulated fire condition to be tested
  - 2.3 Check with them after completion of test to ensure the fire alarm signal was received
  - 2.4 Advise the monitoring station that the system has been reset

### 3. BATTERY CONDITION

- 3.1 Check the battery voltage
  - 3.2 Check the battery conditions

#### 4 SWITCHES

- 4.1 Ensure that all switches are in the correct operating condition after completion of tests
  - 4.2 Take immediate steps to rectify the fault(s) should they exist

5. DEFECTS

  - 5.1 Record in the log any fault(s) identified and that the above test has been carried out.

Block No :

REMARKS

Name & signature of Technician(s)

Verified By :

$$1 \frac{1}{\sqrt{2}}$$

(Name & signature)

2

RED-POWER ELECTRICAL ENGINEERING PTE LTD  
BLK 16 DEFU LANE 10. #01 - 364. SINGAPORE 539197  
TEL : 6 289 2298 FAX : 6 287 9635

TOWN COUNCIL	<u>NEE SOON TOWN COUNCIL</u>
LOCATION	<u>NEE SOON EAST DIVISION</u>
DATE OF SERVICING	<u>20/09/2025</u>

## WEEKLY FIRE ALARM CHECKLIST REPORT

## 1. SIMULATED TEST

- 1.1 Carry out a stimulated fire alarm call
  - 1.2 Operate any Alarm Zone
  - 1.3 Transmit a Fire Alarm Signal to the monitoring station and reset the system

## 2. MONITORING STATION

- 2.1 Contact the monitoring system prior to the transiting of the fire alarm signal
  - 2.2 To warn them of the simulated fire condition to be tested
  - 2.3 Check with them after completion of test to ensure the fire alarm signal was received
  - 2.4 Advise the monitoring station that the systm has been reset

### 3. BATTERY CONDITION

- 3.1 Check the battery voltage
  - 3.2 Check the battery conditions

4 SWITCHES

- 4.1 Ensure that all switches are in the correct operating condition after completion of tests
  - 4.2 Take immediate steps to rectify the fault(s) should they exist

## 5. DEFECTS

- 5.1 Record in the log any fault(s) identified and that the above test has been carried out

Block No :

REMARKS

Name & signature of Technician(s)

Verified By :

1 Df.

(Name & signature)

2

RED-POWER ELECTRICAL ENGINEERING PTE LTD

BLK 16 DEFU LANE 10. #01 - 364. SINGAPORE 539197

TEL : 6 289 2298 FAX : 6 287 9635

TOWN COUNCIL	<u>NEE SOON TOWN COUNCIL</u>
LOCATION	<u>NEE SOON EAST DIVISION</u>
DATE OF SERVICING	<u>6 /09/2025</u>

## WEEKLY FIRE ALARM CHECKLIST REPORT

## 1. SIMULATED TEST

- 1.1 Carry out a stimulated fire alarm call
  - 1.2 Operate any Alarm Zone
  - 1.3 Transmit a Fire Alarm Signal to the monitoring station and reset the system

## 2. MONITORING STATION

- 2.1 Contact the monitoring system prior to the transmitting of the fire alarm signal
  - 2.2 To warn them of the simulated fire condition to be tested
  - 2.3 Check with them after completion of test to ensure the fire alarm signal was received
  - 2.4 Advise the monitoring station that the system has been reset

### 3. BATTERY CONDITION

- 3.1 Check the battery voltage
  - 3.2 Check the battery condition

## 4 SWITCHES

- 4.1 Ensure that all switches are in the correct operating condition after completion of tests
  - 4.2 Take immediate steps to rectify the fault(s) should they exist

## 5. DEFECTS

- 5.1 Record in the log any fault(s) identified and that the above test has been carried out

Block No :

REMARKS

Name & signature of Technician(s)

Verified By :

1 Df

(Name & signature)

2 \_\_\_\_\_

RED-POWER ELECTRICAL ENGINEERING PTE LTD

BLK 16 DEFU LANE 10, #01 - 364, SINGAPORE 539197

TEL : 6 289 2298 FAX : 6 287 9635

TOWN COUNCIL	<u>NEE SOON TOWN COUNCIL</u>
LOCATION	<u>NEE SOON EAST DIVISION</u>
DATE OF SERVICING	 /09/2025

## WEEKLY FIRE ALARM CHECKLIST REPORT

## 1. SIMULATED TEST

- 1.1 Carry out a stimulated fire alarm call
  - 1.2 Operate any Alarm Zone
  - 1.3 Transmit a Fire Alarm Signal to the monitoring station and reset the system

## 2. MONITORING STATION

- 2.1 Contact the monitoring system prior to the transmitting of the fire alarm signal
  - 2.2 To warn them of the simulated fire condition to be tested
  - 2.3 Check with them after completion of test to ensure the fire alarm signal was received
  - 2.4 Advise the monitoring station that the system has been reset

### 3 BATTERY CONDITION

- 3.1 Check the battery voltage
  - 3.2 Check the battery conditions

## 4 SWITCHES

- 4.1 Ensure that all switches are in the correct operating condition after completion of tests
  - 4.2 Take immediate steps to rectify the fault(s) should they exist

5. DEFECTS

  - 5.1 Record in the log any fault(s) identified and that the above test has been carried out

**Block No :**

REMARKS

Name & signature of Technician(s)

Verified By :

1 RK

(Name & signature)

2

**RED-POWER ELECTRICAL ENGINEERING PTE LTD**  
BLK 16 DEFU LANE 10. #01 - 364. SINGAPORE 539197  
TEL : 6 289 2298 FAX : 6 287 9635

TOWN COUNCIL	<u>NEE SOON TOWN COUNCIL</u>
LOCATION	<u>NEE SOON EAST DIVISION</u>
DATE OF SERVICING	<u>11 /09/2025</u>

## WEEKLY FIRE ALARM CHECKLIST REPORT

## 1. SIMULATED TEST

- 1.1 Carry out a stimulated fire alarm call
  - 1.2 Operate any Alarm Zone
  - 1.3 Transmit a Fire Alarm Signal to the monitoring station and reset the system

## 2. MONITORING STATION

- 2.1 Contact the monitoring system prior to the transmitting of the fire alarm signal
  - 2.2 To warn them of the simulated fire condition to be tested
  - 2.3 Check with them after completion of test to ensure the fire alarm signal was received
  - 2.4 Advise the monitoring station that the system has been reset

### 3 BATTERY CONDITION

- 3.1 Check the battery voltage  
3.2 Check the battery condition

4 SWITCHES

- 4.1 Ensure that all switches are in the correct operating condition after completion of tests
  - 4.2 Take immediate steps to rectify the fault(s) should they exist

5. DEFECTS

5.1 Record in the log any fault(s) identified and that the above test has been carried out.

### 3.1 Record

Block No :

REMARKS

Name & signature of Technician(s)

Verified By :

1 Rff

(Name & signature)

2

RED-POWER ELECTRICAL ENGINEERING PTE LTD

BLK 16 DEFU LANE 10. #01 - 364. SINGAPORE 539197

TEL : 6 289 2298 FAX : 6 287 9635

TOWN COUNCIL	<u>NEE SOON TOWN COUNCIL</u>
LOCATION	<u>NEE SOON EAST DIVISION</u>
DATE OF SERVICING	<u>11 /09/2025</u>

## WEEKLY FIRE ALARM CHECKLIST REPORT

## 1. SIMULATED TEST

- 1.1 Carry out a stimulated fire alarm call
  - 1.2 Operate any Alarm Zone
  - 1.3 Transmit a Fire Alarm Signal to the monitoring station and reset the system

## 2. MONITORING STATION

- 2.1 Contact the monitoring system prior to the transitting of the fire alarm signal
  - 2.2 To warn them of the simulated fire condition to be tested
  - 2.3 Check with them after completion of test to ensure the fire alarm signal was received
  - 2.4 Advise the monitoring station that the systm has been reset

### 3. BATTERY CONDITION

- 3.1 Check the battery voltage
  - 3.2 Check the battery conditions

4 SWITCHES

- 4.1 Ensure that all switches are in the correct operating condition after completion of tests
  - 4.2 Take immediate steps to rectify the fault(s) should they exist

## 5. DEFECTS

- 5.1 Record in the log any fault(s) identified and that the above test has been carried out

Block No :

REMARKS

Name & signature of Technician(s)

Verified By :

1 Rf

(Name & signature)

2 \_\_\_\_\_

RED-POWER ELECTRICAL ENGINEERING PTE LTD

BLK 16 DEFU LANE 10. #01 - 364. SINGAPORE 539197

TEL : 6 289 2298 FAX : 6 287 9635

TOWN COUNCIL      NEE SOON TOWN COUNCIL

LOCATION      NEE SOON EAST DIVISION

DATE OF SERVICING 12 ~~09~~ /09/2025

## WEEKLY FIRE ALARM CHECKLIST REPORT

## 1. SIMULATED TEST

- 1.1 Carry out a stimulated fire alarm call
  - 1.2 Operate any Alarm Zone
  - 1.3 Transmit a Fire Alarm Signal to the monitoring station and reset the system

## 2. MONITORING STATION

- 2.1 Contact the monitoring system prior to the transmitting of the fire alarm signal
  - 2.2 To warn them of the simulated fire condition to be tested
  - 2.3 Check with them after completion of test to ensure the fire alarm signal was received
  - 2.4 Advise the monitoring station that the system has been reset

### 3. BATTERY CONDITION

- 3.1 Check the battery voltage
  - 3.2 Check the battery conditions

4 SWITCHES

- 4.1 Ensure that all switches are in the correct operating condition after completion of tests
  - 4.2 Take immediate steps to rectify the fault(s) should they exist

5. DEFECTS

## 5.1 Record

Block No :

REMARKS

Name & signature of Technician(s)

Verified By :

1 Thf.

(Name & signature)

2

RED-POWER ELECTRICAL ENGINEERING PTE LTD

BLK 16 DEFU LANE 10. #01 - 364. SINGAPORE 539197

TEL : 6 289 2298 FAX : 6 287 9635

NEE SOON TOWN COUNCIL

**LOCATION NEE SOON EAST DIVISION**

DATE OF SERVICING 12 /09/2025

[View Details](#) | [Edit](#) | [Delete](#)

## WEEKLY FIRE ALARM CHECKLIST REPORT

## 1. SIMULATED TEST

- 1.1 Carry out a stimulated fire alarm call
  - 1.2 Operate any Alarm Zone
  - 1.3 Transmit a Fire Alarm Signal to the monitoring station and reset the system

## 2. MONITORING STATION

- 2.1 Contact the monitoring system prior to the transmitting of the fire alarm signal
  - 2.2 To warn them of the simulated fire condition to be tested
  - 2.3 Check with them after completion of test to ensure the fire alarm signal was received
  - 2.4 Advise the monitoring station that the system has been reset

### 3 BATTERY CONDITION

- ### 3.1 Check the battery voltage

### 5.2 CHECK THE

- 4. SWITCHES
    - 4.1 Ensure that all switches are in the correct operating condition after completion of tests
    - 4.2 Take immediate steps to rectify the fault(s) should they exist
  - 5. DEFECTS
    - 5.1 Record in the log any fault(s) identified and that the above test has been carried out

Block No :

**REMARKS**

Name & signature of Technician(s)

Verified By :

1

(Name & signature)

2

RED-POWER ELECTRICAL ENGINEERING PTE LTD  
BLK 16 DEFU LANE 10. #01 - 364. SINGAPORE 539197  
TEL : 6 289 2298 FAX : 6 287 9635

TOWN COUNCIL	<u>NEE SOON TOWN COUNCIL</u>
LOCATION	<u>NEE SOON EAST DIVISION</u>
DATE OF SERVICING	<u>12 /09/2025</u>

## WEEKLY FIRE ALARM CHECKLIST REPORT

## 1. SIMULATED TEST

- 1.1 Carry out a stimulated fire alarm call
  - 1.2 Operate any Alarm Zone
  - 1.3 Transmit a Fire Alarm Signal to the monitoring station and reset the system
  2. MONITORING STATION
    - 2.1 Contact the monitoring system prior to the transitting of the fire alarm signal
    - 2.2 To warn them of the simulated fire condition to be tested
    - 2.3 Check with them after completion of test to ensure the fire alarm signal was received
    - 2.4 Advise the monitoring station that the systm has been reset
  3. BATTERY CONDITION
    - 3.1 Check the battery voltage
    - 3.2 Check the battery conditions
  4. SWITCHES
    - 4.1 Ensure that all switches are in the correct operating condition after completion of test
    - 4.2 Take immediate steps to rectify the fault(s) should they exist
  5. DEFECTS
    - 5.1 Record in the log any fault(s) identified and that the above test has been carried out

Block No :

REMARKS

Name & signature of Technician(s)

Verified By :

1 Pf.

(Name & signature)

2 \_\_\_\_\_

RED-POWER ELECTRICAL ENGINEERING PTE LTD  
BLK 16 DEFU LANE 10. #01 - 364. SINGAPORE 539197  
TEL : 6 289 2298 FAX : 6 287 9635

TOWN COUNCIL	<u>NEE SOON TOWN COUNCIL</u>
LOCATION	<u>NEE SOON EAST DIVISION</u>
DATE OF SERVICING	<u>15/09/2025</u>

## WEEKLY FIRE ALARM CHECKLIST REPORT

## 1. SIMULATED TEST

- 1.1 Carry out a stimulated fire alarm call
  - 1.2 Operate any Alarm Zone
  - 1.3 Transmit a Fire Alarm Signal to the monitoring station and reset the system

## 2. MONITORING STATION

- 2.1 Contact the monitoring system prior to the transmitting of the fire alarm signal
  - 2.2 To warn them of the simulated fire condition to be tested
  - 2.3 Check with them after completion of test to ensure the fire alarm signal was received
  - 2.4 Advise the monitoring station that the system has been reset

### 3 BATTERY CONDITION

- ### 3.1 Check the battery voltage

4 SWITCHES

- 4.1 Ensure that all switches are in the correct operating condition after completion of tests
  - 4.2 Take immediate steps to rectify the fault(s) should they exist

5. DEFECTS

  - 5.1 Record in the log any fault(s) identified and that the above test has been carried out

Block No :

**REMARKS**

Name & signature of Technician(s)

Verified By :

dkf.

(Name & signature)

2

RED-POWER ELECTRICAL ENGINEERING PTE LTD

BLK 16 DEFU LANE 10. #01 - 364. SINGAPORE 539197

TEL : 6 289 2298 FAX : 6 287 9635

TOWN COUNCIL	<u>NEE SOON TOWN COUNCIL</u>
LOCATION	<u>NEE SOON EAST DIVISION</u>
DATE OF SERVICING	<u>15 /09/2025</u>

## WEEKLY FIRE ALARM CHECKLIST REPORT

## 1. SIMULATED TEST

- 1.1 Carry out a stimulated fire alarm call
  - 1.2 Operate any Alarm Zone
  - 1.3 Transmit a Fire Alarm Signal to the monitoring station and reset the system

## 2. MONITORING STATION

- 2.1 Contact the monitoring system prior to the transmitting of the fire alarm signal
  - 2.2 To warn them of the simulated fire condition to be tested
  - 2.3 Check with them after completion of test to ensure the fire alarm signal was received

## 2.4 Advise the monitor

- ### 3. BATTERY CONDITION

#### 3.1 Check the battery voltage

### 3.2 Check the

- 4. SWITCHES**

4.1 Ensure that all switches are in the correct operating condition after completion of tests

4.2 Take immediate steps to rectify the fault(s) should they exist

**5. DEFECTS**

5.1 Record in the log any fault(s) identified and that the above test has been completed.

Block No :

REMARKS

Name & signature of Technician(s)

Verified By :

1

(Name & signature)

2 \_\_\_\_\_

RED-POWER ELECTRICAL ENGINEERING PTE LTD

BLK 16 DEFU LANE 10. #01 - 364. SINGAPORE 539197

TEL : 6 289 2298 FAX : 6 287 9635

TOWN COUNCIL	<u>NEE SOON TOWN COUNCIL</u>
LOCATION	<u>NEE SOON EAST DIVISION</u>
DATE OF SERVICING	<u>16 /09/2025</u>

## WEEKLY FIRE ALARM CHECKLIST REPORT

## 1. SIMULATED TEST

- 1.1 Carry out a stimulated fire alarm call
  - 1.2 Operate any Alarm Zone
  - 1.3 Transmit a Fire Alarm Signal to the monitoring station and reset the system

## 2. MONITORING STATION

- 2.1 Contact the monitoring system prior to the transmitting of the fire alarm signal
  - 2.2 To warn them of the simulated fire condition to be tested
  - 2.3 Check with them after completion of test to ensure the fire alarm signal was received
  - 2.4 Advise the monitoring station that the system has been reset

### 3 BATTERY CONDITION

- 3.1 Check the battery voltage
  - 3.2 Check the battery condition

## 4 SWITCHES

- 4.1 Ensure that all switches are in the correct operating condition after completion of tests
  - 4.2 Take immediate steps to rectify the fault(s) should they exist

## 5. DEFECTS

- 5.1 Record in the log any fault(s) identified and that the above test has been carried out

Block No :

**REMARKS**

Name & signature of Technician(s)

Verified By :

1 Rlf

(Name & signature)

2

RED-POWER ELECTRICAL ENGINEERING PTE LTD

BLK 16 DEFU LANE 10. #01 - 364. SINGAPORE 539197

TEL : 6 289 2298 FAX : 6 287 9635

TOWN COUNCIL	<u>NEE SOON TOWN COUNCIL</u>
LOCATION	<u>NEE SOON EAST DIVISION</u>
DATE OF SERVICING	<u>16</u> /09/2025

## WEEKLY FIRE ALARM CHECKLIST REPORT

## 1. SIMULATED TEST

- 1.1 Carry out a stimulated fire alarm call
  - 1.2 Operate any Alarm Zone
  - 1.3 Transmit a Fire Alarm Signal to the monitoring station and reset the system

## 2. MONITORING STATION

- 2.1 Contact the monitoring system prior to the transmitting of the fire alarm signal
  - 2.2 To warn them of the simulated fire condition to be tested
  - 2.3 Check with them after completion of test to ensure the fire alarm signal was received
  - 2.4 Advise the monitoring station that the system has been reset

### 3. BATTERY CONDITION

- 3.1 Check the battery voltage
  - 3.2 Check the battery condition

## 4. SWITCHES

- 4.1 Ensure that all switches are in the correct operating condition after completion of tests.

WE TAKE IT

- 5.1 Record in the log any fault(s) identified and that the document has been checked.

Block No :

REMARKS

Name & signature of Technician(s)

Verified By :

1

(Name & signature)

2 \_\_\_\_\_

RED-POWER ELECTRICAL ENGINEERING PTE LTD  
BLK 16 DEFU LANE 10. #01 - 364. SINGAPORE 539197  
TEL : 6 289 2298 FAX : 6 287 9635

TOWN COUNCIL	<u>NEE SOON TOWN COUNCIL</u>
LOCATION	<u>NEE SOON EAST DIVISION</u>
DATE OF SERVICING	<u>16 /09/2025</u>

## WEEKLY FIRE ALARM CHECKLIST REPORT

## 1. SIMULATED TEST

- 1.1 Carry out a stimulated fire alarm call
  - 1.2 Operate any Alarm Zone
  - 1.3 Transmit a Fire Alarm Signal to the monitoring station and reset the system

## 2. MONITORING STATION

- 2.1 Contact the monitoring system prior to the transmitting of the fire alarm signal
  - 2.2 To warn them of the simulated fire condition to be tested
  - 2.3 Check with them after completion of test to ensure the fire alarm signal was received
  - 2.4 Advise the monitoring station that the system has been reset

### 3 BATTERY CONDITION

- ### 3.1 Check the battery voltage

### 3.2 CHECK THE

4. SWITCHES
    - 4.1 Ensure that all switches are in the correct operating condition after completion of tests
    - 4.2 Take immediate steps to rectify the fault(s) should they exist
  5. DEFECTS
    - 5.1 Record in the log any fault(s) identified and that the above test has been carried out

**Block No :**

REMARKS

Name & signature of Technician(s)

Verified By :

1 DH

(Name & signature)

2

RED-POWER ELECTRICAL ENGINEERING PTE LTD

BLK 16 DEFU LANE 10. #01 - 364. SINGAPORE 539197

TEL : 6 289 2298 FAX : 6 287 9635

TOWN COUNCIL	<u>NEE SOON TOWN COUNCIL</u>
LOCATION	<u>NEE SOON EAST DIVISION</u>
DATE OF SERVICING	<u>22/09/2025</u>

## WEEKLY FIRE ALARM CHECKLIST REPORT

## 1. SIMULATED TEST

- 1.1 Carry out a stimulated fire alarm call
  - 1.2 Operate any Alarm Zone
  - 1.3 Transmit a Fire Alarm Signal to the monitoring station and reset the system

## 2. MONITORING STATION

- 2.1 Contact the monitoring system prior to the transmitting of the fire alarm signal
  - 2.2 To warn them of the simulated fire condition to be tested
  - 2.3 Check with them after completion of test to ensure the fire alarm signal was received
  - 2.4 Advise the monitoring station that the system has been reset

### 3. BATTERY CONDITION

- 3.1 Check the battery voltage
  - 3.2 Check the battery conditions

4 SWITCHES

- 4.1 Ensure that all switches are in the correct operating condition after completion of tests
  - 4.2 Take immediate steps to rectify the fault(s) should they exist

5. DEFECTS

  - 5.1 Record in the log any fault(s) identified and that the above test has been carried out

**Block No :**

REMARKS

Name & signature of Technician(s)

Verified By :

1 Rf

(Name & signature)

2

**RED-POWER ELECTRICAL ENGINEERING PTE LTD**  
BLK 16 DEFU LANE 10. #01 - 364. SINGAPORE 539197  
TEL : 6 289 2298 FAX : 6 287 9635

TOWN COUNCIL	<u>NEE SOON TOWN COUNCIL</u>
LOCATION	<u>NEE SOON EAST DIVISION</u>
DATE OF SERVICING	<u>22/09/2025</u>

## WEEKLY FIRE ALARM CHECKLIST REPORT

## 1. SIMULATED TEST

- 1.1 Carry out a stimulated fire alarm call
  - 1.2 Operate any Alarm Zone
  - 1.3 Transmit a Fire Alarm Signal to the monitoring station and reset the system

## 2. MONITORING STATION

- 2.1 Contact the monitoring system prior to the transmitting of the fire alarm signal
  - 2.2 To warn them of the simulated fire condition to be tested
  - 2.3 Check with them after completion of test to ensure the fire alarm signal was received

#### 2.4 Advise the monitor

3. BATTERY CONDITION
    - 3.1 Check the battery voltage

### 3.2 Check the

4. SWITCHES
    - 4.1 Ensure that all switches are in the correct operating condition after completion of tests
    - 4.2 Take immediate steps to rectify the fault(s) should they exist
  5. DEFECTS
    - 5.1 Record in the log any fault(s) identified and that the above test has been carried out

Block No :

**REMARKS**

Name & signature of Technician(s)

Verified By :

1

(Name & signature)

2

RED-POWER ELECTRICAL ENGINEERING PTE LTD

BLK 16 DEFU LANE 10. #01 - 364. SINGAPORE 539197

TEL : 6 289 2298 FAX : 6 287 9635

TOWN COUNCIL	<u>NEE SOON TOWN COUNCIL</u>
LOCATION	<u>NEE SOON EAST DIVISION</u>
DATE OF SERVICING	<u>23 /09/2025</u>

## WEEKLY FIRE ALARM CHECKLIST REPORT

## 1. SIMULATED TEST

- 1.1 Carry out a stimulated fire alarm call
  - 1.2 Operate any Alarm Zone
  - 1.3 Transmit a Fire Alarm Signal to the monitoring station and reset the system

## 2. MONITORING STATION

- 2.1 Contact the monitoring system prior to the transmitting of the fire alarm signal
  - 2.2 To warn them of the simulated fire condition to be tested
  - 2.3 Check with them after completion of test to ensure the fire alarm signal was received
  - 2.4 Advise the monitoring station that the system has been reset

### 3. BATTERY CONDITION

- 3.1 Check the battery voltage
  - 3.2 Check the battery conditions

4 SWITCHES

- 4.1 Ensure that all switches are in the correct operating condition after completion of tests
  - 4.2 Take immediate steps to rectify the fault(s) should they exist

5. DEFECTS

## 5.1 Record

Block No :

REMARKS

Name & signature of Technician(s)

Verified By :

PL

(Name & signature)

2

RED-POWER ELECTRICAL ENGINEERING PTE LTD

BLK 16 DEFU LANE 10. #01 - 364. SINGAPORE 539197

TEL : 6 289 2298 FAX : 6 287 9635

TOWN COUNCIL	<u>NEE SOON TOWN COUNCIL</u>
LOCATION	<u>NEE SOON EAST DIVISION</u>
DATE OF SERVICING	<u>23/09/2025</u>

## WEEKLY FIRE ALARM CHECKLIST REPORT

## 1. SIMULATED TEST

- 1.1 Carry out a stimulated fire alarm call
  - 1.2 Operate any Alarm Zone
  - 1.3 Transmit a Fire Alarm Signal to the monitoring station and reset the system

## 2. MONITORING STATION

- 2.1 Contact the monitoring system prior to the transmitting of the fire alarm signal
  - 2.2 To warn them of the simulated fire condition to be tested .
  - 2.3 Check with them after completion of test to ensure the fire alarm signal was received

### 3. BATTERY CONDITION

- 3.1 Check the battery voltage
  - 3.2 Check the battery conditions

#### 4 SWITCHES

- 4.1 Ensure that all switches are in the correct operating condition after completion of tests
  - 4.2 Take immediate steps to rectify the fault(s) should they exist.

5 DEFECTS

- 5.1 Record in the log any fault(s) identified and that the above test has been carried out.

Block No :

REMARKS

Name & signature of Technician(s)

Verified By :

1

(Name & signature)

2 \_\_\_\_\_

RED-POWER ELECTRICAL ENGINEERING PTE LTD

BLK 16 DEFU LANE 10. #01 - 364. SINGAPORE 539197

TEL : 6 289 2298 FAX : 6 287 9635

**TOWN COUNCIL**      **NEE SOON TOWN COUNCIL**

LOCATION NEE SOON EAST DIVISION

DATE OF SERVICING 23/09/2025

## WEEKLY FIRE ALARM CHECKLIST REPORT

## 1. SIMULATED TEST

- 1.1 Carry out a stimulated fire alarm call
  - 1.2 Operate any Alarm Zone
  - 1.3 Transmit a Fire Alarm Signal to the monitoring station and reset the system

## 2. MONITORING STATION

- 2.1 Contact the monitoring system prior to the transmitting of the fire alarm signal
  - 2.2 To warn them of the simulated fire condition to be tested
  - 2.3 Check with them after completion of test to ensure the fire alarm signal was received
  - 2.4 Advise the monitoring station that the system has been reset

### 3 BATTERY CONDITION

- ### 3.1 Check the battery voltage

4. OUTCOMES

- 4.1 Ensure that all switches are in the correct operating condition after completion of tests

## 4.2 Take III

- ### 5. DEFECTS

Block No :

**REMARKS**

Name & signature of Technician(s)

Verified By :

1 PL

(Name & signature)

2

RED-POWER ELECTRICAL ENGINEERING PTE LTD

BLK 16 DEFU LANE 10. #01 - 364. SINGAPORE 539197

TEL : 6 289 2298 FAX : 6

FAX : 6 287 9635

TOWN COUNCIL	<u>NEE SOON TOWN COUNCIL</u>
LOCATION	<u>NEE SOON EAST DIVISION</u>
DATE OF SERVICING	<u>3/09/2025</u>

## WEEKLY PRESSURE TANK CHECKLIST REPORT

1. Test run of pumps
  2. Check pump and motor running condition
  3. Check coupling set, baseplate and spring isolator
  4. Check mechanical seal / gland-packing and bearings
  5. Check all pipe work, check valve, gate valve, expansion joint, strainer
  6. Check correct function of pump system in auto and manual mode
  7. Check control panel and electrical isolator
  8. Check electrical components in control panel
  9. Check all indicator lamps
  10. Check conduit and wiring
  11. Check electrode holder and sensor
  12. Check ball float valve / pilot valve and motorised valve
  13. Check pump running ampere
  14. Check pressure switch setting and pressure gauge

Block No :

REMARKS

Name & signature of Technician(s)

Verified By :

1 P. Mani Bhuj

(Name & signature)

2 \_\_\_\_\_

RED-POWER ELECTRICAL ENGINEERING PTE LTD

BLK 16 DEFU LANE 10. #01 - 364. SINGAPORE 539197

TEL : 6 289 2298 FAX : 6 287 9635

TOWN COUNCIL	<u>NEE SOON TOWN COUNCIL</u>
LOCATION	<u>NEE SOON EAST DIVISION</u>
DATE OF SERVICING	<u>3 /09/2025</u>

## WEEKLY PRESSURE TANK CHECKLIST REPORT

1. Test run of pumps
  2. Check pump and motor running condition
  3. Check coupling set, baseplate and spring isolator
  4. Check mechanical seal / gland-packing and bearings
  5. Check all pipe work, check valve, gate valve, expansion joint, strainer
  6. Check correct function of pump system in auto and manual mode
  7. Check control panel and electrical isolator
  8. Check electrical components in control panel
  9. Check all indicator lamps
  10. Check conduit and wiring
  11. Check electrode holder and sensor
  12. Check ball float valve / pilot valve and motorised valve
  13. Check pump running ampere
  14. Check pressure switch setting and pressure gauge

**Block No :**

REMARKS

Name & signature of Technician(s)

Verified By :

<sup>1</sup> Mani Shri

(Name & signature)

2

RED-POWER ELECTRICAL ENGINEERING PTE LTD

BLK 16 DEFU LANE 10. #01 - 364. SINGAPORE 539197

TEL : 6 289 2298 FAX : 6 287 9635

NEE SOON TOWN COUNCIL

## LOCATION

NEE SOON EAST DIVISION

**DATE OF SERVICING**

3 /09/2025

## WEEKLY PRESSURE TANK CHECKLIST REPORT

1. Test run of pumps
  2. Check pump and motor running condition
  3. Check coupling set, baseplate and spring isolator
  4. Check mechanical seal / gland-packing and bearings
  5. Check all pipe work, check valve, gate valve, expansion joint, strainer
  6. Check correct function of pump system in auto and manual mode
  7. Check control panel and electrical isolator
  8. Check electrical components in control panel
  9. Check all indicator lamps
  10. Check conduit and wiring
  11. Check electrode holder and sensor
  12. Check ball float valve / pilot valve and motorised valve
  13. Check pump running ampere
  14. Check pressure switch setting and pressure gauge

**Block No :**

Manus

RED-POWER ELECTRICAL ENGINEERING PTE LTD

BLK 16 DEFU LANE 10. #01 - 364. SINGAPORE 539197

TEL : 6 289 2298 FAX : 6 287 9635

TOWN COUNCIL	NEE SOON TOWN COUNCIL
LOCATION	NEE SOON EAST DIVISION
DATE OF SERVICING	 /09/2025

## WEEKLY PRESSURE TANK CHECKLIST REPORT

1. Test run of pumps
  2. Check pump and motor running condition
  3. Check coupling set, baseplate and spring isolator
  4. Check mechanical seal / gland-packing and bearings
  5. Check all pipe work, check valve, gate valve, expansion joint, strainer
  6. Check correct function of pump system in auto and manual mode
  7. Check control panel and electrical isolator
  8. Check electrical components in control panel
  9. Check all indicator lamps
  10. Check conduit and wiring
  11. Check electrode holder and sensor
  12. Check ball float valve / pilot valve and motorised valve
  13. Check pump running ampere
  14. Check pressure switch setting and pressure gauge

Block No :

REMARKS

Name & signature of Technician(s)

Verified By :

<sup>1</sup> Mani Thij

(Name & signature)

2

RED-POWER ELECTRICAL ENGINEERING PTE LTD

BLK 16 DEFU LANE 10. #01 - 364. SINGAPORE 539197

TEL : 6 289 2298 FAX : 6 287 9635

www.elsevier.com

TOWN COUNCIL	<u>NEE SOON TOWN COUNCIL</u>
LOCATION	<u>NEE SOON EAST DIVISION</u>
DATE OF SERVICING	<u>21/09/2025</u>

## WEEKLY PRESSURE TANK CHECKLIST REPORT

1. Test run of pumps
  2. Check pump and motor running condition
  3. Check coupling set, baseplate and spring isolator
  4. Check mechanical seal / gland-packing and bearings
  5. Check all pipe work, check valve, gate valve, expansion joint, strainer
  6. Check correct function of pump system in auto and manual mode
  7. Check control panel and electrical isolator
  8. Check electrical components in control panel
  9. Check all indicator lamps
  10. Check conduit and wiring
  11. Check electrode holder and sensor
  12. Check ball float valve / pilot valve and motorised valve
  13. Check pump running ampere
  14. Check pressure switch setting and pressure gauge

Block No :

REMARKS

Name & signature of Technician(s)

Verified By :

<sup>1</sup> P. Mori Ohio

(Name & signature)

2

RED-POWER ELECTRICAL ENGINEERING PTE LTD

BLK 16 DEFU LANE 10. #01 - 364. SINGAPORE 539197

TEL : 6 289 2298 FAX : 6 287 9635

TOWN COUNCIL	<u>NEE SOON TOWN COUNCIL</u>
LOCATION	<u>NEE SOON EAST DIVISION</u>
DATE OF SERVICING	<u>2 /09/2025</u>

## WEEKLY PRESSURE TANK CHECKLIST REPORT

1. Test run of pumps
  2. Check pump and motor running condition
  3. Check coupling set, baseplate and spring isolator
  4. Check mechanical seal / gland-packing and bearings
  5. Check all pipe work, check valve, gate valve, expansion joint, strainer
  6. Check correct function of pump system in auto and manual mode
  7. Check control panel and electrical isolator
  8. Check electrical components in control panel
  9. Check all indicator lamps
  10. Check conduit and wiring
  11. Check electrode holder and sensor
  12. Check ball float valve / pilot valve and motorised valve
  13. Check pump running ampere
  14. Check pressure switch setting and pressure gauge

**Block No :**

REMARKS

~~REMARKS~~ BLK-269A - PT1 + PT2 SPO<sup>0</sup> 296A - PT1 + PT2 - SPO<sup>0</sup>

Name & signature of Technician(s)

Verified By :

1 Mami Alij

(Name & signature)

2

RED-POWER ELECTRICAL ENGINEERING PTE LTD

BLK 16 DEFU LANE 10. #01 - 364. SINGAPORE 539197

TEL : 6 289 2298

FAX : 6 287 9635

TOWN COUNCIL

NEE SOON TOWN COUNCIL

## LOCATION

NEE SOON EAST DIVISION

**DATE OF SERVICING**

3 /09/2025

## WEEKLY PRESSURE TANK CHECKLIST REPORT

1. Test run of pumps
  2. Check pump and motor running condition
  3. Check coupling set, baseplate and spring isolator
  4. Check mechanical seal / gland-packing and bearings
  5. Check all pipe work, check valve, gate valve, expansion joint, strainer
  6. Check correct function of pump system in auto and manual mode
  7. Check control panel and electrical isolator
  8. Check electrical components in control panel
  9. Check all indicator lamps
  10. Check conduit and wiring
  11. Check electrode holder and sensor
  12. Check ball float valve / pilot valve and motorised valve
  13. Check pump running ampere
  14. Check pressure switch setting and pressure gauge

Block No :

**REMARKS**

Name & signature of Technician(s)

Verified By :

1 Miami Ohio

(Name & signature)

2

RED-POWER ELECTRICAL ENGINEERING PTE LTD

BLK 16 DEFU LANE 10. #01 - 364. SINGAPORE 539197

TEL : 6 289 2298 FAX : 6 287 9635

FAX : 6 287 9635

TOWN COUNCIL

## NEE SOON TOWN COUNCIL

## LOCATION

NEE SOON EAST DIVISION

**DATE OF SERVICING**

9 /09/2025

## WEEKLY PRESSURE TANK CHECKLIST REPORT

1. Test run of pumps
  2. Check pump and motor running condition
  3. Check coupling set, baseplate and spring isolator
  4. Check mechanical seal / gland-packing and bearings
  5. Check all pipe work, check valve, gate valve, expansion joint, strainer
  6. Check correct function of pump system in auto and manual mode
  7. Check control panel and electrical isolator
  8. Check electrical components in control panel
  9. Check all indicator lamps
  10. Check conduit and wiring
  11. Check electrode holder and sensor
  12. Check ball float valve / pilot valve and motorised valve
  13. Check pump running ampere
  14. Check pressure switch setting and pressure gauge

**Block No :**

REMARKS

RKS  
PLK-269A, PT1 & PT2 - 3P01, 296A-PT1 & PT2 3P01

Name & signature of Technician(s)

Verified By :

1 Mani Brij

(Name & signature)

2

RED-POWER ELECTRICAL ENGINEERING PTE LTD

BLK 16 DEFU LANE 10. #01 - 364. SINGAPORE 539197

TEL : 6 289 2298 FAX : 6 287 9635

TOWN COUNCIL	<u>NEE SOON TOWN COUNCIL</u>
LOCATION	<u>NEE SOON EAST DIVISION</u>
DATE OF SERVICING	<u>9/09/2025</u>

## WEEKLY PRESSURE TANK CHECKLIST REPORT

1. Test run of pumps
  2. Check pump and motor running condition
  3. Check coupling set, baseplate and spring isolator
  4. Check mechanical seal / gland-packing and bearings
  5. Check all pipe work, check valve, gate valve, expansion joint, strainer
  6. Check correct function of pump system in auto and manual mode
  7. Check control panel and electrical isolator
  8. Check electrical components in control panel
  9. Check all indicator lamps
  10. Check conduit and wiring
  11. Check electrode holder and sensor
  12. Check ball float valve / pilot valve and motorised valve
  13. Check pump running ampere
  14. Check pressure switch setting and pressure gauge

**Block No :**

REMARKS

Name & signature of Technician(s)

Verified By :

<sup>1</sup> P. Mani Mri

(Name & signature)

2

RED-POWER ELECTRICAL ENGINEERING PTE LTD

BLK 16 DEFU LANE 10. #01 - 364. SINGAPORE 539197

TEL : 6 289 2298 FAX : 6 287 9635

TOWN COUNCIL	<u>NEE SOON TOWN COUNCIL</u>
LOCATION	<u>NEE SOON EAST DIVISION</u>
DATE OF SERVICING	<u>9/09/2025</u>

## WEEKLY PRESSURE TANK CHECKLIST REPORT

1. Test run of pumps
  2. Check pump and motor running condition
  3. Check coupling set, baseplate and spring isolator
  4. Check mechanical seal / gland-packing and bearings
  5. Check all pipe work, check valve, gate valve, expansion joint, strainer
  6. Check correct function of pump system in auto and manual mode
  7. Check control panel and electrical isolator
  8. Check electrical components in control panel
  9. Check all indicator lamps
  10. Check conduit and wiring
  11. Check electrode holder and sensor
  12. Check ball float valve / pilot valve and motorised valve
  13. Check pump running ampere
  14. Check pressure switch setting and pressure gauge

**Block No :**

REMARKS

Name & signature of Technician(s)

Verified By :

## 1 Mani ohni

(Name & signature)

2

RED-POWER ELECTRICAL ENGINEERING PTE LTD

BLK 16 DEFU LANE 10. #01 - 364. SINGAPORE 539197

TEL : 6 289 2298 FAX : 6 287 9635

TOWN COUNCIL                    NEE SOON TOWN COUNCIL  
LOCATION                        NEE SOON EAST DIVISION  
DATE OF SERVICING            10/09/2025

## WEEKLY PRESSURE TANK CHECKLIST REPORT

1. Test run of pumps
  2. Check pump and motor running condition
  3. Check coupling set, baseplate and spring isolator
  4. Check mechanical seal / gland-packing and bearings
  5. Check all pipe work, check valve, gate valve, expansion joint, strainer
  6. Check correct function of pump system in auto and manual mode
  7. Check control panel and electrical isolator
  8. Check electrical components in control panel
  9. Check all indicator lamps
  10. Check conduit and wiring
  11. Check electrode holder and sensor
  12. Check ball float valve / pilot valve and motorised valve
  13. Check pump running ampere
  14. Check pressure switch setting and pressure gauge

**Block No :**

**RED-POWER ELECTRICAL ENGINEERING PTE LTD**  
BLK 16 DEFU LANE 10. #01 - 364. SINGAPORE 53919  
TEL : 6 289 2298 FAX : 6 287 9635

TOWN COUNCIL	<u>NEE SOON TOWN COUNCIL</u>
LOCATION	<u>NEE SOON EAST DIVISION</u>
DATE OF SERVICING	<u>NO/09/2025</u>

## WEEKLY PRESSURE TANK CHECKLIST REPORT

1. Test run of pumps
  2. Check pump and motor running condition
  3. Check coupling set, baseplate and spring isolator
  4. Check mechanical seal / gland-packing and bearings
  5. Check all pipe work, check valve, gate valve, expansion joint, strainer
  6. Check correct function of pump system in auto and manual mode
  7. Check control panel and electrical isolator
  8. Check electrical components in control panel
  9. Check all indicator lamps
  10. Check conduit and wiring
  11. Check electrode holder and sensor
  12. Check ball float valve / pilot valve and motorised valve
  13. Check pump running ampere
  14. Check pressure switch setting and pressure gauge

**Block No :**

REMARKS

Name & signature of Technician(s)

Verified By :

1 Mani M.

(Name & signature)

2

RED-POWER ELECTRICAL ENGINEERING PTE LTD  
BLK 16 DEFU LANE 10. #01 - 364. SINGAPORE 539197  
TEL : 6 289 2298 FAX : 6 287 9635

TOWN COUNCIL  
LOCATION  
DATE OF SERVICING NEE SOON TOWN COUNCIL  
NEE SOON EAST DIVISION  
 /09/2025

## WEEKLY PRESSURE TANK CHECKLIST REPORT

- WATER PUMP CHECKLIST REPORT

  1. Test run of pumps
  2. Check pump and motor running condition
  3. Check coupling set, baseplate and spring isolator
  4. Check mechanical seal / gland-packing and bearings
  5. Check all pipe work, check valve, gate valve, expansion joint, strainer
  6. Check correct function of pump system in auto and manual mode
  7. Check control panel and electrical isolator
  8. Check electrical components in control panel
  9. Check all indicator lamps
  10. Check conduit and wiring
  11. Check electrode holder and sensor
  12. Check ball float valve / pilot valve and motorised valve
  13. Check pump running ampere
  14. Check pressure switch setting and pressure gauge

Block No :

REMARKS

Name & signature of Technician(s)

Verified By :

<sup>1</sup> P. Mani Phij

(Name & signature)

2

RED-POWER ELECTRICAL ENGINEERING PTE LTD

BLK 16 DEFU LANE 10. #01 - 364. SINGAPORE 539197

TEL : 6 289 2298 FAX : 6 287 9635

FAX : 6 287 9635

**TOWN COUNCIL**      **NEE SOON TOWN COUNCIL**

LOCATION NEE SOON EAST DIVISION

DATE OF SERVICING 10/09/2025

## WEEKLY PRESSURE TANK CHECKLIST REPORT

1. Test run of pumps
  2. Check pump and motor running condition
  3. Check coupling set, baseplate and spring isolator
  4. Check mechanical seal / gland-packing and bearings
  5. Check all pipe work, check valve, gate valve, expansion joint, strainer
  6. Check correct function of pump system in auto and manual mode
  7. Check control panel and electrical isolator
  8. Check electrical components in control panel
  9. Check all indicator lamps
  10. Check conduit and wiring
  11. Check electrode holder and sensor
  12. Check ball float valve / pilot valve and motorised valve
  13. Check pump running ampere
  14. Check pressure switch setting and pressure gauge

**Block No :**

REMARKS

Name & signature of Technician(s)

Verified By :

1 Mani Mai

(Name & signature)

2 \_\_\_\_\_



RED-POWER ELECTRICAL ENGINEERING PTE LTD

BLK 16 DEFU LANE 10. #01 - 364. SINGAPORE 539197

TEL : 6 289 2298 FAX : 6 287 9635

FAX : 6 287 9635

## TOWN COUNCIL

NEE SOON TOWN COUNCIL

## LOCATION

NEE SOON EAST DIVISION

**DATE OF SERVICING**

16 /09/2025

## WEEKLY PRESSURE TANK CHECKLIST REPORT

1. Test run of pumps
  2. Check pump and motor running condition
  3. Check coupling set, baseplate and spring isolator
  4. Check mechanical seal / gland-packing and bearings
  5. Check all pipe work, check valve, gate valve, expansion joint, strainer
  6. Check correct function of pump system in auto and manual mode
  7. Check control panel and electrical isolator
  8. Check electrical components in control panel
  9. Check all indicator lamps
  10. Check conduit and wiring
  11. Check electrode holder and sensor
  12. Check ball float valve / pilot valve and motorised valve
  13. Check pump running ampere
  14. Check pressure switch setting and pressure gauge

**Block No :**

REMARKS

REMARKS Bk 2bq A- PT1 + PT2 Spoil, 296 A- PT1 + PT2 Spoil.

Name & signature of Technician(s)

Verified By :

<sup>1</sup> Mami Phi

(Name & signature)

2

RED-POWER ELECTRICAL ENGINEERING PTE LTD

BLK 16 DEFU LANE 10. #01 - 364. SINGAPORE 539197

TEL : 6 289 2298 FAX : 6 287 9635

TOWN COUNCIL	<u>NEE SOON TOWN COUNCIL</u>
LOCATION	<u>NEE SOON EAST DIVISION</u>
DATE OF SERVICING	<u>16 /09/2025</u>

## WEEKLY PRESSURE TANK CHECKLIST REPORT

1. Test run of pumps
  2. Check pump and motor running condition
  3. Check coupling set, baseplate and spring isolator
  4. Check mechanical seal / gland-packing and bearings
  5. Check all pipe work, check valve, gate valve, expansion joint, strainer
  6. Check correct function of pump system in auto and manual mode
  7. Check control panel and electrical isolator
  8. Check electrical components in control panel
  9. Check all indicator lamps
  10. Check conduit and wiring
  11. Check electrode holder and sensor
  12. Check ball float valve / pilot valve and motorised valve
  13. Check pump running ampere
  14. Check pressure switch setting and pressure gauge

**Block No :**

REMARKS

Name & signature of Technician(s)

Verified By :

<sup>1</sup> P. N. omi ohi

(Name & signature)

2 \_\_\_\_\_

RED-POWER ELECTRICAL ENGINEERING PTE LTD

BLK 16 DEFU LANE 10. #01 - 364. SINGAPORE 539197

TEL : 6 289 2298

FAX : 6 287 9635

## TOWN COUNCIL

## NEE SOON TOWN COUNCIL

## LOCATION

NEE SOON EAST DIVISION

**DATE OF SERVICING**

16 /09/2025

## WEEKLY PRESSURE TANK CHECKLIST REPORT

1. Test run of pumps
  2. Check pump and motor running condition
  3. Check coupling set, baseplate and spring isolator
  4. Check mechanical seal / gland-packing and bearings
  5. Check all pipe work, check valve, gate valve, expansion joint, strainer
  6. Check correct function of pump system in auto and manual mode
  7. Check control panel and electrical isolator
  8. Check electrical components in control panel
  9. Check all indicator lamps
  10. Check conduit and wiring
  11. Check electrode holder and sensor
  12. Check ball float valve / pilot valve and motorised valve
  13. Check pump running ampere
  14. Check pressure switch setting and pressure gauge

Block No :

REMARKS

Name & signature of Technician(s)

Verified By :

<sup>1</sup> Miami Mij

(Name & signature)

2

RED-POWER ELECTRICAL ENGINEERING PTE LTD

BLK 16 DEFU LANE 10. #01 - 364. SINGAPORE 539197

TEL : 6 289 2298 FAX : 6 287 9635

TOWN COUNCIL	<u>NEE SOON TOWN COUNCIL</u>
LOCATION	<u>NEE SOON EAST DIVISION</u>
DATE OF SERVICING	17/09/2025

## WEEKLY PRESSURE TANK CHECKLIST REPORT

1. Test run of pumps
  2. Check pump and motor running condition
  3. Check coupling set, baseplate and spring isolator
  4. Check mechanical seal / gland-packing and bearings
  5. Check all pipe work, check valve, gate valve, expansion joint, strainer
  6. Check correct function of pump system in auto and manual mode
  7. Check control panel and electrical isolator
  8. Check electrical components in control panel
  9. Check all indicator lamps
  10. Check conduit and wiring
  11. Check electrode holder and sensor
  12. Check ball float valve / pilot valve and motorised valve
  13. Check pump running ampere
  14. Check pressure switch setting and pressure gauge

**Block No :**

RED-POWER ELECTRICAL ENGINEERING PTE LTD

BLK 16 DEFU LANE 10. #01 - 364. SINGAPORE 539197

TEL : 6 289 2298 FAX : 6 287 9635

TOWN COUNCIL	<u>NEE SOON TOWN COUNCIL</u>
LOCATION	<u>NEE SOON EAST DIVISION</u>
DATE OF SERVICING	<u>17/09/2025</u>

## WEEKLY PRESSURE TANK CHECKLIST REPORT

1. Test run of pumps
  2. Check pump and motor running condition
  3. Check coupling set, baseplate and spring isolator
  4. Check mechanical seal / gland-packing and bearings
  5. Check all pipe work, check valve, gate valve, expansion joint, strainer
  6. Check correct function of pump system in auto and manual mode
  7. Check control panel and electrical isolator
  8. Check electrical components in control panel
  9. Check all indicator lamps
  10. Check conduit and wiring
  11. Check electrode holder and sensor
  12. Check ball float valve / pilot valve and motorised valve
  13. Check pump running ampere
  14. Check pressure switch setting and pressure gauge

**Block No :**

REMARKS

Name & signature of Technician(s)

Verified By :

1 Miami Mari

(Name & signature)

2

RED-POWER ELECTRICAL ENGINEERING PTE LTD

BLK 16 DEFU LANE 10. #01 - 364. SINGAPORE 539197

TEL : 6 289 2298 FAX : 6 287 9635

TOWN COUNCIL	<u>NEE SOON TOWN COUNCIL</u>
LOCATION	<u>NEE SOON EAST DIVISION</u>
DATE OF SERVICING	<u>17/09/2025</u>

## WEEKLY PRESSURE TANK CHECKLIST REPORT

1. Test run of pumps
  2. Check pump and motor running condition
  3. Check coupling set, baseplate and spring isolator
  4. Check mechanical seal / gland-packing and bearings
  5. Check all pipe work, check valve, gate valve, expansion joint, strainer
  6. Check correct function of pump system in auto and manual mode
  7. Check control panel and electrical isolator
  8. Check electrical components in control panel
  9. Check all indicator lamps
  10. Check conduit and wiring
  11. Check electrode holder and sensor
  12. Check ball float valve / pilot valve and motorised valve
  13. Check pump running ampere
  14. Check pressure switch setting and pressure gauge

**Block No :**

REMARKS

Name & signature of Technician(s)

Verified By :

1 P. Nani Mji

(Name & signature)

2 \_\_\_\_\_

RED-POWER ELECTRICAL ENGINEERING PTE LTD

BLK 16 DEFU LANE 10. #01 - 364. SINGAPORE 539197

TEL : 6 289 2298

FAX : 6 287 9635

TOWN COUNCIL

NEE SOON TOWN COUNCIL

LOCATION

NEE SOON EAST DIVISION

DATE OF SERVICING

17/09/2025

WEEKLY PRESSURE TANK CHECKLIST REPORT

1. Test run of pumps
2. Check pump and motor running condition
3. Check coupling set, baseplate and spring isolator
4. Check mechanical seal / gland-packing and bearings
5. Check all pipe work, check valve, gate valve, expansion joint, strainer
6. Check correct function of pump system in auto and manual mode
7. Check control panel and electrical isolator
8. Check electrical components in control panel
9. Check all indicator lamps
10. Check conduit and wiring
11. Check electrode holder and sensor
12. Check ball float valve / pilot valve and motorised valve
13. Check pump running ampere
14. Check pressure switch setting and pressure gauge

Block No :

384A	384B	-	-	-	-	-	-	-	-
✓	✓	-	-	-	-	-	-	-	-
✓	✓	-	-	-	-	-	-	-	-
✓	✓	-	-	-	-	-	-	-	-
✓	✓	-	-	-	-	-	-	-	-
✓	✓	-	-	-	-	-	-	-	-
✓	✓	-	-	-	-	-	-	-	-
✓	✓	-	-	-	-	-	-	-	-
✓	✓	-	-	-	-	-	-	-	-
✓	✓	-	-	-	-	-	-	-	-
✓	✓	-	-	-	-	-	-	-	-
✓	✓	-	-	-	-	-	-	-	-
✓	✓	-	-	-	-	-	-	-	-
✓	✓	-	-	-	-	-	-	-	-
✓	✓	-	-	-	-	-	-	-	-
35 40		-	-	-	-	-	-	-	-
✓	✓	-	-	-	-	-	-	-	-

REMARKS

Name & signature of Technician(s)

Verified By :

1 P. Mami Neni

\_\_\_\_\_

(Name & signature)

2 \_\_\_\_\_

RED-POWER ELECTRICAL ENGINEERING PTE LTD

BLK 16 DEFU LANE 10. #01 - 364. SINGAPORE 539197

TEL : 6 289 2298 FAX : 6 287 9635

FAX : 6 287 9635

TOWN COUNCIL	<u>NEE SOON TOWN COUNCIL</u>
LOCATION	<u>NEE SOON EAST DIVISION</u>
DATE OF SERVICING	<u>23 /09/2025</u>

## WEEKLY PRESSURE TANK CHECKLIST REPORT

1. Test run of pumps
  2. Check pump and motor running condition
  3. Check coupling set, baseplate and spring isolator
  4. Check mechanical seal / gland-packing and bearings
  5. Check all pipe work, check valve, gate valve, expansion joint, strainer
  6. Check correct function of pump system in auto and manual mode
  7. Check control panel and electrical isolator
  8. Check electrical components in control panel
  9. Check all indicator lamps
  10. Check conduit and wiring
  11. Check electrode holder and sensor
  12. Check ball float valve / pilot valve and motorised valve
  13. Check pump running ampere
  14. Check pressure switch setting and pressure gauge

**Block No :**

REMARKS

REMARKS BK-269A - PT1 & P<sub>100</sub> spoil, 296A - PT1 + PT8 spoil.

Name & signature of Technician(s)

Verified By :

## 1 P.Nani ahri

(Name & signature)

2

RED-POWER ELECTRICAL ENGINEERING PTE LTD

BLK 16 DEFU LANE 10. #01 - 364. SINGAPORE 539197

TEL : 6 289 2298

FAX : 6 287 9635

## TOWN COUNCIL

## NEE SOON TOWN COUNCIL

## LOCATION

NEE SOON EAST DIVISION

**DATE OF SERVICING**

23 /09/2025

## WEEKLY PRESSURE TANK CHECKLIST REPORT

1. Test run of pumps
  2. Check pump and motor running condition
  3. Check coupling set, baseplate and spring isolator
  4. Check mechanical seal / gland-packing and bearings
  5. Check all pipe work, check valve, gate valve, expansion joint, strainer
  6. Check correct function of pump system in auto and manual mode
  7. Check control panel and electrical isolator
  8. Check electrical components in control panel
  9. Check all indicator lamps
  10. Check conduit and wiring
  11. Check electrode holder and sensor
  12. Check ball float valve / pilot valve and motorised valve
  13. Check pump running ampere
  14. Check pressure switch setting and pressure gauge

**Block No :**

**REMARKS**

Name & signature of Technician(s)

Verified By :

1 P. Mani Meij

(Name & signature)

2

RED-POWER ELECTRICAL ENGINEERING PTE LTD

BLK 16 DEFU LANE 10. #01 - 364. SINGAPORE 539197

TEL : 6 289 2298 FAX : 6 287 9635

FAX : 6 287 9635

## TOWN COUNCIL

NEE SOON TOWN COUNCIL

## LOCATION

NEE SOON EAST DIVISION

**DATE OF SERVICING**

23 /09/2025

## WEEKLY PRESSURE TANK CHECKLIST REPORT

1. Test run of pumps
  2. Check pump and motor running condition
  3. Check coupling set, baseplate and spring isolator
  4. Check mechanical seal / gland-packing and bearings
  5. Check all pipe work, check valve, gate valve, expansion joint, strainer
  6. Check correct function of pump system in auto and manual mode
  7. Check control panel and electrical isolator
  8. Check electrical components in control panel
  9. Check all indicator lamps
  10. Check conduit and wiring
  11. Check electrode holder and sensor
  12. Check ball float valve / pilot valve and motorised valve
  13. Check pump running ampere
  14. Check pressure switch setting and pressure gauge

**Block No :**

**REMARKS**

Name & signature of Technician(s)

Verified By :

<sup>1</sup> P. Nomi obj

(Name & signature)

2

RED-POWER ELECTRICAL ENGINEERING PTE LTD

BLK 16 DEFU LANE 10. #01 - 364. SINGAPORE 539197

TEL : 6 289 2298 FAX : 6 287 9635

TOWN COUNCIL	<u>NEE SOON TOWN COUNCIL</u>
LOCATION	<u>NEE SOON EAST DIVISION</u>
DATE OF SERVICING	<u>24 /09/2025</u>

## WEEKLY PRESSURE TANK CHECKLIST REPORT

1. Test run of pumps
  2. Check pump and motor running condition
  3. Check coupling set, baseplate and spring isolator
  4. Check mechanical seal / gland-packing and bearings
  5. Check all pipe work, check valve, gate valve, expansion joint, strainer
  6. Check correct function of pump system in auto and manual mode
  7. Check control panel and electrical isolator
  8. Check electrical components in control panel
  9. Check all indicator lamps
  10. Check conduit and wiring
  11. Check electrode holder and sensor
  12. Check ball float valve / pilot valve and motorised valve
  13. Check pump running ampere
  14. Check pressure switch setting and pressure gauge

**Block No :**

RED-POWER ELECTRICAL ENGINEERING PTE LTD

BLK 16 DEFU LANE 10. #01 - 364. SINGAPORE 539197

TEL : 6 289 2298 FAX : 6 287 9635

FAX : 6 287 9635

## TOWN COUNCIL

## NEE SOON TOWN COUNCIL

## LOCATION

NEE SOON EAST DIVISION

**DATE OF SERVICING**

24 09/2025

## WEEKLY PRESSURE TANK CHECKLIST REPORT

1. Test run of pumps
  2. Check pump and motor running condition
  3. Check coupling set, baseplate and spring isolator
  4. Check mechanical seal / gland-packing and bearings
  5. Check all pipe work, check valve, gate valve, expansion joint, strainer
  6. Check correct function of pump system in auto and manual mode
  7. Check control panel and electrical isolator
  8. Check electrical components in control panel
  9. Check all indicator lamps
  10. Check conduit and wiring
  11. Check electrode holder and sensor
  12. Check ball float valve / pilot valve and motorised valve
  13. Check pump running ampere
  14. Check pressure switch setting and pressure gauge

**Block No :**

REMARKS

Name & signature of Technician(s)

Verified By :

<sup>1</sup> P-Mami Ami

(Name & signature)

2

RED-POWER ELECTRICAL ENGINEERING PTE LTD

BLK 16 DEFU LANE 10. #01 - 364. SINGAPORE 539197

TEL : 6 289 2298 FAX :

FAX : 6 287 9635

## TOWN COUNCIL

## NEE SOON TOWN COUNCIL

## LOCATION

NEE SOON EAST DIVISION

**DATE OF SERVICING**

24 /09/2025

## WEEKLY PRESSURE TANK CHECKLIST REPORT

1. Test run of pumps
  2. Check pump and motor running condition
  3. Check coupling set, baseplate and spring isolator
  4. Check mechanical seal / gland-packing and bearings
  5. Check all pipe work, check valve, gate valve, expansion joint, strainer
  6. Check correct function of pump system in auto and manual mode
  7. Check control panel and electrical isolator
  8. Check electrical components in control panel
  9. Check all indicator lamps
  10. Check conduit and wiring
  11. Check electrode holder and sensor
  12. Check ball float valve / pilot valve and motorised valve
  13. Check pump running ampere
  14. Check pressure switch setting and pressure gauge

**Block No :**

**REMARKS**

Name & signature of Technician(s)

Verified By :

1 P.Mani Nthi

(Name & signature)

2

RED-POWER ELECTRICAL ENGINEERING PTE LTD

BLK 16 DEFU LANE 10. #01 - 364. SINGAPORE 539197

TEL : 6 289 2298 FAX : 6 287 9635

FAX : 6 287 9635

## TOWN COUNCIL

## NEE SOON TOWN COUNCIL

## LOCATION

NEE SOON EAST DIVISION

**DATE OF SERVICING**

20/09/2025

## WEEKLY PRESSURE TANK CHECKLIST REPORT

1. Test run of pumps
  2. Check pump and motor running condition
  3. Check coupling set, baseplate and spring isolator
  4. Check mechanical seal / gland-packing and bearings
  5. Check all pipe work, check valve, gate valve, expansion joint, strainer
  6. Check correct function of pump system in auto and manual mode
  7. Check control panel and electrical isolator
  8. Check electrical components in control panel
  9. Check all indicator lamps
  10. Check conduit and wiring
  11. Check electrode holder and sensor
  12. Check ball float valve / pilot valve and motorised valve
  13. Check pump running ampere
  14. Check pressure switch setting and pressure gauge

**Block No :**

REMARKS

Name & signature of Technician(s)

Verified By :

<sup>1</sup> P.Ntami Ohij

(Name & signature)

2

RED-POWER ELECTRICAL ENGINEERING PTE LTD

BLK 16 DEFU LANE 10. #01 - 364. SINGAPORE 539197

TEL : 6 289 2298 FAX : 6 287 9635

FAX : 6 287 9635

## TOWN COUNCIL

NEE SOON TOWN COUNCIL

## LOCATION

## NEE SOON EAST DIVISION

**DATE OF SERVICING**

29 /09/2025

## **WEEKLY PRESSURE TANK CHECKLIST REPORT**

1. Test run of pumps
  2. Check pump and motor running condition
  3. Check coupling set, baseplate and spring isolator
  4. Check mechanical seal / gland-packing and bearings
  5. Check all pipe work, check valve, gate valve, expansion joint, strainer
  6. Check correct function of pump system in auto and manual mode
  7. Check control panel and electrical isolator
  8. Check electrical components in control panel
  9. Check all indicator lamps
  10. Check conduit and wiring
  11. Check electrode holder and sensor
  12. Check ball float valve / pilot valve and motorised valve
  13. Check pump running ampere
  14. Check pressure switch setting and pressure gauge

Block No :

**REMARKS**

REMARKS BLK - 269A - PT1 ♀ · PT2 - Spoil, 296A · PT1 ♂ PT2 - Spoil

Name & signature of Technician(s)

Verified By :

<sup>1</sup> P.Ntami Ntjij

(Name & signature)

2

RED-POWER ELECTRICAL ENGINEERING PTE LTD

BLK 16 DEFU LANE 10. #01 - 364. SINGAPORE 539197

TEL : 6 289 2298

FAX : 6 287 9635

TOWN COUNCIL

## NEE SOON TOWN COUNCIL

## LOCATION

NEE SOON EAST DIVISION

**DATE OF SERVICING**

29 /09/2025

## WEEKLY PRESSURE TANK CHECKLIST REPORT

1. Test run of pumps
  2. Check pump and motor running condition
  3. Check coupling set, baseplate and spring isolator
  4. Check mechanical seal / gland-packing and bearings
  5. Check all pipe work, check valve, gate valve, expansion joint, strainer
  6. Check correct function of pump system in auto and manual mode
  7. Check control panel and electrical isolator
  8. Check electrical components in control panel
  9. Check all indicator lamps
  10. Check conduit and wiring
  11. Check electrode holder and sensor
  12. Check ball float valve / pilot valve and motorised valve
  13. Check pump running ampere
  14. Check pressure switch setting and pressure gauge

Block No :

REMARKS

Name & signature of Technician(s)

Verified By :

1 P.Nomi Neri

(Name & signature)

2

RED-POWER ELECTRICAL ENGINEERING PTE LTD

BLK 16 DEFU LANE 10. #01 - 364. SINGAPORE 539197

TEL : 6 289 2298 FAX : 6 287 9635

TOWN COUNCIL	<u>NEE SOON TOWN COUNCIL</u>
LOCATION	<u>NEE SOON EAST DIVISION</u>
DATE OF SERVICING	<u>29/09/2025</u>

## WEEKLY PRESSURE TANK CHECKLIST REPORT

1. Test run of pumps
  2. Check pump and motor running condition
  3. Check coupling set, baseplate and spring isolator
  4. Check mechanical seal / gland-packing and bearings
  5. Check all pipe work, check valve, gate valve, expansion joint, strainer
  6. Check correct function of pump system in auto and manual mode
  7. Check control panel and electrical isolator
  8. Check electrical components in control panel
  9. Check all indicator lamps
  10. Check conduit and wiring
  11. Check electrode holder and sensor
  12. Check ball float valve / pilot valve and motorised valve
  13. Check pump running ampere
  14. Check pressure switch setting and pressure gauge

**Block No :**

REMARKS

Name & signature of Technician(s)

Verified By :

<sup>1</sup> Ramtani Bhuj

(Name & signature)

2

RED-POWER ELECTRICAL ENGINEERING PTE LTD

BLK 16 DEFU LANE 10. #01 - 364. SINGAPORE 539197

TEL : 6 289 2298 FAX : 6

FAX : 6 287 9635

## TOWN COUNCIL

## NEE SOON TOWN COUNCIL

## LOCATION

NEE SOON EAST DIVISION

**DATE OF SERVICING**

20 /09/2025

## WEEKLY PRESSURE TANK CHECKLIST REPORT

1. Test run of pumps
  2. Check pump and motor running condition
  3. Check coupling set, baseplate and spring isolator
  4. Check mechanical seal / gland-packing and bearings
  5. Check all pipe work, check valve, gate valve, expansion joint, strainer
  6. Check correct function of pump system in auto and manual mode
  7. Check control panel and electrical isolator
  8. Check electrical components in control panel
  9. Check all indicator lamps
  10. Check conduit and wiring
  11. Check electrode holder and sensor
  12. Check ball float valve / pilot valve and motorised valve
  13. Check pump running ampere
  14. Check pressure switch setting and pressure gauge

**Block No :**

**RED-POWER ELECTRICAL ENGINEERING PTE LTD**  
BLK 16 DEFU LANE 10. #01 - 364. SINGAPORE 539196  
TEL : 6 289 2298 FAX : 6 287 9635

TOWN COUNCIL	<u>NEE SOON TOWN COUNCIL</u>
LOCATION	<u>NEE SOON EAST DIVISION</u>
DATE OF SERVICING	<u>20/09/2025</u>

## WEEKLY PRESSURE TANK CHECKLIST REPORT

1. Test run of pumps
  2. Check pump and motor running condition
  3. Check coupling set, baseplate and spring isolator
  4. Check mechanical seal / gland-packing and bearings
  5. Check all pipe work, check valve, gate valve, expansion joint, strainer
  6. Check correct function of pump system in auto and manual mode
  7. Check control panel and electrical isolator
  8. Check electrical components in control panel
  9. Check all indicator lamps
  10. Check conduit and wiring
  11. Check electrode holder and sensor
  12. Check ball float valve / pilot valve and motorised valve
  13. Check pump running ampere
  14. Check pressure switch setting and pressure gauge

**Block No :**

**REMARKS**

Name & signature of Technician(s)

Verified By :

<sup>1</sup> D. Nomi Mhi

(Name & signature)

2 \_\_\_\_\_

RED-POWER ELECTRICAL ENGINEERING PTE LTD

BLK 16 DEFU LANE 10. #01 - 364. SINGAPORE 539197

TEL : 6 289 2298 FAX : 6 287 9635

TOWN COUNCIL	<u>NEE SOON TOWN COUNCIL</u>
LOCATION	<u>NEE SOON EAST DIVISION</u>
DATE OF SERVICING	<u>20 /09/2025</u>

## WEEKLY PRESSURE TANK CHECKLIST REPORT

1. Test run of pumps
  2. Check pump and motor running condition
  3. Check coupling set, baseplate and spring isolator
  4. Check mechanical seal / gland-packing and bearings
  5. Check all pipe work, check valve, gate valve, expansion joint, strainer
  6. Check correct function of pump system in auto and manual mode
  7. Check control panel and electrical isolator
  8. Check electrical components in control panel
  9. Check all indicator lamps
  10. Check conduit and wiring
  11. Check electrode holder and sensor
  12. Check ball float valve / pilot valve and motorised valve
  13. Check pump running ampere
  14. Check pressure switch setting and pressure gauge

**Block No :**

### REMARKS

Name & signature of Technician(s)

Verified By :

<sup>1</sup> P-Nani Rhy

(Name & signature)

2

RED-POWER ELECTRICAL ENGINEERING PTE LTD

BLK 16 DEFU LANE 10. #01 - 364. SINGAPORE 539197

TEL : 6 289 2298 FAX : 6 287 9635

FAX : 6 287 9635

TOWN COUNCIL

## NEE SOON TOWN COUNCIL

## LOCATION

NEE SOON EAST DIVISION

**DATE OF SERVICING**

20/09/2025

## WEEKLY PRESSURE TANK CHECKLIST REPORT

1. Test run of pumps
  2. Check pump and motor running condition
  3. Check coupling set, baseplate and spring isolator
  4. Check mechanical seal / gland-packing and bearings
  5. Check all pipe work, check valve, gate valve, expansion joint, strainer
  6. Check correct function of pump system in auto and manual mode
  7. Check control panel and electrical isolator
  8. Check electrical components in control panel
  9. Check all indicator lamps
  10. Check conduit and wiring
  11. Check electrode holder and sensor
  12. Check ball float valve / pilot valve and motorised valve
  13. Check pump running ampere
  14. Check pressure switch setting and pressure gauge

**Block No :**

REMARKS

Name & signature of Technician(s)

Verified By :

<sup>1</sup> P.N.Tomi Ohi

(Name & signature)

2 \_\_\_\_\_