

RED-POWER ELECTRICAL ENGINEERING PTE LTD

BLK 16 DEFU LANE 10. #01 - 364. SINGAPORE 539197

TEL : 6 289 2298 FAX : 6 287 9635

TOWN COUNCIL	<u>NEE SOON TOWN COUNCIL</u>
LOCATION	<u>NEE SOON LINK DIVISION</u>
DATE OF SERVICING	<u>6/09/2025</u>

WEEKLY FIRE ALARM CHECKLIST REPORT

1. SIMULATED TEST

- 1.1 Carry out a stimulated fire alarm call
 - 1.2 Operate any Alarm Zone
 - 1.3 Transmit a Fire Alarm Signal to the monitoring station and reset the system

2. MONITORING STATION

- 2.1 Contact the monitoring system prior to the transiting of the fire alarm signal
 - 2.2 To warn them of the simulated fire condition to be tested
 - 2.3 Check with them after completion of test to ensure the fire alarm signal was received
 - 2.4 Advise the monitoring station that the systm has been reset

3. BATTERY CONDITION

- 3.1 Check the battery voltage
 - 3.2 Check the battery condition

4 SWITCHES

- 4.1 Ensure that all switches are in the correct operating condition after completion of tests
 - 4.2 Take immediate steps to rectify the fault(s) should they exist.

5. DEFECTS

- 5.1 Record in the log any fault(s) identified and that the above test has been carried out

Block No :

REMARKS

Name & signature of Technician(s)

Verified By :

1 Pk -

(Name & signature)

2

RED-POWER ELECTRICAL ENGINEERING PTE LTD

BLK 16 DEFU LANE 10. #01 - 364. SINGAPORE 539197

TEL : 6 289 2298 FAX : 6 287 9635

TOWN COUNCIL	<u>NEE SOON TOWN COUNCIL</u>
LOCATION	<u>NEE SOON LINK DIVISION</u>
DATE OF SERVICING	<u>6 /09/2025</u>

WEEKLY FIRE ALARM CHECKLIST REPORT

1. SIMULATED TEST

- 1.1 Carry out a stimulated fire alarm call
 - 1.2 Operate any Alarm Zone
 - 1.3 Transmit a Fire Alarm Signal to the monitoring station and reset the system

2. MONITORING STATION

- 2.1 Contact the monitoring system prior to the transmitting of the fire alarm signal
 - 2.2 To warn them of the simulated fire condition to be tested
 - 2.3 Check with them after completion of test to ensure the fire alarm signal was received
 - 2.4 Advise the monitoring station that the system has been reset

3. BATTERY CONDITION

- 3.1 Check the battery voltage
3.2 Check the battery condition

4 SWITCHES

- 4.1 Ensure that all switches are in the correct operating condition after completion of tests
 - 4.2 Take immediate steps to rectify the fault(s) should they exist

5. DEFECTS

- 5.1 Record in the log any fault(s) identified and that the above test has been carried out

Block No :

REMARKS

Name & signature of Technician(s)

Verified By :

1 RH

(Name & signature)

2

RED-POWER ELECTRICAL ENGINEERING PTE LTD
BLK 16 DEFU LANE 10. #01 - 364. SINGAPORE 539197
TEL : 6 289 2298 FAX : 6 287 9635

TOWN COUNCIL	<u>NEE SOON TOWN COUNCIL</u>
LOCATION	<u>NEE SOON LINK DIVISION</u>
DATE OF SERVICING	<u>6/09/2025</u>

WEEKLY FIRE ALARM CHECKLIST REPORT

1. SIMULATED TEST

- 1.1 Carry out a stimulated fire alarm call
 - 1.2 Operate any Alarm Zone
 - 1.3 Transmit a Fire Alarm Signal to the monitoring station and reset the system

2. MONITORING STATION

- 2.1 Contact the monitoring system prior to the transmitting of the fire alarm signal
 - 2.2 To warn them of the simulated fire condition to be tested
 - 2.3 Check with them after completion of test to ensure the fire alarm signal was received
 - 2.4 Advise the monitoring station that the system has been reset

3 BATTERY CONDITION

- 3.1 Check the battery voltage
 - 3.2 Check the battery conditions

4 SWITCHES

- 4.1 Ensure that all switches are in the correct operating condition after completion of tests
 - 4.2 Take immediate steps to rectify the fault(s) should they exist

5. DEFECTS

 - 5.1 Record in the log any fault(s) identified and that the above test has been carried out

Block No :

REMARKS

Name & signature of Technician(s)

Verified By :

1

(Name & signature)

2

RED-POWER ELECTRICAL ENGINEERING PTE LTD

BLK 16 DEFU LANE 10. #01 - 364. SINGAPORE 539197

TEL : 6 289 2298 FAX : 6 287 9635

TOWN COUNCIL	<u>NEE SOON TOWN COUNCIL</u>
LOCATION	<u>NEE SOON LINK DIVISION</u>
DATE OF SERVICING	<u>26 /09/2025</u>

WEEKLY FIRE ALARM CHECKLIST REPORT

1. SIMULATED TEST

- 1.1 Carry out a stimulated fire alarm call
 - 1.2 Operate any Alarm Zone
 - 1.3 Transmit a Fire Alarm Signal to the monitoring station and reset the system

2. MONITORING STATION

- 2.1 Contact the monitoring system prior to the transmitting of the fire alarm signal
 - 2.2 To warn them of the simulated fire condition to be tested
 - 2.3 Check with them after completion of test to ensure the fire alarm signal was received
 - 2.4 Advise the monitoring station that the system has been reset

3. BATTERY CONDITION

- 3.1 Check the battery voltage
3.2 Check the battery condition

4 SWITCHES

- 4.1 Ensure that all switches are in the correct operating condition after completion of tests
 - 4.2 Take immediate steps to rectify the fault(s) should they exist

5. DEFECTS

- 5.1 Record in the log any fault(s) identified and that the above test has been carried out

Block No :

472A	472B	473A	473B	476

REMARKS

Name & signature of Technician(s)

Verified By :

1 Dff.

(Name & signature)

2 _____

RED-POWER ELECTRICAL ENGINEERING PTE LTD

BLK 16 DEFU LANE 10. #01 - 364. SINGAPORE 539197

TEL : 6 289 2298 FAX : 6 287 9635

TOWN COUNCIL	<u>NEE SOON TOWN COUNCIL</u>
LOCATION	<u>NEE SOON LINK DIVISION</u>
DATE OF SERVICING	<u>6</u> /09/2025

WEEKLY FIRE ALARM CHECKLIST REPORT

1. SIMULATED TEST

- 1.1 Carry out a stimulated fire alarm call
 - 1.2 Operate any Alarm Zone
 - 1.3 Transmit a Fire Alarm Signal to the monitoring station and reset the system

2. MONITORING STATION

- 2.1 Contact the monitoring system prior to the transiting of the fire alarm signal
 - 2.2 To warn them of the simulated fire condition to be tested
 - 2.3 Check with them after completion of test to ensure the fire alarm signal was received
 - 2.4 Advise the monitoring station that the systm has been reset

3. BATTERY CONDITION

- 3.1 Check the battery voltage
 - 3.2 Check the battery condition

4 SWITCHES

- 4.1 Ensure that all switches are in the correct operating condition after completion of tests
 - 4.2 Take immediate steps to rectify the fault(s) should they exist

5. DEFECTS

 - 5.1 Record in the log any fault(s) identified and that the above test has been carried out

Block No :

REMARKS

Name & signature of Technician(s)

Verified By :

1 

(Name & signature)

2

RED-POWER ELECTRICAL ENGINEERING PTE LTD
BLK 16 DEFU LANE 10. #01 - 364. SINGAPORE 539197
TEL : 6 289 2298 FAX : 6 287 9635

TOWN COUNCIL	<u>NEE SOON TOWN COUNCIL</u>
LOCATION	<u>NEE SOON LINK DIVISION</u>
DATE OF SERVICING	<u>8 /09/2025</u>

WEEKLY FIRE ALARM CHECKLIST REPORT

1. SIMULATED TEST

- 1.1 Carry out a stimulated fire alarm call
 - 1.2 Operate any Alarm Zone
 - 1.3 Transmit a Fire Alarm Signal to the monitoring station and reset the system

2. MONITORING STATION

- 2.1 Contact the monitoring system prior to the transmitting of the fire alarm signal
 - 2.2 To warn them of the simulated fire condition to be tested
 - 2.3 Check with them after completion of test to ensure the fire alarm signal was received
 - 2.4 Advise the monitoring station that the system has been reset

3 BATTERY CONDITION

- 3.1 Check the battery voltage
 - 3.2 Check the battery conditions

4 SWITCHES

- 4.1 Ensure that all switches are in the correct operating condition after completion of tests
 - 4.2 Take immediate steps to rectify the fault(s) should they exist

5. DEFECTS

5.1 Record

Block No :

REMARKS

Name & signature of Technician(s)

Verified By :

1

(Name & signature)

2

RED-POWER ELECTRICAL ENGINEERING PTE LTD

BLK 16 DEFU LANE 10. #01 - 364. SINGAPORE 539197

TEL : 6 289 2298 FAX : 6 287 9635

TOWN COUNCIL	<u>NEE SOON TOWN COUNCIL</u>
LOCATION	<u>NEE SOON LINK DIVISION</u>
DATE OF SERVICING	<u>8/09/2025</u>

WEEKLY FIRE ALARM CHECKLIST REPORT

1. SIMULATED TEST

- 1.1 Carry out a stimulated fire alarm call
 - 1.2 Operate any Alarm Zone
 - 1.3 Transmit a Fire Alarm Signal to the monitoring station and reset the system

2. MONITORING STATION

- 2.1 Contact the monitoring system prior to the transmitting of the fire alarm signal
 - 2.2 To warn them of the simulated fire condition to be tested
 - 2.3 Check with them after completion of test to ensure the fire alarm signal was received
 - 2.4 Advise the monitoring station that the system has been reset

3. BATTERY CONDITION

- 3.1 Check the battery voltage
 - 3.2 Check the battery condition

4 SWITCHES

- 4.1 Ensure that all switches are in the correct operating condition after completion of tests
 - 4.2 Take immediate steps to rectify the fault(s) should they exist

5. DEFECTS

- 5.1 Record in the log any fault(s) identified and that the above test has been carried out

Block No :

REMARKS

Name & signature of Technician(s)

Verified By :

1 PDF.

(Name & signature)

2

RED-POWER ELECTRICAL ENGINEERING PTE LTD

BLK 16 DEFU LANE 10. #01 - 364. SINGAPORE 539197

TEL : 6 289 2298 FAX : 6 287 9635

TOWN COUNCIL	<u>NEE SOON TOWN COUNCIL</u>
LOCATION	<u>NEE SOON LINK DIVISION</u>
DATE OF SERVICING	<u>8/09/2025</u>

WEEKLY FIRE ALARM CHECKLIST REPORT

1. SIMULATED TEST

- 1.1 Carry out a stimulated fire alarm call
 - 1.2 Operate any Alarm Zone
 - 1.3 Transmit a Fire Alarm Signal to the monitoring station and reset the system

2. MONITORING STATION

- 2.1 Contact the monitoring system prior to the transmitting of the fire alarm signal
 - 2.2 To warn them of the simulated fire condition to be tested
 - 2.3 Check with them after completion of test to ensure the fire alarm signal was received

2.4 Advise the monitor

- 3.1 Check the battery voltage
 - 3.2 Check the battery condition

4 SWITCHES

- 4.1 Ensure that all switches are in the correct operating condition after completion of tests
 - 4.2 Take immediate steps to rectify the fault(s) should they exist

5. DEFECTS

 - 5.1 Record in the log any fault(s) identified and that the above test has been carried out

Block No :

REMARKS

Name & signature of Technician(s)

Verified By :

1 DfL

(Name & signature)

2

RED-POWER ELECTRICAL ENGINEERING PTE LTD

BLK 16 DEFU LANE 10. #01 - 364. SINGAPORE 539197

TEL : 6 289 2298 FAX : 6 287 9635

NEE SOON TOWN COUNCIL

LOCATION NEE SOON LINK DIVISION

DATE OF SERVICING 8/09/2025

WEEKLY FIRE ALARM CHECKLIST REPORT

1. SIMULATED TEST

- 1.1 Carry out a stimulated fire alarm call
 - 1.2 Operate any Alarm Zone
 - 1.3 Transmit a Fire Alarm Signal to the monitoring station and reset the system

2. MONITORING STATION

- 2.1 Contact the monitoring system prior to the transmitting of the fire alarm signal
 - 2.2 To warn them of the simulated fire condition to be tested
 - 2.3 Check with them after completion of test to ensure the fire alarm signal was received
 - 2.4 Advise the monitoring station that the systm has been reset

3 BATTERY CONDITION

- 3.1 Check the battery voltage
 - 3.2 Check the battery conditions

4 SWITCHES

- 4.1 Ensure that all switches are in the correct operating condition after completion of tests
 - 4.2 Take immediate steps to rectify the fault(s) should they exist

5. DEFECTS

- 5.1 Record in the log any fault(s) identified and that the above test has been carried out

Block No :

REMARKS

Name & signature of Technician(s)

Verified By :

A graph showing a curve with a sharp corner or cusp at the origin (0,0). The curve consists of two separate branches: one in the second quadrant and another in the fourth quadrant. Both branches approach the y-axis as x approaches zero from both sides.

(Name & signature)

2

RED-POWER ELECTRICAL ENGINEERING PTE LTD

BLK 16 DEFU LANE 10. #01 - 364. SINGAPORE 539197

TEL : 6 289 2298 FAX : 6 287 9635

TOWN COUNCIL	<u>NEE SOON TOWN COUNCIL</u>
LOCATION	<u>NEE SOON LINK DIVISION</u>
DATE OF SERVICING	<u>8 /09/2025</u>

WEEKLY FIRE ALARM CHECKLIST REPORT

1. SIMULATED TEST

- 1.1 Carry out a stimulated fire alarm call
 - 1.2 Operate any Alarm Zone
 - 1.3 Transmit a Fire Alarm Signal to the monitoring station and reset the system

2. MONITORING STATION

- 2.1 Contact the monitoring system prior to the transmitting of the fire alarm signal
 - 2.2 To warn them of the simulated fire condition to be tested
 - 2.3 Check with them after completion of test to ensure the fire alarm signal was received
 - 2.4 Advise the monitoring station that the system has been reset

3 BATTERY CONDITION

- 3.1 Check the battery voltage
 - 3.2 Check the battery conditions

4 SWITCHES

- 4.1 Ensure that all switches are in the correct operating condition after completion of tests
 - 4.2 Take immediate steps to rectify the fault(s) should they exist.

5. DEFECTS

- 5.1 Record in the log any fault(s) identified and that the above test has been carried out

Block No :

REMARKS

Name & signature of Technician(s)

Verified By :

1 Rf.

(Name & signature)

2

RED-POWER ELECTRICAL ENGINEERING PTE LTD
BLK 16 DEFU LANE 10. #01 - 364. SINGAPORE 539197
TEL : 6 289 2298 FAX : 6 287 9635

TOWN COUNCIL	<u>NEE SOON TOWN COUNCIL</u>
LOCATION	<u>NEE SOON LINK DIVISION</u>
DATE OF SERVICING	<u>16 /09/2025</u>

WEEKLY FIRE ALARM CHECKLIST REPORT

- 1. SIMULATED TEST
 - 1.1 Carry out a stimulated fire alarm call
 - 1.2 Operate any Alarm Zone
 - 1.3 Transmit a Fire Alarm Signal to the monitoring station and reset the system
 - 2. MONITORING STATION
 - 2.1 Contact the monitoring system prior to the transitting of the fire alarm signal
 - 2.2 To warn them of the simulated fire condition to be tested
 - 2.3 Check with them after completion of test to ensure the fire alarm signal was received
 - 2.4 Advise the monitoring station that the systm has been reset
 - 3. BATTERY CONDITION
 - 3.1 Check the battery voltage
 - 3.2 Check the battery conditions
 - 4. SWITCHES
 - 4.1 Ensure that all switches are in the correct operating condition after completion of tests
 - 4.2 Take immediate steps to rectify the fault(s) should they exist
 - 5. DEFECTS
 - 5.1 Record in the log any fault(s) identified and that the above test has been carried out

Block No :

REMARKS

Name & signature of Technician(s)

Verified By :

1 Pf.

(Name & signature)

2 _____

RED-POWER ELECTRICAL ENGINEERING PTE LTD

BLK 16 DEFU LANE 10. #01 - 364. SINGAPORE 539197

TEL : 6 289 2298 FAX : 6 287 9635

TOWN COUNCIL	<u>NEE SOON TOWN COUNCIL</u>
LOCATION	<u>NEE SOON LINK DIVISION</u>
DATE OF SERVICING	<u>16/09/2025</u>

WEEKLY FIRE ALARM CHECKLIST REPORT

1. SIMULATED TEST

- 1.1 Carry out a stimulated fire alarm call
 - 1.2 Operate any Alarm Zone
 - 1.3 Transmit a Fire Alarm Signal to the monitoring station and reset the system

2. MONITORING STATION

- 2.1 Contact the monitoring system prior to the transmitting of the fire alarm signal
 - 2.2 To warn them of the simulated fire condition to be tested
 - 2.3 Check with them after completion of test to ensure the fire alarm signal was received
 - 2.4 Advise the monitoring station that the system has been reset

3. BATTERY CONDITION

- ### 3.1 Check the battery voltage

4 SWITCHES

- 4.1 Ensure that all switches are in the correct operating condition after completion of tests
 - 4.2 Take immediate steps to rectify the fault(s) should they exist

5. DEFECTS

- 5.1 Record in the log any fault(s) identified and that the above test has been carried out

Block No :

REMARKS

Name & signature of Technician(s)

Verified By :

1 Df.

2

(Name & signature)

RED-POWER ELECTRICAL ENGINEERING PTE LTD
BLK 16 DEFU LANE 10. #01 - 364. SINGAPORE 539197
TEL : 6 289 2298 FAX : 6 287 9635

TOWN COUNCIL	<u>NEE SOON TOWN COUNCIL</u>
LOCATION	<u>NEE SOON LINK DIVISION</u>
DATE OF SERVICING	<u>16/09/2025</u>

WEEKLY FIRE ALARM CHECKLIST REPORT

1. SIMULATED TEST

- 1.1 Carry out a stimulated fire alarm call
 - 1.2 Operate any Alarm Zone
 - 1.3 Transmit a Fire Alarm Signal to the monitoring station and reset the system

2. MONITORING STATION

- 2.1 Contact the monitoring system prior to the transmitting of the fire alarm signal
 - 2.2 To warn them of the simulated fire condition to be tested
 - 2.3 Check with them after completion of test to ensure the fire alarm signal was received
 - 2.4 Advise the monitoring station that the system has been reset

3. BATTERY CONDITION

- ### 3.1 Check the battery voltage

4 SWITCHES

- 4.1 Ensure that all switches are in the correct operating condition after completion of tests
 - 4.2 Take immediate steps to rectify the fault(s) should they exist

5. DEFECTS

 - 5.1 Record in the log any fault(s) identified and that the above test has been carried out

Block No :

REMARKS

Name & signature of Technician(s)

Verified By :

DK

(Name & signature)

2

RED-POWER ELECTRICAL ENGINEERING PTE LTD

BLK 16 DEFU LANE 10. #01 - 364. SINGAPORE 539197

TEL : 6 289 2298 FAX : 6 287 9635

TOWN COUNCIL	<u>NEE SOON TOWN COUNCIL</u>
LOCATION	<u>NEE SOON LINK DIVISION</u>
DATE OF SERVICING	<u>16/09/2025</u>

WEEKLY FIRE ALARM CHECKLIST REPORT

1. SIMULATED TEST

- 1.1 Carry out a stimulated fire alarm call
 - 1.2 Operate any Alarm Zone
 - 1.3 Transmit a Fire Alarm Signal to the monitoring station and reset the system

2. MONITORING STATION

- 2.1 Contact the monitoring system prior to the transmitting of the fire alarm signal
 - 2.2 To warn them of the simulated fire condition to be tested
 - 2.3 Check with them after completion of test to ensure the fire alarm signal was received
 - 2.4 Advise the monitoring station that the system has been reset

3. BATTERY CONDITION

- 3.1 Check the battery voltage
3.2 Check the battery condition

4. SWITCHES

- 4.1 Ensure that all switches are in the correct operating condition after completion of tests
 - 4.2 Take immediate steps to rectify the fault(s) should they exist

5. DEFECTS

- 5.1 Record in the log any fault(s) identified and that the above test has been carried out

Block No :

472A	472B	473A	473B	476
	<			

REMARKS

Name & signature of Technician(s)

Verified By :

1 D. H.

(Name & signature)

2

RED-POWER ELECTRICAL ENGINEERING PTE LTD

BLK 16 DEFU LANE 10. #01 - 364. SINGAPORE 539197

TEL : 6 289 2298 FAX : 6 287 9635

TOWN COUNCIL	<u>NEE SOON TOWN COUNCIL</u>
LOCATION	<u>NEE SOON LINK DIVISION</u>
DATE OF SERVICING	<u>16</u> /09/2025

WEEKLY FIRE ALARM CHECKLIST REPORT

1. SIMULATED TEST

- ### 1.1 Carry out a stimulated fire alarm call

- ## 1.2 Operate any Alarm Zone

- 1.3 Transmit a Fire Alarm Signal to the monitoring station and reset the system

2. MONITORING STATION

- 2.1 Contact the monitoring system prior to the transmitting of the fire alarm signal

- 2.2 To warn them of the simulated fire condition to be tested

- 2.3 Check with them after completion of test to ensure the fire alarm signal was received

- 2.4 Advise the monitoring station that the system has been reset

3. BATTERY CONDITION

- ### 3.1 Check the battery voltage

- ### 3.2 Check the battery conditions

4 SWITCHES

- 4.1 Ensure that all switches are in the correct operating condition after completion of tests

- 4.2 Take immediate steps to rectify the fault(s) should they exist.

5 DEFECTS

- 5.1 Record in the log any fault(s) identified and that the above test has been carried out

Block No :

REMARKS

Name & signature of Technician(s)

Verified By :

1 D .

(Name & signature)

2

RED-POWER ELECTRICAL ENGINEERING PTE LTD

BLK 16 DEFU LANE 10. #01 - 364. SINGAPORE 539197

TEL : 6 289 2298 FAX : 6 287 9635

TOWN COUNCIL

NEE SOON TOWN COUNCIL

LOCATION

NEE SOON LINK DIVISION

DATE OF SERVICING

26 /09/2025

WEEKLY FIRE ALARM CHECKLIST REPORT

1. SIMULATED TEST

- 1.1 Carry out a stimulated fire alarm call
 - 1.2 Operate any Alarm Zone
 - 1.3 Transmit a Fire Alarm Signal to the monitoring station and reset the system

2. MONITORING STATION

- 2.1 Contact the monitoring system prior to the transitting of the fire alarm signal
 - 2.2 To warn them of the simulated fire condition to be tested
 - 2.3 Check with them after completion of test to ensure the fire alarm signal was received
 - 2.4 Advise the monitoring station that the systm has been reset

3. BATTERY CONDITION

- 3.1 Check the battery voltage
 - 3.2 Check the battery conditions

4 SWITCHES

- 4.1 Ensure that all switches are in the correct operating condition after completion of tests
 - 4.2 Take immediate steps to rectify the fault(s) should they exist

5. DEFECTS

- 5.1 Record in the log any fault(s) identified and that the above test has been carried out

Block No :

REMARKS

Name & signature of Technician(s)

Verified By :

1 Rf

(Name & signature)

2

RED-POWER ELECTRICAL ENGINEERING PTE LTD

BLK 16 DEFU LANE 10. #01 - 364. SINGAPORE 539197

TEL : 6 289 2298 FAX : 6 287 9635

TOWN COUNCIL	<u>NEE SOON TOWN COUNCIL</u>
LOCATION	<u>NEE SOON LINK DIVISION</u>
DATE OF SERVICING	<u>26</u> /09/2025

WEEKLY FIRE ALARM CHECKLIST REPORT

1. SIMULATED TEST

- 1.1 Carry out a stimulated fire alarm call
 - 1.2 Operate any Alarm Zone
 - 1.3 Transmit a Fire Alarm Signal to the monitoring station and reset the system

2. MONITORING STATION

- 2.1 Contact the monitoring system prior to the transmitting of the fire alarm signal
 - 2.2 To warn them of the simulated fire condition to be tested
 - 2.3 Check with them after completion of test to ensure the fire alarm signal was received
 - 2.4 Advise the monitoring station that the system has been reset

3 BATTERY CONDITION

- ### 3.1 Check the battery voltage

4 SWITCHES

- 4.1 Ensure that all switches are in the correct operating condition after completion of tests
 - 4.2 Take immediate steps to rectify the fault(s) should they exist

5. DEFECTS

- 5.1 Record in the log any fault(s) identified and that the above test has been carried out

Block No :

REMARKS

Name & signature of Technician(s)

Verified By :

1 

(Name & signature)

2

RED-POWER ELECTRICAL ENGINEERING PTE LTD

BLK 16 DEFU LANE 10. #01 - 364. SINGAPORE 539197

TEL : 6 289 2298 FAX : 6 287 9635

TOWN COUNCIL	<u>NEE SOON TOWN COUNCIL</u>
LOCATION	<u>NEE SOON LINK DIVISION</u>
DATE OF SERVICING	<u>26</u> /09/2025

WEEKLY FIRE ALARM CHECKLIST REPORT

1. SIMULATED TEST

- 1.1 Carry out a stimulated fire alarm call
 - 1.2 Operate any Alarm Zone
 - 1.3 Transmit a Fire Alarm Signal to the monitoring station and reset the system

2. MONITORING STATION

- 2.1 Contact the monitoring system prior to the transmitting of the fire alarm signal
 - 2.2 To warn them of the simulated fire condition to be tested
 - 2.3 Check with them after completion of test to ensure the fire alarm signal was received
 - 2.4 Advise them via e-mail that the meter has been reset.

3. BATTERY CONDITION

- 3.1 Check the battery voltage
 - 3.2 Check the battery conditions

4 SWITCHES

- 4.1 Ensure that all switches are in the correct operating condition after completion of tests
 - 4.2 Take immediate steps to rectify the fault(s) should they exist.

5 DEFECTS

- 5.1 Record in the log any fault(s) identified and that the above test has been carried out

Block No :

REMARKS

Name & signature of Technician(s)

Verified By :

1 PF.

(Name & signature)

2

RED-POWER ELECTRICAL ENGINEERING PTE LTD

BLK 16 DEFU LANE 10. #01 - 364. SINGAPORE 539197

TEL : 6 289 2298 FAX : 6 287 9635

TOWN COUNCIL	<u>NEE SOON TOWN COUNCIL</u>
LOCATION	<u>NEE SOON LINK DIVISION</u>
DATE OF SERVICING	<u>26</u> /09/2025

WEEKLY FIRE ALARM CHECKLIST REPORT

1. SIMULATED TEST

- 1.1 Carry out a stimulated fire alarm call
 - 1.2 Operate any Alarm Zone
 - 1.3 Transmit a Fire Alarm Signal to the monitoring station and reset the system

2. MONITORING STATION

- 2.1 Contact the monitoring system prior to the transmitting of the fire alarm signal
 - 2.2 To warn them of the simulated fire condition to be tested
 - 2.3 Check with them after completion of test to ensure the fire alarm signal was received
 - 2.4 Advise the monitoring station that the system has been reset

3 BATTERY CONDITION

- 3.1 Check the battery voltage
 - 3.2 Check the battery condition

4. SWITCHES

- 4.1 Ensure that all switches are in the correct operating condition after completion of tests
 - 4.2 Take immediate steps to rectify the fault(s) should they exist

5. DEFECTS

- 5.1 Record in the log any fault(s) identified and that the above test has been carried out

Block No :

REMARKS

Name & signature of Technician(s)

Verified By :

1 Df.

(Name & signature)

2 _____

RED-POWER ELECTRICAL ENGINEERING PTE LTD

BLK 16 DEFU LANE 10. #01 - 364. SINGAPORE 539197

TEL : 6 289 2298 FAX : 6 287 9635

TOWN COUNCIL	<u>NEE SOON TOWN COUNCIL</u>
LOCATION	<u>NEE SOON LINK DIVISION</u>
DATE OF SERVICING	<u>26</u> /09/2025

WEEKLY FIRE ALARM CHECKLIST REPORT

1. SIMULATED TEST

- 1.1 Carry out a stimulated fire alarm call
 - 1.2 Operate any Alarm Zone
 - 1.3 Transmit a Fire Alarm Signal to the monitoring station and reset the system

2. MONITORING STATION

- 2.1 Contact the monitoring system prior to the transmitting of the fire alarm signal
 - 2.2 To warn them of the simulated fire condition to be tested
 - 2.3 Check with them after completion of test to ensure the fire alarm signal was received
 - 2.4 Advise the monitoring station that the system has been reset

3. BATTERY CONDITION

- 3.1 Check the battery voltage
 - 3.2 Check the battery conditions

4 SWITCHES

- 4.1 Ensure that all switches are in the correct operating condition after completion of tests
 - 4.2 Take immediate steps to rectify the fault(s) should they exist

5. DEFECTS

 - 5.1 Record in the log any fault(s) identified and that the above test has been carried out.

3.1 Record

REMARKS

Name & signature of Technician(s)

Verified By :

1 Rf

(Name & signature)

2

RED-POWER ELECTRICAL ENGINEERING PTE LTD

BLK 16 DEFU LANE 10. #01 - 364. SINGAPORE 539197

TEL : 6 289 2298

FAX : 6 287 9635

TOWN COUNCIL

NEE SOON TOWN COUNCIL

LOCATION

NEE SOON LINK DIVISION

DATE OF SERVICING

4 /09/2025

WEEKLY PRESSURE TANK CHECKLIST REPORT

1. Test run of pumps
2. Check pump and motor running condition
3. Check coupling set, baseplate and spring isolator
4. Check mechanical seal / gland-packing and bearings
5. Check all pipe work, check valve, gate valve, expansion joint, strainer
6. Check correct function of pump system in auto and manual mode
7. Check control panel and electrical isolator
8. Check electrical components in control panel
9. Check all indicator lamps
10. Check conduit and wiring
11. Check electrode holder and sensor
12. Check ball float valve / pilot valve and motorised valve
13. Check pump running ampere
14. Check pressure switch setting and pressure gauge

Block No :

385	419A	424A	424B	424C	424D	426	426A	426B
/	/	/	/	/	/	/	/	/
/	/	/	/	/	/	/	/	/
/	/	/	/	/	/	/	/	/
/	/	/	/	/	/	/	/	/
/	/	/	/	/	/	/	/	/
/	/	/	/	/	/	/	/	/
/	/	/	/	/	/	/	/	/
/	/	/	/	/	/	/	/	/
/	/	/	/	/	/	/	/	/
/	/	/	/	/	/	/	/	/
/	/	/	/	/	/	/	/	/
4.045	3.520	3.03.5	4.045	4.045	4.045			
/	/	/	/	/	/	/	/	/

REMARKS

Name & signature of Technician(s)

1 Selva M.

Verified By :

(Name & signature)

2 _____

RED-POWER ELECTRICAL ENGINEERING PTE LTD

BLK 16 DEFU LANE 10. #01 - 364. SINGAPORE 539197

TEL : 6 289 2298

FAX : 6 287 9635

TOWN COUNCIL

NEE SOON TOWN COUNCIL

LOCATION

NEE SOON LINK DIVISION

DATE OF SERVICING

11 /09/2025

WEEKLY PRESSURE TANK CHECKLIST REPORT

1. Test run of pumps
2. Check pump and motor running condition
3. Check coupling set, baseplate and spring isolator
4. Check mechanical seal / gland-packing and bearings
5. Check all pipe work, check valve, gate valve, expansion joint, strainer
6. Check correct function of pump system in auto and manual mode
7. Check control panel and electrical isolator
8. Check electrical components in control panel
9. Check all indicator lamps
10. Check conduit and wiring
11. Check electrode holder and sensor
12. Check ball float valve / pilot valve and motorised valve
13. Check pump running ampere
14. Check pressure switch setting and pressure gauge

Block No :

426C	426D	428A	428B	429	429A	429B	430	430A
/	/	/	/	/	/	/	/	/
/	/	/	/	/	/	/	/	/
/	/	/	/	/	/	/	/	/
/	/	/	/	/	/	/	/	/
/	/	/	/	/	/	/	/	/
/	/	/	/	/	/	/	/	/
/	/	/	/	/	/	/	/	/
/	/	/	/	/	/	/	/	/
/	/	/	/	/	/	/	/	/
/	/	/	/	/	/	/	/	/
/	/	/	/	/	/	/	/	/
35	3.0	45	3.0	35	3.0	3.0	45	4.0
/	/	/	/	/	/	/	/	/

REMARKS

Name & signature of Technician(s)

1. Selva M.

Verified By :

(Name & signature)

2. _____

RED-POWER ELECTRICAL ENGINEERING PTE LTD

BLK 16 DEFU LANE 10. #01 - 364. SINGAPORE 539197

TEL : 6 289 2298

FAX : 6 287 9635

TOWN COUNCIL

NEE SOON TOWN COUNCIL

LOCATION

NEE SOON LINK DIVISION

DATE OF SERVICING

4 /09/2025

WEEKLY PRESSURE TANK CHECKLIST REPORT

1. Test run of pumps
2. Check pump and motor running condition
3. Check coupling set, baseplate and spring isolator
4. Check mechanical seal / gland-packing and bearings
5. Check all pipe work, check valve, gate valve, expansion joint, strainer
6. Check correct function of pump system in auto and manual mode
7. Check control panel and electrical isolator
8. Check electrical components in control panel
9. Check all indicator lamps
10. Check conduit and wiring
11. Check electrode holder and sensor
12. Check ball float valve / pilot valve and motorised valve
13. Check pump running ampere
14. Check pressure switch setting and pressure gauge

Block No :

430B	431	431A	431B	431C	431D	432A	432B	432C
/	/	/	/	/	/	/	/	/
/	/	/	/	/	/	/	/	/
/	/	/	/	/	/	/	/	/
/	/	/	/	/	/	/	/	/
/	/	/	/	/	/	/	/	/
/	/	/	/	/	/	/	/	/
/	/	/	/	/	/	/	/	/
/	/	/	/	/	/	/	/	/
/	/	/	/	/	/	/	/	/
/	/	/	/	/	/	/	/	/
3.0	3.5	4.0	4.5	4.0	4.5	3.0	3.5	3.5

REMARKS

Name & signature of Technician(s)

1 Rehna A.

Verified By :

(Name & signature)

2 _____

RED-POWER ELECTRICAL ENGINEERING PTE LTD

BLK 16 DEFU LANE 10. #01 - 364. SINGAPORE 539197

TEL : 6 289 2298

FAX : 6 287 9635

TOWN COUNCIL

NEE SOON TOWN COUNCIL

LOCATION

NEE SOON LINK DIVISION

DATE OF SERVICING

— . 4 /09/2025

WEEKLY PRESSURE TANK CHECKLIST REPORT

1. Test run of pumps
2. Check pump and motor running condition
3. Check coupling set, baseplate and spring isolator
4. Check mechanical seal / gland-packing and bearings
5. Check all pipe work, check valve, gate valve, expansion joint, strainer
6. Check correct function of pump system in auto and manual mode
7. Check control panel and electrical isolator
8. Check electrical components in control panel
9. Check all indicator lamps
10. Check conduit and wiring
11. Check electrode holder and sensor
12. Check ball float valve / pilot valve and motorised valve
13. Check pump running ampere
14. Check pressure switch setting and pressure gauge

Block No :

432D	436	438	441	453	454	455	456	456A
/	/	/	/	/	/	/	/	/
/	/	/	/	/	/	/	/	/
/	/	/	/	/	/	/	/	/
/	/	/	/	/	/	/	/	/
/	/	/	/	/	/	/	/	/
/	/	/	/	/	/	/	/	/
/	/	/	/	/	/	/	/	/
/	/	/	/	/	/	/	/	/
/	/	/	/	/	/	/	/	/
3.5	3.0	4.0	4.5	4.0	3.5	3.0	3.8	3.0
/	/	/	/	/	/	/	/	/

Selva 

RED-POWER ELECTRICAL ENGINEERING PTE LTD

BLK 16 DEFU LANE 10. #01 - 364. SINGAPORE 539197

TEL : 6 289 2298

FAX : 6 287 9635

TOWN COUNCIL

NEE SOON TOWN COUNCIL

LOCATION

NEE SOON LINK DIVISION

DATE OF SERVICING

A /09/2025

WEEKLY PRESSURE TANK CHECKLIST REPORT

1. Test run of pumps
2. Check pump and motor running condition
3. Check coupling set, baseplate and spring isolator
4. Check mechanical seal / gland-packing and bearings
5. Check all pipe work, check valve, gate valve, expansion joint, strainer
6. Check correct function of pump system in auto and manual mode
7. Check control panel and electrical isolator
8. Check electrical components in control panel
9. Check all indicator lamps
10. Check conduit and wiring
11. Check electrode holder and sensor
12. Check ball float valve / pilot valve and motorised valve
13. Check pump running ampere
14. Check pressure switch setting and pressure gauge

Block No :

457	458	459	461	461A	461B	462A	462B	462C
/	/	/	/	/	/	/	/	/
/	/	/	/	/	/	/	/	/
/	/	/	/	/	/	/	/	/
/	/	/	/	/	/	/	/	/
/	/	/	/	/	/	/	/	/
/	/	/	/	/	/	/	/	/
/	/	/	/	/	/	/	/	/
/	/	/	/	/	/	/	/	/
/	/	/	/	/	/	/	/	/
/	/	/	/	/	/	/	/	/
/	/	/	/	/	/	/	/	/
40	3.0	3.5	3.0	40	45	3.5	3.5	3.0
/	/	/	/	/	/	/	/	/

REMARKS

Name & signature of Technician(s)

Colva

Verified By :

(Name & signature)

2 _____

RED-POWER ELECTRICAL ENGINEERING PTE LTD

BLK 16 DEFU LANE 10. #01 - 364. SINGAPORE 539197

TEL : 6 289 2298 FAX : 6 287 9635

TOWN COUNCIL NEE SOON TOWN COUNCIL
LOCATION NEE SOON LINK DIVISION
DATE OF SERVICING S /09/2025

WEEKLY PRESSURE TANK CHECKLIST REPORT

1. Test run of pumps
2. Check pump and motor running condition
3. Check coupling set, baseplate and spring isolator
4. Check mechanical seal / gland-packing and bearings
5. Check all pipe work, check valve, gate valve, expansion joint, strainer
6. Check correct function of pump system in auto and manual mode
7. Check control panel and electrical isolator
8. Check electrical components in control panel
9. Check all indicator lamps
10. Check conduit and wiring
11. Check electrode holder and sensor
12. Check ball float valve / pilot valve and motorised valve
13. Check pump running ampere
14. Check pressure switch setting and pressure gauge

Block No :

462D	465	465A	465B	466A	466B	467A	467B	467C
/	/	/	/	/	/	/	/	/
/	/	/	/	/	/	/	/	/
/	/	/	/	/	/	/	/	/
/	/	/	/	/	/	/	/	/
/	/	/	/	/	/	/	/	/
/	/	/	/	/	/	/	/	/
/	/	/	/	/	/	/	/	/
/	/	/	/	/	/	/	/	/
/	/	/	/	/	/	/	/	/
/	/	/	/	/	/	/	/	/
/	/	/	/	/	/	/	/	/
3.5	3.0	4.5	4.0	4.5	4.5	3.0	3.0	3.5
/	/	/	/	/	/	/	/	/

REMARKS

Name & signature of Technician(s)

1 Selva .

Verified By :

(Name & signature)

2 _____

RED-POWER ELECTRICAL ENGINEERING PTE LTD

BLK 16 DEFU LANE 10. #01 - 364. SINGAPORE 539197

TEL : 6 289 2298

FAX : 6 287 9635

TOWN COUNCIL

NEE SOON TOWN COUNCIL

LOCATION

NEE SOON LINK DIVISION

DATE OF SERVICING

5 /09/2025

WEEKLY PRESSURE TANK CHECKLIST REPORT

1. Test run of pumps
2. Check pump and motor running condition
3. Check coupling set, baseplate and spring isolator
4. Check mechanical seal / gland-packing and bearings
5. Check all pipe work, check valve, gate valve, expansion joint, strainer
6. Check correct function of pump system in auto and manual mode
7. Check control panel and electrical isolator
8. Check electrical components in control panel
9. Check all indicator lamps
10. Check conduit and wiring
11. Check electrode holder and sensor
12. Check ball float valve / pilot valve and motorised valve
13. Check pump running ampere
14. Check pressure switch setting and pressure gauge

Block No :

468	468A	469A	469B	470A	470B	471A	471B	472A
/	/	/	/	/	/	/	/	/
/	/	/	/	/	/	/	/	/
/	/	/	/	/	/	/	/	/
/	/	/	/	/	/	/	/	/
/	/	/	/	/	/	/	/	/
/	/	/	/	/	/	/	/	/
/	/	/	/	/	/	/	/	/
/	/	/	/	/	/	/	/	/
/	/	/	/	/	/	/	/	/
3.0	4.0	3.5	4.5	3.5	3.0	4.0	4.5	4.5
/	/	/	/	/	/	/	/	/

REMARKS

Name & signature of Technician(s)



Verified By :


(Name & signature)

2 _____

RED-POWER ELECTRICAL ENGINEERING PTE LTD

BLK 16 DEFU LANE 10. #01 - 364. SINGAPORE 539197

TEL : 6 289 2298

FAX : 6 287 9635

TOWN COUNCIL

NEE SOON TOWN COUNCIL

LOCATION

NEE SOON LINK DIVISION

DATE OF SERVICING

5 /09/2025

WEEKLY PRESSURE TANK CHECKLIST REPORT

1. Test run of pumps
2. Check pump and motor running condition
3. Check coupling set, baseplate and spring isolator
4. Check mechanical seal / gland-packing and bearings
5. Check all pipe work, check valve, gate valve, expansion joint, strainer
6. Check correct function of pump system in auto and manual mode
7. Check control panel and electrical isolator
8. Check electrical components in control panel
9. Check all indicator lamps
10. Check conduit and wiring
11. Check electrode holder and sensor
12. Check ball float valve / pilot valve and motorised valve
13. Check pump running ampere
14. Check pressure switch setting and pressure gauge

Block No :

472B	473A	473B	475A	475B	476	476A	476B	476C
/	/	/	/	/	/	/	/	/
/	/	/	/	/	/	/	/	/
/	/	/	/	/	/	/	/	/
/	/	/	/	/	/	/	/	/
/	/	/	/	/	/	/	/	/
/	/	/	/	/	/	/	/	/
/	/	/	/	/	/	/	/	/
/	/	/	/	/	/	/	/	/
/	/	/	/	/	/	/	/	/
3.0	3.5	4.0	4.5	4.0	4.5	3.5	3.5	3.0
/	/	/	/	/	/	/	/	/

REMARKS

Name & signature of Technician(s)

1 Selva A.

Verified By :

(Name & signature)

2 _____

RED-POWER ELECTRICAL ENGINEERING PTE LTD

BLK 16 DEFU LANE 10. #01 - 364. SINGAPORE 539197

TEL : 6 289 2298

FAX : 6 287 9635

TOWN COUNCIL

NEE SOON TOWN COUNCIL

LOCATION

NEE SOON LINK DIVISION

DATE OF SERVICING

5/09/2025

WEEKLY PRESSURE TANK CHECKLIST REPORT

1. Test run of pumps
2. Check pump and motor running condition
3. Check coupling set, baseplate and spring isolator
4. Check mechanical seal / gland-packing and bearings
5. Check all pipe work, check valve, gate valve, expansion joint, strainer
6. Check correct function of pump system in auto and manual mode
7. Check control panel and electrical isolator
8. Check electrical components in control panel
9. Check all indicator lamps
10. Check conduit and wiring
11. Check electrode holder and sensor
12. Check ball float valve / pilot valve and motorised valve
13. Check pump running ampere
14. Check pressure switch setting and pressure gauge

Block No :

477A	477B	477C	478	478A	478B	478C	479A	479B
/	/	/	/	/	/	/	/	/
/	/	/	/	/	/	/	/	/
/	/	/	/	/	/	/	/	/
/	/	/	/	/	/	/	/	/
/	/	/	/	/	/	/	/	/
/	/	/	/	/	/	/	/	/
/	/	/	/	/	/	/	/	/
/	/	/	/	/	/	/	/	/
30	38	40	45	48	50	35	35	45
/	/	/	/	/	/	/	/	/

REMARKS

Name & signature of Technician(s)

1 Delva

Verified By :

(Name & signature)

2 _____

RED-POWER ELECTRICAL ENGINEERING PTE LTD

BLK 16 DEFU LANE 10. #01 - 364. SINGAPORE 539197

TEL : 6 289 2298

FAX : 6 287 9635

TOWN COUNCIL

NEE SOON TOWN COUNCIL

LOCATION

NEE SOON LINK DIVISION

DATE OF SERVICING

5 /09/2025

WEEKLY PRESSURE TANK CHECKLIST REPORT

1. Test run of pumps
2. Check pump and motor running condition
3. Check coupling set, baseplate and spring isolator
4. Check mechanical seal / gland-packing and bearings
5. Check all pipe work, check valve, gate valve, expansion joint, strainer
6. Check correct function of pump system in auto and manual mode
7. Check control panel and electrical isolator
8. Check electrical components in control panel
9. Check all indicator lamps
10. Check conduit and wiring
11. Check electrode holder and sensor
12. Check ball float valve / pilot valve and motorised valve
13. Check pump running ampere
14. Check pressure switch setting and pressure gauge

Block No :

479C	-	-	-	-	-	-	-	-	-
/	-	-	-	-	-	-	-	-	-
/	-	-	-	-	-	-	-	-	-
/	-	-	-	-	-	-	-	-	-
/	-	-	-	-	-	-	-	-	-
/	-	-	-	-	-	-	-	-	-
/	-	-	-	-	-	-	-	-	-
/	-	-	-	-	-	-	-	-	-
/	-	-	-	-	-	-	-	-	-
/	-	-	-	-	-	-	-	-	-
3-X	-	-	-	-	-	-	-	-	-
/	-	-	-	-	-	-	-	-	-

REMARKS

Name & signature of Technician(s)

Verified By :

1 Sohna Lat.

(Name & signature)

2 _____

RED-POWER ELECTRICAL ENGINEERING PTE LTD

BLK 16 DEFU LANE 10. #01 - 364. SINGAPORE 539197

TEL : 6 289 2298

FAX : 6 287 9635

TOWN COUNCIL

NEE SOON TOWN COUNCIL

LOCATION

NEE SOON LINK DIVISION

DATE OF SERVICING

11 /09/2025

WEEKLY PRESSURE TANK CHECKLIST REPORT

1. Test run of pumps
2. Check pump and motor running condition
3. Check coupling set, baseplate and spring isolator
4. Check mechanical seal / gland-packing and bearings
5. Check all pipe work, check valve, gate valve, expansion joint, strainer
6. Check correct function of pump system in auto and manual mode
7. Check control panel and electrical isolator
8. Check electrical components in control panel
9. Check all indicator lamps
10. Check conduit and wiring
11. Check electrode holder and sensor
12. Check ball float valve / pilot valve and motorised valve
13. Check pump running ampere
14. Check pressure switch setting and pressure gauge

Block No :

385	419A	424A	424B	424C	424D	426	426A	426B
/	/	/	/	/	/	/	/	/
/	/	/	/	/	/	/	/	/
/	/	/	/	/	/	/	/	/
/	/	/	/	/	/	/	/	/
/	/	/	/	/	/	/	/	/
/	/	/	/	/	/	/	/	/
/	/	/	/	/	/	/	/	/
/	/	/	/	/	/	/	/	/
/	/	/	/	/	/	/	/	/
4.0	3.5	3.0	3.5	3.0	4.0	4.5	4.0	4.5

REMARKS

Name & signature of Technician(s)

1 Selva Raj

2 _____

Verified By :

(Name & signature)

RED-POWER ELECTRICAL ENGINEERING PTE LTD

BLK 16 DEFU LANE 10. #01 - 364. SINGAPORE 539197

TEL : 6 289 2298

FAX : 6 287 9635

TOWN COUNCIL

NEE SOON TOWN COUNCIL

LOCATION

NEE SOON LINK DIVISION

DATE OF SERVICING

11 /09/2025

WEEKLY PRESSURE TANK CHECKLIST REPORT

1. Test run of pumps
2. Check pump and motor running condition
3. Check coupling set, baseplate and spring isolator
4. Check mechanical seal / gland-packing and bearings
5. Check all pipe work, check valve, gate valve, expansion joint, strainer
6. Check correct function of pump system in auto and manual mode
7. Check control panel and electrical isolator
8. Check electrical components in control panel
9. Check all indicator lamps
10. Check conduit and wiring
11. Check electrode holder and sensor
12. Check ball float valve / pilot valve and motorised valve
13. Check pump running ampere
14. Check pressure switch setting and pressure gauge

Block No :

426C	426D	428A	428B	429	429A	429B	430	430A
/	/	/	/	/	/	/	/	/
/	/	/	/	/	/	/	/	/
/	/	/	/	/	/	/	/	/
/	/	/	/	/	/	/	/	/
/	/	/	/	/	/	/	/	/
/	/	/	/	/	/	/	/	/
/	/	/	/	/	/	/	/	/
/	/	/	/	/	/	/	/	/
/	/	/	/	/	/	/	/	/
/	/	/	/	/	/	/	/	/
/	/	/	/	/	/	/	/	/
3.0	4.5	4.0	3.5	4.0	4.5	3.0	3.5	3.0
/	/	/	/	/	/	/	/	/

REMARKS

Name & signature of Technician(s)

1 Selva A.

Verified By :

(Name & signature)

2 _____

RED-POWER ELECTRICAL ENGINEERING PTE LTD

BLK 16 DEFU LANE 10. #01 - 364. SINGAPORE 539197

TEL : 6 289 2298

FAX : 6 287 9635

TOWN COUNCIL

NEE SOON TOWN COUNCIL

LOCATION

NEE SOON LINK DIVISION

DATE OF SERVICING

11 /09/2025

WEEKLY PRESSURE TANK CHECKLIST REPORT

1. Test run of pumps
2. Check pump and motor running condition
3. Check coupling set, baseplate and spring isolator
4. Check mechanical seal / gland-packing and bearings
5. Check all pipe work, check valve, gate valve, expansion joint, strainer
6. Check correct function of pump system in auto and manual mode
7. Check control panel and electrical isolator
8. Check electrical components in control panel
9. Check all indicator lamps
10. Check conduit and wiring
11. Check electrode holder and sensor
12. Check ball float valve / pilot valve and motorised valve
13. Check pump running ampere
14. Check pressure switch setting and pressure gauge

Block No :

430B	431	431A	431B	431C	431D	432A	432B	432C
/	/	/	/	/	/	/	/	/
/	/	/	/	/	/	/	/	/
/	/	/	/	/	/	/	/	/
/	/	/	/	/	/	/	/	/
/	/	/	/	/	/	/	/	/
/	/	/	/	/	/	/	/	/
/	/	/	/	/	/	/	/	/
/	/	/	/	/	/	/	/	/
/	/	/	/	/	/	/	/	/
4.5	3.0	3.5	3.0	4.0	4.5	4.0	3.5	3.0
/	/	/	/	/	/	/	/	/

REMARKS

Name & signature of Technician(s)

1 Selva R -

Verified By :

(Name & signature)

2 _____

RED-POWER ELECTRICAL ENGINEERING PTE LTD

BLK 16 DEFU LANE 10. #01 - 364. SINGAPORE 539197

TEL : 6 289 2298

FAX : 6 287 9635

TOWN COUNCIL

NEE SOON TOWN COUNCIL

LOCATION

NEE SOON LINK DIVISION

DATE OF SERVICING

11 /09/2025

WEEKLY PRESSURE TANK CHECKLIST REPORT

1. Test run of pumps
2. Check pump and motor running condition
3. Check coupling set, baseplate and spring isolator
4. Check mechanical seal / gland-packing and bearings
5. Check all pipe work, check valve, gate valve, expansion joint, strainer
6. Check correct function of pump system in auto and manual mode
7. Check control panel and electrical isolator
8. Check electrical components in control panel
9. Check all indicator lamps
10. Check conduit and wiring
11. Check electrode holder and sensor
12. Check ball float valve / pilot valve and motorised valve
13. Check pump running ampere
14. Check pressure switch setting and pressure gauge

Block No :

432D	436	438	441	453	454	455	456	456A
/	/	/	/	/	/	/	/	/
/	/	/	/	/	/	/	/	/
/	/	/	/	/	/	/	/	/
/	/	/	/	/	/	/	/	/
/	/	/	/	/	/	/	/	/
/	/	/	/	/	/	/	/	/
/	/	/	/	/	/	/	/	/
/	/	/	/	/	/	/	/	/
/	/	/	/	/	/	/	/	/
3.5	4.5	3.0	4.0	4.5	4.0	3.5	3.5	3.0
/	/	/	/	/	/	/	/	/

Selva *et* .

RED-POWER ELECTRICAL ENGINEERING PTE LTD

BLK 16 DEFU LANE 10. #01 - 364. SINGAPORE 539197

TEL : 6 289 2298

FAX : 6 287 9635

TOWN COUNCIL

NEE SOON TOWN COUNCIL

LOCATION

NEE SOON LINK DIVISION

DATE OF SERVICING

11 /09/2025

WEEKLY PRESSURE TANK CHECKLIST REPORT

1. Test run of pumps
2. Check pump and motor running condition
3. Check coupling set, baseplate and spring isolator
4. Check mechanical seal / gland-packing and bearings
5. Check all pipe work, check valve, gate valve, expansion joint, strainer
6. Check correct function of pump system in auto and manual mode
7. Check control panel and electrical isolator
8. Check electrical components in control panel
9. Check all indicator lamps
10. Check conduit and wiring
11. Check electrode holder and sensor
12. Check ball float valve / pilot valve and motorised valve
13. Check pump running ampere
14. Check pressure switch setting and pressure gauge

Block No :

457	458	459	461	461A	461B	462A	462B	462C
/	/	/	/	/	/	/	/	/
/	/	/	/	/	/	/	/	/
/	/	/	/	/	/	/	/	/
/	/	/	/	/	/	/	/	/
/	/	/	/	/	/	/	/	/
/	/	/	/	/	/	/	/	/
/	/	/	/	/	/	/	/	/
/	/	/	/	/	/	/	/	/
/	/	/	/	/	/	/	/	/
/	/	/	/	/	/	/	/	/
3035	45	40	4535	40	4030			
/	/	/	/	/	/	/	/	/

REMARKS

Name & signature of Technician(s)

1 Schwa KA -

Verified By :

(Name & signature)

2 _____

RED-POWER ELECTRICAL ENGINEERING PTE LTD

BLK 16 DEFU LANE 10. #01 - 364. SINGAPORE 539197

TEL : 6 289 2298

FAX : 6 287 9635

TOWN COUNCIL

NEE SOON TOWN COUNCIL

LOCATION

NEE SOON LINK DIVISION

DATE OF SERVICING

12 /09/2025

WEEKLY PRESSURE TANK CHECKLIST REPORT

1. Test run of pumps
2. Check pump and motor running condition
3. Check coupling set, baseplate and spring isolator
4. Check mechanical seal / gland-packing and bearings
5. Check all pipe work, check valve, gate valve, expansion joint, strainer
6. Check correct function of pump system in auto and manual mode
7. Check control panel and electrical isolator
8. Check electrical components in control panel
9. Check all indicator lamps
10. Check conduit and wiring
11. Check electrode holder and sensor
12. Check ball float valve / pilot valve and motorised valve
13. Check pump running ampere
14. Check pressure switch setting and pressure gauge

Block No :

462D	465	465A	465B	466A	466B	467A	467B	467C
/	/	/	/	/	/	/	/	/
/	/	/	/	/	/	/	/	/
/	/	/	/	/	/	/	/	/
/	/	/	/	/	/	/	/	/
/	/	/	/	/	/	/	/	/
/	/	/	/	/	/	/	/	/
/	/	/	/	/	/	/	/	/
/	/	/	/	/	/	/	/	/
/	/	/	/	/	/	/	/	/
/	/	/	/	/	/	/	/	/
3.0	4.5	3.8	3.0	4.0	4.5	3.5	3.0	3.5
/	/	/	/	/	/	/	/	/

REMARKS

Name & signature of Technician(s)

Verified By :

1 Selvaraj -

(Name & signature)

2 _____

RED-POWER ELECTRICAL ENGINEERING PTE LTD

BLK 16 DEFU LANE 10. #01 - 364. SINGAPORE 539197

TEL : 6 289 2298

FAX : 6 287 9635

TOWN COUNCIL

NEE SOON TOWN COUNCIL

LOCATION

NEE SOON LINK DIVISION

DATE OF SERVICING

12/09/2025

WEEKLY PRESSURE TANK CHECKLIST REPORT

1. Test run of pumps
2. Check pump and motor running condition
3. Check coupling set, baseplate and spring isolator
4. Check mechanical seal / gland-packing and bearings
5. Check all pipe work, check valve, gate valve, expansion joint, strainer
6. Check correct function of pump system in auto and manual mode
7. Check control panel and electrical isolator
8. Check electrical components in control panel
9. Check all indicator lamps
10. Check conduit and wiring
11. Check electrode holder and sensor
12. Check ball float valve / pilot valve and motorised valve
13. Check pump running ampere
14. Check pressure switch setting and pressure gauge

Block No :

468	468A	469A	469B	470A	470B	471A	471B	472A
/	/	/	/	/	/	/	/	/
/	/	/	/	/	/	/	/	/
/	/	/	/	/	/	/	/	/
/	/	/	/	/	/	/	/	/
/	/	/	/	/	/	/	/	/
/	/	/	/	/	/	/	/	/
/	/	/	/	/	/	/	/	/
/	/	/	/	/	/	/	/	/
3.0	3.5	4.0	4.5	3.0	3.0	3.0	3.5	4.0
/	/	/	/	/	/	/	/	/

REMARKS

Name & signature of Technician(s)

1 Selma M.

Verified By :

(Name & signature)

2 _____

RED-POWER ELECTRICAL ENGINEERING PTE LTD

BLK 16 DEFU LANE 10. #01 - 364. SINGAPORE 539197

TEL : 6 289 2298

FAX : 6 287 9635

TOWN COUNCIL

NEE SOON TOWN COUNCIL

LOCATION

NEE SOON LINK DIVISION

DATE OF SERVICING

12/09/2025

WEEKLY PRESSURE TANK CHECKLIST REPORT

1. Test run of pumps
2. Check pump and motor running condition
3. Check coupling set, baseplate and spring isolator
4. Check mechanical seal / gland-packing and bearings
5. Check all pipe work, check valve, gate valve, expansion joint, strainer
6. Check correct function of pump system in auto and manual mode
7. Check control panel and electrical isolator
8. Check electrical components in control panel
9. Check all indicator lamps
10. Check conduit and wiring
11. Check electrode holder and sensor
12. Check ball float valve / pilot valve and motorised valve
13. Check pump running ampere
14. Check pressure switch setting and pressure gauge

Block No :

472B	473A	473B	475A	475B	476	476A	476B	476C
/	/	/	/	/	/	/	/	/
/	/	/	/	/	/	/	/	/
/	/	/	/	/	/	/	/	/
/	/	/	/	/	/	/	/	/
/	/	/	/	/	/	/	/	/
/	/	/	/	/	/	/	/	/
/	/	/	/	/	/	/	/	/
/	/	/	/	/	/	/	/	/
/	/	/	/	/	/	/	/	/
/	/	/	/	/	/	/	/	/
3.0	3.5	4.5	4.0	4.5	3.5	3.0	3.0	3.5
/	/	/	/	/	/	/	/	/

REMARKS

Name & signature of Technician(s)

1 Selva M -

Verified By :

(Name & signature)

2 _____

RED-POWER ELECTRICAL ENGINEERING PTE LTD

BLK 16 DEFU LANE 10. #01 - 364. SINGAPORE 539197

TEL : 6 289 2298

FAX : 6 287 9635

TOWN COUNCIL

NEE SOON TOWN COUNCIL

LOCATION

NEE SOON LINK DIVISION

DATE OF SERVICING

12/09/2025

WEEKLY PRESSURE TANK CHECKLIST REPORT

1. Test run of pumps
2. Check pump and motor running condition
3. Check coupling set, baseplate and spring isolator
4. Check mechanical seal / gland-packing and bearings
5. Check all pipe work, check valve, gate valve, expansion joint, strainer
6. Check correct function of pump system in auto and manual mode
7. Check control panel and electrical isolator
8. Check electrical components in control panel
9. Check all indicator lamps
10. Check conduit and wiring
11. Check electrode holder and sensor
12. Check ball float valve / pilot valve and motorised valve
13. Check pump running ampere
14. Check pressure switch setting and pressure gauge

Block No :

477A	477B	477C	478	478A	478B	478C	479A	479B
/	/	/	/	/	/	/	/	/
/	/	/	/	/	/	/	/	/
/	/	/	/	/	/	/	/	/
/	/	/	/	/	/	/	/	/
/	/	/	/	/	/	/	/	/
/	/	/	/	/	/	/	/	/
/	/	/	/	/	/	/	/	/
/	/	/	/	/	/	/	/	/
/	/	/	/	/	/	/	/	/
4.0	3.8	3.0	3.8	4.0	4.5	4.0	4.5	3.5
/	/	/	/	/	/	/	/	/

REMARKS

Name & signature of Technician(s)

1 Selva M.

Verified By :

(Name & signature)

2 _____

RED-POWER ELECTRICAL ENGINEERING PTE LTD

BLK 16 DEFU LANE 10. #01 - 364. SINGAPORE 539197

TEL : 6 289 2298

FAX : 6 287 9635

TOWN COUNCIL

NEE SOON TOWN COUNCIL

LOCATION

NEE SOON LINK DIVISION

DATE OF SERVICING

12/09/2025

WEEKLY PRESSURE TANK CHECKLIST REPORT

1. Test run of pumps
2. Check pump and motor running condition
3. Check coupling set, baseplate and spring isolator
4. Check mechanical seal / gland-packing and bearings
5. Check all pipe work, check valve, gate valve, expansion joint, strainer
6. Check correct function of pump system in auto and manual mode
7. Check control panel and electrical isolator
8. Check electrical components in control panel
9. Check all indicator lamps
10. Check conduit and wiring
11. Check electrode holder and sensor
12. Check ball float valve / pilot valve and motorised valve
13. Check pump running ampere
14. Check pressure switch setting and pressure gauge

Block No :

479C	-	-	-	-	-	-	-	-	-
/	-	-	-	-	-	-	-	-	-
/	-	-	-	-	-	-	-	-	-
/	-	-	-	-	-	-	-	-	-
/	-	-	-	-	-	-	-	-	-
/	-	-	-	-	-	-	-	-	-
/	-	-	-	-	-	-	-	-	-
/	-	-	-	-	-	-	-	-	-
/	-	-	-	-	-	-	-	-	-
/	-	-	-	-	-	-	-	-	-
4-5	-	-	-	-	-	-	-	-	-
/	-	-	-	-	-	-	-	-	-

REMARKS

Name & signature of Technician(s)

1 Debra -

Verified By :

(Name & signature)

2 _____

RED-POWER ELECTRICAL ENGINEERING PTE LTD

BLK 16 DEFU LANE 10. #01 - 364. SINGAPORE 539197

TEL : 6 289 2298

FAX : 6 287 9635

TOWN COUNCIL

NEE SOON TOWN COUNCIL

LOCATION

NEE SOON LINK DIVISION

DATE OF SERVICING

18 /09/2025

WEEKLY PRESSURE TANK CHECKLIST REPORT

1. Test run of pumps
2. Check pump and motor running condition
3. Check coupling set, baseplate and spring isolator
4. Check mechanical seal / gland-packing and bearings
5. Check all pipe work, check valve, gate valve, expansion joint, strainer
6. Check correct function of pump system in auto and manual mode
7. Check control panel and electrical isolator
8. Check electrical components in control panel
9. Check all indicator lamps
10. Check conduit and wiring
11. Check electrode holder and sensor
12. Check ball float valve / pilot valve and motorised valve
13. Check pump running ampere
14. Check pressure switch setting and pressure gauge

Block No :

385	419A	424A	424B	424C	424D	426	426A	426B
/	/	/	/	/	/	/	/	/
/	/	/	/	/	/	/	/	/
/	/	/	/	/	/	/	/	/
/	/	/	/	/	/	/	/	/
/	/	/	/	/	/	/	/	/
/	/	/	/	/	/	/	/	/
/	/	/	/	/	/	/	/	/
/	/	/	/	/	/	/	/	/
25	20	40	45	40	40	40	28	30
/	/	/	/	/	/	/	/	/

REMARKS

Name & signature of Technician(s)

Verified By :

1 Selva M

(Name & signature)

2 _____

RED-POWER ELECTRICAL ENGINEERING PTE LTD

BLK 16 DEFU LANE 10. #01 - 364. SINGAPORE 539197

TEL : 6 289 2298

FAX : 6 287 9635

TOWN COUNCIL

NEE SOON TOWN COUNCIL

LOCATION

NEE SOON LINK DIVISION

DATE OF SERVICING

18/09/2025

WEEKLY PRESSURE TANK CHECKLIST REPORT

1. Test run of pumps
2. Check pump and motor running condition
3. Check coupling set, baseplate and spring isolator
4. Check mechanical seal / gland-packing and bearings
5. Check all pipe work, check valve, gate valve, expansion joint, strainer
6. Check correct function of pump system in auto and manual mode
7. Check control panel and electrical isolator
8. Check electrical components in control panel
9. Check all indicator lamps
10. Check conduit and wiring
11. Check electrode holder and sensor
12. Check ball float valve / pilot valve and motorised valve
13. Check pump running ampere
14. Check pressure switch setting and pressure gauge

Block No :

426C	426D	428A	428B	429	429A	429B	430	430A
/	/	/	/	/	/	/	/	/
/	/	/	/	/	/	/	/	/
/	/	/	/	/	/	/	/	/
/	/	/	/	/	/	/	/	/
/	/	/	/	/	/	/	/	/
/	/	/	/	/	/	/	/	/
/	/	/	/	/	/	/	/	/
/	/	/	/	/	/	/	/	/
/	/	/	/	/	/	/	/	/
/	/	/	/	/	/	/	/	/
3.0	3.5	4.5	4.0	4.5	3.5	3.5	3.0	3.5
/	/	/	/	/	/	/	/	/

REMARKS

Name & signature of Technician(s)

Verified By :

1 Selvaraj.

(Name & signature)

2 _____

RED-POWER ELECTRICAL ENGINEERING PTE LTD

BLK 16 DEFU LANE 10. #01 - 364. SINGAPORE 539197

TEL : 6 289 2298

FAX : 6 287 9635

TOWN COUNCIL

NEE SOON TOWN COUNCIL

LOCATION

NEE SOON LINK DIVISION

DATE OF SERVICING

18 /09/2025

WEEKLY PRESSURE TANK CHECKLIST REPORT

1. Test run of pumps
2. Check pump and motor running condition
3. Check coupling set, baseplate and spring isolator
4. Check mechanical seal / gland-packing and bearings
5. Check all pipe work, check valve, gate valve, expansion joint, strainer
6. Check correct function of pump system in auto and manual mode
7. Check control panel and electrical isolator
8. Check electrical components in control panel
9. Check all indicator lamps
10. Check conduit and wiring
11. Check electrode holder and sensor
12. Check ball float valve / pilot valve and motorised valve
13. Check pump running ampere
14. Check pressure switch setting and pressure gauge

Block No :

430B	431	431A	431B	431C	431D	432A	432B	432C
/	/	/	/	/	/	/	/	/
/	/	/	/	/	/	/	/	/
/	/	/	/	/	/	/	/	/
/	/	/	/	/	/	/	/	/
/	/	/	/	/	/	/	/	/
/	/	/	/	/	/	/	/	/
/	/	/	/	/	/	/	/	/
/	/	/	/	/	/	/	/	/
/	/	/	/	/	/	/	/	/
4.5	3.5	2.5	3.0	3.0	3.5	3.5	3.0	3.5
/	/	/	/	/	/	/	/	/

REMARKS

Name & signature of Technician(s)

Verified By :

1 Selvaraj.

(Name & signature)

2 _____

RED-POWER ELECTRICAL ENGINEERING PTE LTD

BLK 16 DEFU LANE 10. #01 - 364. SINGAPORE 539197

TEL : 6 289 2298

FAX : 6 287 9635

TOWN COUNCIL

NEE SOON TOWN COUNCIL

LOCATION

NEE SOON LINK DIVISION

DATE OF SERVICING

18 /09/2025

WEEKLY PRESSURE TANK CHECKLIST REPORT

1. Test run of pumps
2. Check pump and motor running condition
3. Check coupling set, baseplate and spring isolator
4. Check mechanical seal / gland-packing and bearings
5. Check all pipe work, check valve, gate valve, expansion joint, strainer
6. Check correct function of pump system in auto and manual mode
7. Check control panel and electrical isolator
8. Check electrical components in control panel
9. Check all indicator lamps
10. Check conduit and wiring
11. Check electrode holder and sensor
12. Check ball float valve / pilot valve and motorised valve
13. Check pump running ampere
14. Check pressure switch setting and pressure gauge

Block No :

432D	436	438	441	453	454	455	456	456A
/	/	/	/	/	/	/	/	/
/	/	/	/	/	/	/	/	/
/	/	/	/	/	/	/	/	/
/	/	/	/	/	/	/	/	/
/	/	/	/	/	/	/	/	/
/	/	/	/	/	/	/	/	/
/	/	/	/	/	/	/	/	/
/	/	/	/	/	/	/	/	/
/	/	/	/	/	/	/	/	/
/	/	/	/	/	/	/	/	/
3.5	4.5	3.0	4.0	4.5	3.5	3.0	3.5	3.5
/	/	/	/	/	/	/	/	/

Selva M.

RED-POWER ELECTRICAL ENGINEERING PTE LTD

BLK 16 DEFU LANE 10. #01 - 364. SINGAPORE 539197

TEL : 6 289 2298

FAX : 6 287 9635

TOWN COUNCIL

NEE SOON TOWN COUNCIL

LOCATION

NEE SOON LINK DIVISION

DATE OF SERVICING

18 /09/2025

74

WEEKLY PRESSURE TANK CHECKLIST REPORT

1. Test run of pumps
2. Check pump and motor running condition
3. Check coupling set, baseplate and spring isolator
4. Check mechanical seal / gland-packing and bearings
5. Check all pipe work, check valve, gate valve, expansion joint, strainer
6. Check correct function of pump system in auto and manual mode
7. Check control panel and electrical isolator
8. Check electrical components in control panel
9. Check all indicator lamps
10. Check conduit and wiring
11. Check electrode holder and sensor
12. Check ball float valve / pilot valve and motorised valve
13. Check pump running ampere
14. Check pressure switch setting and pressure gauge

Block No :

457	458	459	461	461A	461B	462A	462B	462C
/	/	/	/	/	/	/	/	/
/	/	/	/	/	/	/	/	/
/	/	/	/	/	/	/	/	/
/	/	/	/	/	/	/	/	/
/	/	/	/	/	/	/	/	/
/	/	/	/	/	/	/	/	/
/	/	/	/	/	/	/	/	/
/	/	/	/	/	/	/	/	/
/	/	/	/	/	/	/	/	/
3.5	3.0	3.5	3.0	3.5	4.5	4.0	4.5	4.0
/	/	/	/	/	/	/	/	/

REMARKS

Name & signature of Technician(s)

1 selva A -

Verified By :

(Name & signature)

2 _____

RED-POWER ELECTRICAL ENGINEERING PTE LTD

BLK 16 DEFU LANE 10. #01 - 364. SINGAPORE 539197

TEL : 6 289 2298

FAX : 6 287 9635

TOWN COUNCIL

NEE SOON TOWN COUNCIL

LOCATION

NEE SOON LINK DIVISION

DATE OF SERVICING

19/09/2025

WEEKLY PRESSURE TANK CHECKLIST REPORT

1. Test run of pumps
2. Check pump and motor running condition
3. Check coupling set, baseplate and spring isolator
4. Check mechanical seal / gland-packing and bearings
5. Check all pipe work, check valve, gate valve, expansion joint, strainer
6. Check correct function of pump system in auto and manual mode
7. Check control panel and electrical isolator
8. Check electrical components in control panel
9. Check all indicator lamps
10. Check conduit and wiring
11. Check electrode holder and sensor
12. Check ball float valve / pilot valve and motorised valve
13. Check pump running ampere
14. Check pressure switch setting and pressure gauge

Block No :

462D	465	465A	465B	466A	466B	467A	467B	467C
/	/	/	/	/	/	/	/	/
/	/	/	/	/	/	/	/	/
/	/	/	/	/	/	/	/	/
/	/	/	/	/	/	/	/	/
/	/	/	/	/	/	/	/	/
/	/	/	/	/	/	/	/	/
/	/	/	/	/	/	/	/	/
/	/	/	/	/	/	/	/	/
/	/	/	/	/	/	/	/	/
4.0	4.5	3.0	3.5	3.5	4.5	3.5	3.0	3.5
/	/	/	/	/	/	/	/	/

REMARKS

Name & signature of Technician(s)

Verified By :

1 Selva -

(Name & signature)

2 _____

RED-POWER ELECTRICAL ENGINEERING PTE LTD

BLK 16 DEFU LANE 10. #01 - 364. SINGAPORE 539197

TEL : 6 289 2298

FAX : 6 287 9635

TOWN COUNCIL

NEE SOON TOWN COUNCIL

LOCATION

NEE SOON LINK DIVISION

DATE OF SERVICING

10/ /09/2025

WEEKLY PRESSURE TANK CHECKLIST REPORT

1. Test run of pumps
2. Check pump and motor running condition
3. Check coupling set, baseplate and spring isolator
4. Check mechanical seal / gland-packing and bearings
5. Check all pipe work, check valve, gate valve, expansion joint, strainer
6. Check correct function of pump system in auto and manual mode
7. Check control panel and electrical isolator
8. Check electrical components in control panel
9. Check all indicator lamps
10. Check conduit and wiring
11. Check electrode holder and sensor
12. Check ball float valve / pilot valve and motorised valve
13. Check pump running ampere
14. Check pressure switch setting and pressure gauge

Block No :

468	468A	469A	469B	470A	470B	471A	471B	472A
/	/	/	/	/	/	/	/	/
/	/		/	/	/	/	/	/
/	/		/	/	/	/	/	/
/	/		/	/	/	/	/	/
/	/		/	/	/	/	/	/
/	/		/	/	/	/	/	/
/	/		/	/	/	/	/	/
/	/		/	/	/	/	/	/
3.0	4.5	4.0	4.5	3.5	3.5	3.0	4.0	3.8
/	/	/	/	/	/	/	/	/

REMARKS

Name & signature of Technician(s)

Verified By :

1 Selvaraj .

(Name & signature)

2 _____

RED-POWER ELECTRICAL ENGINEERING PTE LTD

BLK 16 DEFU LANE 10. #01 - 364. SINGAPORE 539197

TEL : 6 289 2298

FAX : 6 287 9635

TOWN COUNCIL

NEE SOON TOWN COUNCIL

LOCATION

NEE SOON LINK DIVISION

DATE OF SERVICING

19 /09/2025

WEEKLY PRESSURE TANK CHECKLIST REPORT

1. Test run of pumps
2. Check pump and motor running condition
3. Check coupling set, baseplate and spring isolator
4. Check mechanical seal / gland-packing and bearings
5. Check all pipe work, check valve, gate valve, expansion joint, strainer
6. Check correct function of pump system in auto and manual mode
7. Check control panel and electrical isolator
8. Check electrical components in control panel
9. Check all indicator lamps
10. Check conduit and wiring
11. Check electrode holder and sensor
12. Check ball float valve / pilot valve and motorised valve
13. Check pump running ampere
14. Check pressure switch setting and pressure gauge

Block No :

472B	473A	473B	475A	475B	476	476A	476B	476C
/	/	/	/	/	/	/	/	/
/	/	/	/	/	/	/	/	/
/	/	/	/	/	/	/	/	/
/	/	/	/	/	/	/	/	/
/	/	/	/	/	/	/	/	/
/	/	/	/	/	/	/	/	/
/	/	/	/	/	/	/	/	/
/	/	/	/	/	/	/	/	/
/	/	/	/	/	/	/	/	/
2.5	3.5	4.0	3.0	4.5	3.5	3.8	3.0	4.0
/	/	/	/	/	/	/	/	/

REMARKS

Name & signature of Technician(s)

Verified By :

Selva M.

(Name & signature)

2 _____

RED-POWER ELECTRICAL ENGINEERING PTE LTD

BLK 16 DEFU LANE 10. #01 - 364. SINGAPORE 539197

TEL : 6 289 2298

FAX : 6 287 9635

TOWN COUNCIL

NEE SOON TOWN COUNCIL

LOCATION

NEE SOON LINK DIVISION

DATE OF SERVICING

09/2025

12

WEEKLY PRESSURE TANK CHECKLIST REPORT

1. Test run of pumps
 2. Check pump and motor running condition
 3. Check coupling set, baseplate and spring isolator
 4. Check mechanical seal / gland-packing and bearings
 5. Check all pipe work, check valve, gate valve, expansion joint, strainer
 6. Check correct function of pump system in auto and manual mode
 7. Check control panel and electrical isolator
 8. Check electrical components in control panel
 9. Check all indicator lamps
 10. Check conduit and wiring
 11. Check electrode holder and sensor
 12. Check ball float valve / pilot valve and motorised valve
 13. Check pump running ampere
 14. Check pressure switch setting and pressure gauge

Block No :

REMARKS

Name & signature of Technician(s)

Verified By :

1 Seller's

(Name & signature)

2 _____

RED-POWER ELECTRICAL ENGINEERING PTE LTD

BLK 16 DEFU LANE 10. #01 - 364. SINGAPORE 539197

TEL : 6 289 2298

FAX : 6 287 9635

TOWN COUNCIL

NEE SOON TOWN COUNCIL

LOCATION

NEE SOON LINK DIVISION

DATE OF SERVICING

19 /09/2025

WEEKLY PRESSURE TANK CHECKLIST REPORT

1. Test run of pumps
2. Check pump and motor running condition
3. Check coupling set, baseplate and spring isolator
4. Check mechanical seal / gland-packing and bearings
5. Check all pipe work, check valve, gate valve, expansion joint, strainer
6. Check correct function of pump system in auto and manual mode
7. Check control panel and electrical isolator
8. Check electrical components in control panel
9. Check all indicator lamps
10. Check conduit and wiring
11. Check electrode holder and sensor
12. Check ball float valve / pilot valve and motorised valve
13. Check pump running ampere
14. Check pressure switch setting and pressure gauge

Block No :

479C	-	-	-	-	-	-	-	-	-	-
/	-	-	-	-	-	-	-	-	-	-
/	-	-	-	-	-	-	-	-	-	-
/	-	-	-	-	-	-	-	-	-	-
/	-	-	-	-	-	-	-	-	-	-
/	-	-	-	-	-	-	-	-	-	-
/	-	-	-	-	-	-	-	-	-	-
/	-	-	-	-	-	-	-	-	-	-
/	-	-	-	-	-	-	-	-	-	-
/	-	-	-	-	-	-	-	-	-	-
35	-	-	-	-	-	-	-	-	-	-
/	-	-	-	-	-	-	-	-	-	-

REMARKS

Name & signature of Technician(s)

1 R. Lee A.

Verified By :

(Name & signature)

2 _____

RED-POWER ELECTRICAL ENGINEERING PTE LTD

BLK 16 DEFU LANE 10. #01 - 364. SINGAPORE 539197

TEL : 6 289 2298

FAX : 6 287 9635

TOWN COUNCIL

NEE SOON TOWN COUNCIL

LOCATION

NEE SOON LINK DIVISION

DATE OF SERVICING

25 /09/2025

WEEKLY PRESSURE TANK CHECKLIST REPORT

1. Test run of pumps
 2. Check pump and motor running condition
 3. Check coupling set, baseplate and spring isolator
 4. Check mechanical seal / gland-packing and bearings
 5. Check all pipe work, check valve, gate valve, expansion joint, strainer
 6. Check correct function of pump system in auto and manual mode
 7. Check control panel and electrical isolator
 8. Check electrical components in control panel
 9. Check all indicator lamps
 10. Check conduit and wiring
 11. Check electrode holder and sensor
 12. Check ball float valve / pilot valve and motorised valve
 13. Check pump running ampere
 14. Check pressure switch setting and pressure gauge

Block No :

REMARKS

Name & signature of Technician(s)

Verified By :

¹ P.Namini Mohi

(Name & signature)

2

RED-POWER ELECTRICAL ENGINEERING PTE LTD

BLK 16 DEFU LANE 10. #01 - 364. SINGAPORE 539197

TEL : 6 289 2298 FAX : 6 287 9635

TOWN COUNCIL	<u>NEE SOON TOWN COUNCIL</u>
LOCATION	<u>NEE SOON LINK DIVISION</u>
DATE OF SERVICING	<u>25/09/2025</u>

WEEKLY PRESSURE TANK CHECKLIST REPORT

1. Test run of pumps
 2. Check pump and motor running condition
 3. Check coupling set, baseplate and spring isolator
 4. Check mechanical seal / gland-packing and bearings
 5. Check all pipe work, check valve, gate valve, expansion joint, strainer
 6. Check correct function of pump system in auto and manual mode
 7. Check control panel and electrical isolator
 8. Check electrical components in control panel
 9. Check all indicator lamps
 10. Check conduit and wiring
 11. Check electrode holder and sensor
 12. Check ball float valve / pilot valve and motorised valve
 13. Check pump running ampere
 14. Check pressure switch setting and pressure gauge

Block No :

REMARKS

Name & signature of Technician(s)

Verified By :

¹ P-Namini Niri

(Name & signature)

2

RED-POWER ELECTRICAL ENGINEERING PTE LTD

BLK 16 DEFU LANE 10. #01 - 364. SINGAPORE 539197

TEL : 6 289 2298 FAX : 6 287 9635

TOWN COUNCIL	<u>NEE SOON TOWN COUNCIL</u>
LOCATION	<u>NEE SOON LINK DIVISION</u>
DATE OF SERVICING	<u>25/09/2025</u>

WEEKLY PRESSURE TANK CHECKLIST REPORT

1. Test run of pumps
 2. Check pump and motor running condition
 3. Check coupling set, baseplate and spring isolator
 4. Check mechanical seal / gland-packing and bearings
 5. Check all pipe work, check valve, gate valve, expansion joint, strainer
 6. Check correct function of pump system in auto and manual mode
 7. Check control panel and electrical isolator
 8. Check electrical components in control panel
 9. Check all indicator lamps
 10. Check conduit and wiring
 11. Check electrode holder and sensor
 12. Check ball float valve / pilot valve and motorised valve
 13. Check pump running ampere
 14. Check pressure switch setting and pressure gauge

Block No :

REMARKS

Name & signature of Technician(s)

Verified By :

¹ P. Mami Obi

(Name & signature)

2

RED-POWER ELECTRICAL ENGINEERING PTE LTD

BLK 16 DEFU LANE 10. #01 - 364. SINGAPORE 539197

TEL : 6 289 2298 FAX : 6 287 9635

TOWN COUNCIL	<u>NEE SOON TOWN COUNCIL</u>
LOCATION	<u>NEE SOON LINK DIVISION</u>
DATE OF SERVICING	<u>25 /09/2025</u>

WEEKLY PRESSURE TANK CHECKLIST REPORT

1. Test run of pumps
 2. Check pump and motor running condition
 3. Check coupling set, baseplate and spring isolator
 4. Check mechanical seal / gland-packing and bearings
 5. Check all pipe work, check valve, gate valve, expansion joint, strainer
 6. Check correct function of pump system in auto and manual mode
 7. Check control panel and electrical isolator
 8. Check electrical components in control panel
 9. Check all indicator lamps
 10. Check conduit and wiring
 11. Check electrode holder and sensor
 12. Check ball float valve / pilot valve and motorised valve
 13. Check pump running ampere
 14. Check pressure switch setting and pressure gauge

Block No :

RED-POWER ELECTRICAL ENGINEERING PTE LTD

BLK 16 DEFU LANE 10. #01 - 364. SINGAPORE 539197

TEL : 6 289 2298 FAX : 6 287 9635

FAX : 6 287 9635

TOWN COUNCIL

NEE SOON TOWN COUNCIL

LOCATION

NEE SOON LINK DIVISION

DATE OF SERVICING

28 /09/2025

WEEKLY PRESSURE TANK CHECKLIST REPORT

1. Test run of pumps
 2. Check pump and motor running condition
 3. Check coupling set, baseplate and spring isolator
 4. Check mechanical seal / gland-packing and bearings
 5. Check all pipe work, check valve, gate valve, expansion joint, strainer
 6. Check correct function of pump system in auto and manual mode
 7. Check control panel and electrical isolator
 8. Check electrical components in control panel
 9. Check all indicator lamps
 10. Check conduit and wiring
 11. Check electrode holder and sensor
 12. Check ball float valve / pilot valve and motorised valve
 13. Check pump running ampere
 14. Check pressure switch setting and pressure gauge

Block No :

REMARKS

Name & signature of Technician(s)

Verified By :

1 P. Mani (fmr)

(Name & signature)

2

RED-POWER ELECTRICAL ENGINEERING PTE LTD

BLK 16 DEFU LANE 10. #01 - 364. SINGAPORE 539197

TEL : 6 289 2298 FAX : 6 287 9635

NEE SOON TOWN COUNCIL

LOCATION

NEE SOON LINK DIVISION

DATE OF SERVICING

26 /09/2025

WEEKLY PRESSURE TANK CHECKLIST REPORT

1. Test run of pumps
 2. Check pump and motor running condition
 3. Check coupling set, baseplate and spring isolator
 4. Check mechanical seal / gland-packing and bearings
 5. Check all pipe work, check valve, gate valve, expansion joint, strainer
 6. Check correct function of pump system in auto and manual mode
 7. Check control panel and electrical isolator
 8. Check electrical components in control panel
 9. Check all indicator lamps
 10. Check conduit and wiring
 11. Check electrode holder and sensor
 12. Check ball float valve / pilot valve and motorised valve
 13. Check pump running ampere
 14. Check pressure switch setting and pressure gauge

Block No :

REMARKS

Name & signature of Technician(s)

Verified By :

¹ P. Mami Hui

(Name & signature)

2

RED-POWER ELECTRICAL ENGINEERING PTE LTD

BLK 16 DEFU LANE 10. #01 - 364. SINGAPORE 539197

TEL : 6 289 2298 FAX : 6 287 9635

FAX : 6 287 9635

TOWN COUNCIL

NEE SOON TOWN COUNCIL

LOCATION

NEE SOON LINK DIVISION

DATE OF SERVICING

26 /09/2025

WEEKLY PRESSURE TANK CHECKLIST REPORT

1. Test run of pumps
 2. Check pump and motor running condition
 3. Check coupling set, baseplate and spring isolator
 4. Check mechanical seal / gland-packing and bearings
 5. Check all pipe work, check valve, gate valve, expansion joint, strainer
 6. Check correct function of pump system in auto and manual mode
 7. Check control panel and electrical isolator
 8. Check electrical components in control panel
 9. Check all indicator lamps
 10. Check conduit and wiring
 11. Check electrode holder and sensor
 12. Check ball float valve / pilot valve and motorised valve
 13. Check pump running ampere
 14. Check pressure switch setting and pressure gauge

Block No :

REMARKS

Name & signature of Technician(s)

Verified By :

¹ P.Mani Shri

(Name & signature)

2

RED-POWER ELECTRICAL ENGINEERING PTE LTD

BLK 16 DEFU LANE 10. #01 - 364. SINGAPORE 539197

TEL : 6 289 2298 FAX : 6 287 9635

TOWN COUNCIL	<u>NEE SOON TOWN COUNCIL</u>
LOCATION	<u>NEE SOON LINK DIVISION</u>
DATE OF SERVICING	<u>26/09/2025</u>

WEEKLY PRESSURE TANK CHECKLIST REPORT

1. Test run of pumps
 2. Check pump and motor running condition
 3. Check coupling set, baseplate and spring isolator
 4. Check mechanical seal / gland-packing and bearings
 5. Check all pipe work, check valve, gate valve, expansion joint, strainer
 6. Check correct function of pump system in auto and manual mode
 7. Check control panel and electrical isolator
 8. Check electrical components in control panel
 9. Check all indicator lamps
 10. Check conduit and wiring
 11. Check electrode holder and sensor
 12. Check ball float valve / pilot valve and motorised valve
 13. Check pump running ampere
 14. Check pressure switch setting and pressure gauge

Block No :

REMARKS

Name & signature of Technician(s)

Verified By :

1 Ptani Rhiz

(Name & signature)

2

RED-POWER ELECTRICAL ENGINEERING PTE LTD

BLK 16 DEFU LANE 10. #01 - 364. SINGAPORE 539197

TEL : 6 289 2298 FAX : 6 287 9635

FAX : 6 287 9635

TOWN COUNCIL

NEE SOON TOWN COUNCIL

LOCATION

NEE SOON LINK DIVISION

DATE OF SERVICING

 /09/2025

WEEKLY PRESSURE TANK CHECKLIST REPORT

1. Test run of pumps
 2. Check pump and motor running condition
 3. Check coupling set, baseplate and spring isolator
 4. Check mechanical seal / gland-packing and bearings
 5. Check all pipe work, check valve, gate valve, expansion joint, strainer
 6. Check correct function of pump system in auto and manual mode
 7. Check control panel and electrical isolator
 8. Check electrical components in control panel
 9. Check all indicator lamps
 10. Check conduit and wiring
 11. Check electrode holder and sensor
 12. Check ball float valve / pilot valve and motorised valve
 13. Check pump running ampere
 14. Check pressure switch setting and pressure gauge

Block No :

REMARKS

Name & signature of Technician(s)

Verified By :

¹ P. Muni Bhagat

(Name & signature)

2

RED-POWER ELECTRICAL ENGINEERING PTE LTD

BLK 16 DEFU LANE 10. #01 - 364. SINGAPORE 539197

TEL : 6 289 2298 FAX : 6 287 9635

TOWN COUNCIL	<u>NEE SOON TOWN COUNCIL</u>
LOCATION	<u>NEE SOON LINK DIVISION</u>
DATE OF SERVICING	<u>26/09/2025</u>

WEEKLY PRESSURE TANK CHECKLIST REPORT

1. Test run of pumps
 2. Check pump and motor running condition
 3. Check coupling set, baseplate and spring isolator
 4. Check mechanical seal / gland-packing and bearings
 5. Check all pipe work, check valve, gate valve, expansion joint, strainer
 6. Check correct function of pump system in auto and manual mode
 7. Check control panel and electrical isolator
 8. Check electrical components in control panel
 9. Check all indicator lamps
 10. Check conduit and wiring
 11. Check electrode holder and sensor
 12. Check ball float valve / pilot valve and motorised valve
 13. Check pump running ampere
 14. Check pressure switch setting and pressure gauge

Block No :

REMARKS

Name & signature of Technician(s)

Verified By :

¹ P. Mani Bhui

(Name & signature)

2

RED-POWER ELECTRICAL ENGINEERING PTE LTD

BLK 16 DEFU LANE 10. #01 - 364. SINGAPORE 539197

TEL : 6 289 2298 FAX : 6 287 9635

FAX : 6 287 9635

TOWN COUNCIL

NEE SOON TOWN COUNCIL

LOCATION

NEE SOON LINK DIVISION

DATE OF SERVICING

29 /09/2025

WEEKLY PRESSURE TANK CHECKLIST REPORT

1. Test run of pumps
 2. Check pump and motor running condition
 3. Check coupling set, baseplate and spring isolator
 4. Check mechanical seal / gland-packing and bearings
 5. Check all pipe work, check valve, gate valve, expansion joint, strainer
 6. Check correct function of pump system in auto and manual mode
 7. Check control panel and electrical isolator
 8. Check electrical components in control panel
 9. Check all indicator lamps
 10. Check conduit and wiring
 11. Check electrode holder and sensor
 12. Check ball float valve / pilot valve and motorised valve
 13. Check pump running ampere
 14. Check pressure switch setting and pressure gauge

Block No :

REMARKS

Name & signature of Technician(s)

Verified By :

¹ P.Mani M.

(Name & signature)

2

RED-POWER ELECTRICAL ENGINEERING PTE LTD

BLK 16 DEFU LANE 10. #01 - 364. SINGAPORE 539197

TEL : 6 289 2298

FAX : 6 287 9635

TOWN COUNCIL

NEE SOON TOWN COUNCIL

LOCATION

NEE SOON LINK DIVISION

DATE OF SERVICING

29 /09/2025

WEEKLY PRESSURE TANK CHECKLIST REPORT

1. Test run of pumps
2. Check pump and motor running condition
3. Check coupling set, baseplate and spring isolator
4. Check mechanical seal / gland-packing and bearings
5. Check all pipe work, check valve, gate valve, expansion joint, strainer
6. Check correct function of pump system in auto and manual mode
7. Check control panel and electrical isolator
8. Check electrical components in control panel
9. Check all indicator lamps
10. Check conduit and wiring
11. Check electrode holder and sensor
12. Check ball float valve / pilot valve and motorised valve
13. Check pump running ampere
14. Check pressure switch setting and pressure gauge

Block No :

426C	426D	428A	428B	429	429A	429B	430	430A
/	/	/	/	/	/	/	/	/
/	/	/	/	/	/	/	/	/
/	/	/	/	/	/	/	/	/
/	/	/	/	/	/	/	/	/
/	/	/	/	/	/	/	/	/
/	/	/	/	/	/	/	/	/
/	/	/	/	/	/	/	/	/
/	/	/	/	/	/	/	/	/
/	/	/	/	/	/	/	/	/
/	/	/	/	/	/	/	/	/
/	/	/	/	/	/	/	/	/
3.0	4.5	4.0	3.5	3.0	3.5	3.0	4.0	4.5
/	/	/	/	/	/	/	/	/

REMARKS

Name & signature of Technician(s)

1 Deber A.

Verified By :

(Name & signature)

2 _____

RED-POWER ELECTRICAL ENGINEERING PTE LTD

BLK 16 DEFU LANE 10. #01 - 364. SINGAPORE 539197

TEL : 6 289 2298 FAX : 6 287 9635

TOWN COUNCIL	<u>NEE SOON TOWN COUNCIL</u>
LOCATION	<u>NEE SOON LINK DIVISION</u>
DATE OF SERVICING	<u>29/09/2025</u>

WEEKLY PRESSURE TANK CHECKLIST REPORT

1. Test run of pumps
 2. Check pump and motor running condition
 3. Check coupling set, baseplate and spring isolator
 4. Check mechanical seal / gland-packing and bearings
 5. Check all pipe work, check valve, gate valve, expansion joint, strainer
 6. Check correct function of pump system in auto and manual mode
 7. Check control panel and electrical isolator
 8. Check electrical components in control panel
 9. Check all indicator lamps
 10. Check conduit and wiring
 11. Check electrode holder and sensor
 12. Check ball float valve / pilot valve and motorised valve
 13. Check pump running ampere
 14. Check pressure switch setting and pressure gauge

Block No :

REMARKS

Name & signature of Technician(s)

Verified By :

1 P. Mani Bhui

(Name & signature)

2

RED-POWER ELECTRICAL ENGINEERING PTE LTD

BLK 16 DEFU LANE 10. #01 - 364. SINGAPORE 539197

TEL : 6 289 2298

FAX : 6 287 9635

TOWN COUNCIL

NEE SOON TOWN COUNCIL

LOCATION

NEE SOON LINK DIVISION

DATE OF SERVICING

29 /09/2025

WEEKLY PRESSURE TANK CHECKLIST REPORT

1. Test run of pumps
2. Check pump and motor running condition
3. Check coupling set, baseplate and spring isolator
4. Check mechanical seal / gland-packing and bearings
5. Check all pipe work, check valve, gate valve, expansion joint, strainer
6. Check correct function of pump system in auto and manual mode
7. Check control panel and electrical isolator
8. Check electrical components in control panel
9. Check all indicator lamps
10. Check conduit and wiring
11. Check electrode holder and sensor
12. Check ball float valve / pilot valve and motorised valve
13. Check pump running ampere
14. Check pressure switch setting and pressure gauge

Block No :

432D	436	438	441	453	454	455	456	456A
/	/	/	/	/	/	/	/	/
/	/	/	/	/	/	/	/	/
/	/	/	/	/	/	/	/	/
/	/	/	/	/	/	/	/	/
/	/	/	/	/	/	/	/	/
/	/	/	/	/	/	/	/	/
/	/	/	/	/	/	/	/	/
/	/	/	/	/	/	/	/	/
/	/	/	/	/	/	/	/	/
/	/	/	/	/	/	/	/	/
/	/	/	/	/	/	/	/	/
/	/	/	/	/	/	/	/	/
302.5	400	405	400	400	400	25	400	
/	/	/	/	/	/	/	/	/



RED-POWER ELECTRICAL ENGINEERING PTE LTD

BLK 16 DEFU LANE 10. #01 - 364. SINGAPORE 539197

TEL : 6 289 2298

FAX : 6 287 9635

TOWN COUNCIL

NEE SOON TOWN COUNCIL

LOCATION

NEE SOON LINK DIVISION

DATE OF SERVICING

29 /09/2025

WEEKLY PRESSURE TANK CHECKLIST REPORT

1. Test run of pumps
 2. Check pump and motor running condition
 3. Check coupling set, baseplate and spring isolator
 4. Check mechanical seal / gland-packing and bearings
 5. Check all pipe work, check valve, gate valve, expansion joint, strainer
 6. Check correct function of pump system in auto and manual mode
 7. Check control panel and electrical isolator
 8. Check electrical components in control panel
 9. Check all indicator lamps
 10. Check conduit and wiring
 11. Check electrode holder and sensor
 12. Check ball float valve / pilot valve and motorised valve
 13. Check pump running ampere
 14. Check pressure switch setting and pressure gauge

Block No :

REMARKS

Name & signature of Technician(s)

Verified By :

1 P. Nambi Nni

(Name & signature)

2

RED-POWER ELECTRICAL ENGINEERING PTE LTD

BLK 16 DEFU LANE 10. #01 - 364. SINGAPORE 539197

TEL : 6 289 2298

FAX : 6 287 9635

TOWN COUNCIL

NEE SOON TOWN COUNCIL

LOCATION

NEE SOON LINK DIVISION

DATE OF SERVICING

30 /09/2025

WEEKLY PRESSURE TANK CHECKLIST REPORT

1. Test run of pumps
2. Check pump and motor running condition
3. Check coupling set, baseplate and spring isolator
4. Check mechanical seal / gland-packing and bearings
5. Check all pipe work, check valve, gate valve, expansion joint, strainer
6. Check correct function of pump system in auto and manual mode
7. Check control panel and electrical isolator
8. Check electrical components in control panel
9. Check all indicator lamps
10. Check conduit and wiring
11. Check electrode holder and sensor
12. Check ball float valve / pilot valve and motorised valve
13. Check pump running ampere
14. Check pressure switch setting and pressure gauge

Block No :

462D	465	465A	465B	466A	466B	467A	467B	467C
/	/	/	/	/	/	/	/	/
/	/	/	/	/	/	/	/	/
/	/	/	/	/	/	/	/	/
/	/	/	/	/	/	/	/	/
/	/	/	/	/	/	/	/	/
/	/	/	/	/	/	/	/	/
/	/	/	/	/	/	/	/	/
/	/	/	/	/	/	/	/	/
/	/	/	/	/	/	/	/	/
/	/	/	/	/	/	/	/	/
/	/	/	/	/	/	/	/	/
/	/	/	/	/	/	/	/	/
/	/	/	/	/	/	/	/	/
3-5	4-5	3-0	3-5	4-0	4-5	4-0	3-5	3-0
✓	/	/	/	/	/	/	/	/

REMARKS

Name & signature of Technician(s)

1 Sohail

Verified By :

(Name & signature)

2 _____

RED-POWER ELECTRICAL ENGINEERING PTE LTD

BLK 16 DEFU LANE 10. #01 - 364. SINGAPORE 539197

TEL : 6 289 2298 FAX : 6 287 9635

TOWN COUNCIL	<u>NEE SOON TOWN COUNCIL</u>
LOCATION	<u>NEE SOON LINK DIVISION</u>
DATE OF SERVICING	<u>30 /09/2025</u>

WEEKLY PRESSURE TANK CHECKLIST REPORT

1. Test run of pumps
 2. Check pump and motor running condition
 3. Check coupling set, baseplate and spring isolator
 4. Check mechanical seal / gland-packing and bearings
 5. Check all pipe work, check valve, gate valve, expansion joint, strainer
 6. Check correct function of pump system in auto and manual mode
 7. Check control panel and electrical isolator
 8. Check electrical components in control panel
 9. Check all indicator lamps
 10. Check conduit and wiring
 11. Check electrode holder and sensor
 12. Check ball float valve / pilot valve and motorised valve
 13. Check pump running ampere
 14. Check pressure switch setting and pressure gauge

Block No :

REMARKS

Name & signature of Technician(s)

Verified By :

1 P. Mani Phi

(Name & signature)

2

RED-POWER ELECTRICAL ENGINEERING PTE LTD

BLK 16 DEFU LANE 10. #01 - 364. SINGAPORE 539197

TEL : 6 289 2298 FAX : 6 287 9635

TOWN COUNCIL	<u>NEE SOON TOWN COUNCIL</u>
LOCATION	<u>NEE SOON LINK DIVISION</u>
DATE OF SERVICING	<u>30/09/2025</u>

WEEKLY PRESSURE TANK CHECKLIST REPORT

1. Test run of pumps
 2. Check pump and motor running condition
 3. Check coupling set, baseplate and spring isolator
 4. Check mechanical seal / gland-packing and bearings
 5. Check all pipe work, check valve, gate valve, expansion joint, strainer
 6. Check correct function of pump system in auto and manual mode
 7. Check control panel and electrical isolator
 8. Check electrical components in control panel
 9. Check all indicator lamps
 10. Check conduit and wiring
 11. Check electrode holder and sensor
 12. Check ball float valve / pilot valve and motorised valve
 13. Check pump running ampere
 14. Check pressure switch setting and pressure gauge

Block No :

REMARKS

Name & signature of Technician(s)

Verified By :

John

(Name & signature)

2 _____

RED-POWER ELECTRICAL ENGINEERING PTE LTD

BLK 16 DEFU LANE 10. #01 - 364. SINGAPORE 539197

TEL : 6 289 2298 FAX : 6 287 9635

TOWN COUNCIL	NEE SOON TOWN COUNCIL
LOCATION	NEE SOON LINK DIVISION
DATE OF SERVICING	<u>30</u> /09/2025

WEEKLY PRESSURE TANK CHECKLIST REPORT

1. Test run of pumps
 2. Check pump and motor running condition
 3. Check coupling set, baseplate and spring isolator
 4. Check mechanical seal / gland-packing and bearings
 5. Check all pipe work, check valve, gate valve, expansion joint, strainer
 6. Check correct function of pump system in auto and manual mode
 7. Check control panel and electrical isolator
 8. Check electrical components in control panel
 9. Check all indicator lamps
 10. Check conduit and wiring
 11. Check electrode holder and sensor
 12. Check ball float valve / pilot valve and motorised valve
 13. Check pump running ampere
 14. Check pressure switch setting and pressure gauge

Block No :

REMARKS

Name & signature of Technician(s)

Verified By :

¹P.Nani Mji

(Name & signature)

2 _____

RED-POWER ELECTRICAL ENGINEERING PTE LTD

BLK 16 DEFU LANE 10. #01 - 364. SINGAPORE 539197

TEL : 6 289 2298 FAX : 6 287 9635

NEE SOON TOWN COUNCIL

LOCATION

NEE SOON LINK DIVISION

DATE OF SERVICING

30 /09/2025

WEEKLY PRESSURE TANK CHECKLIST REPORT

1. Test run of pumps
 2. Check pump and motor running condition
 3. Check coupling set, baseplate and spring isolator
 4. Check mechanical seal / gland-packing and bearings
 5. Check all pipe work, check valve, gate valve, expansion joint, strainer
 6. Check correct function of pump system in auto and manual mode
 7. Check control panel and electrical isolator
 8. Check electrical components in control panel
 9. Check all indicator lamps
 10. Check conduit and wiring
 11. Check electrode holder and sensor
 12. Check ball float valve / pilot valve and motorised valve
 13. Check pump running ampere
 14. Check pressure switch setting and pressure gauge

Block No :

REMARKS

Name & signature of Technician(s)

Verified By :

¹ P.Nani Thi

(Name & signature)

2

RED-POWER ELECTRICAL ENGINEERING PTE LTD

BLK 16 DEFU LANE 10. #01 - 364. SINGAPORE 539197

TEL : 6 289 2298

FAX : 6 287 9635

TOWN COUNCIL

NEE SOON TOWN COUNCIL

LOCATION

YISHUN AVE 6/ST 42/ST 44 (NEE SOON LINK DIVISION)

DATE OF SERVICING

4 /09/2025

WEEKLY GENERATOR CHECKLIST REPORT

1. BATTERY & ENGINE

- 1.1 Check starter battery condition and top up electrolyte where necessary
 - 1.1a Start engine and bring unit up to normal operating temperature
 - 1.1b To allow the engine to run for half an hour
 - 1.1c Record log book this information: Before starting of engine -
 - 1.1d(i) Battery charging current ampere
 - 1.1d(ii) Battery voltage
 - 1.1d(iii) Engine fuel tank level
 - 1.1e Record in the log book this information: After engine been running half an hour -
 - 1.1f(i) Engine lubricating oil pressure
 - 1.1f(ii) Engine rpm (tachometer reading)
 - 1.1f(iii) Engine cooling water temperature
 - 1.1f(iv) Generator output voltage
 - 1.1f(v) Generator output frequency
 - 1.1g Any irregularities detected and remarks
 - 1.1h Ensure controls are set for automatic operation

Block No :

REMARKS

Name & signature of Technician(s)

1 Ruf

2

RED-POWER ELECTRICAL ENGINEERING PTE LTD

BLK 16 DEFU LANE 10. #01 - 364. SINGAPORE 539197

TEL : 6 289 2298

FAX : 6 287 9635

TOWN COUNCIL

NEE SOON TOWN COUNCIL

LOCATION

YISHUN AVE 6/ST 42/ST 44 (NEE SOON LINK DIVISION)

DATE OF SERVICING

11 /09/2025

WEEKLY GENERATOR CHECKLIST REPORT

1. BATTERY & ENGINE

- 1.1 Check starter battery condition and top up electrolyte where necessary
 - 1.1a Start engine and bring unit up to normal operating temperature
 - 1.1b To allow the engine to run for half an hour
 - 1.1c Record log book this information: Before starting of engine -
 - 1.1d(i) Battery charging current ampere
 - 1.1d(ii) Battery voltage
 - 1.1d(iii) Engine fuel tank level
 - 1.1e Record in the log book this information: After engine been running half an hour -
 - 1.1f(i) Engine lubricating oil pressure
 - 1.1f(ii) Engine rpm (tachometer reading)
 - 1.1f(iii) Engine cooling water temperature
 - 1.1f(iv) Generator output voltage
 - 1.1f(v) Generator output frequency
 - 1.1g Any irregularities detected and remarks
 - 1.1h Ensure controls are set for automatic operation

Block No :

REMARKS

Name & signature of Technician(s)

R.H.

2

RED-POWER ELECTRICAL ENGINEERING PTE LTD

BLK 16 DEFU LANE 10. #01 - 364. SINGAPORE 539197

TEL : 6 289 2298

FAX : 6 287 9635

TOWN COUNCIL

NEE SOON TOWN COUNCIL

LOCATION

YISHUN AVE 6/ST 42/ST 44 (NEE SOON LINK DIVISION)

DATE OF SERVICING

18 /09/2025

WEEKLY GENERATOR CHECKLIST REPORT

1. BATTERY & ENGINE

- 1.1 Check starter battery condition and top up electrolyte where necessary
 - 1.1a Start engine and bring unit up to normal operating temperature
 - 1.1b To allow the engine to run for half an hour
 - 1.1c Record log book this information: Before starting of engine -
 - 1.1d(i) Battery charging current ampere
 - 1.1d(ii) Battery voltage
 - 1.1d(iii) Engine fuel tank level
 - 1.1e Record in the log book this information: After engine been running half an hour -
 - 1.1f(i) Engine lubricating oil pressure
 - 1.1f(ii) Engine rpm (tachometer reading)
 - 1.1f(iii) Engine cooling water temperature
 - 1.1f(iv) Generator output voltage
 - 1.1f(v) Generator output frequency
 - 1.1g Any irregularities detected and remarks
 - 1.1h Ensure controls are set for automatic operation

Block No :

REMARKS

Name & signature of Technician(s)

1 _____

2 _____

RED-POWER ELECTRICAL ENGINEERING PTE LTD

BLK 16 DEFU LANE 10. #01 - 364. SINGAPORE 539197

TEL : 6 289 2298

FAX : 6 287 9635

TOWN COUNCIL

NEE SOON TOWN COUNCIL

LOCATION

YISHUN AVE 6/ST 42/ST 44 (NEE SOON LINK DIVISION)

DATE OF SERVICING

25 /09/2025

WEEKLY GENERATOR CHECKLIST REPORT

1. BATTERY & ENGINE

- 1.1 Check starter battery condition and top up electrolyte where necessary
 - 1.1a Start engine and bring unit up to normal operating temperature
 - 1.1b To allow the engine to run for half an hour
 - 1.1c Record log book this information: Before starting of engine -
 - 1.1d(i) Battery charging current ampere
 - 1.1d(ii) Battery voltage
 - 1.1d(iii) Engine fuel tank level
 - 1.1e Record in the log book this information: After engine been running half an hour -
 - 1.1f(i) Engine lubricating oil pressure
 - 1.1f(ii) Engine rpm (tachometer reading)
 - 1.1f(iii) Engine cooling water temperature
 - 1.1f(iv) Generator output voltage
 - 1.1f(v) Generator output frequency
 - 1.1g Any irregularities detected and remarks
 - 1.1h Ensure controls are set for automatic operation

Block No :

REMARKS

Name & signature of Technician(s)

1

2

RED-POWER ELECTRICAL ENGINEERING PTE LTD

BLK 16 DEFU LANE 10. #01 - 364. SINGAPORE 539197

TEL : 6 289 2298

FAX : 6 287 9635

TOWN COUNCIL

NEE SOON TOWN COUNCIL

LOCATION

YISHUN AVE 6/ST 42 (NEE SOON LINK)

DATE OF SERVICING

4 /09/2025

WEEKLY SPRINKLER CHECKLIST REPORT

1. INLETS, SPRINKLERS & PRESSURE TANKS

- 1.1 Check the fire Service breeching inlet to ensure it is in good condition
- 1.2 Ensure the Fire Service breeching inlet is easily visible and accessible

Block No :

461	471A	-	-	-	-	-	-
/	/	-	-	-	-	-	-
/	/	-	-	-	-	-	-
/	/	-	-	-	-	-	-

REMARKS

B1K101 Sprinkler Pump 1 & 2 Panel D motor spoil.

Name & signature of Technician(s)

1 RJF.

2 _____

Verified By :

(Name & signature)

4

RED-POWER ELECTRICAL ENGINEERING PTE LTD

BLK 16 DEFU LANE 10. #01 - 364. SINGAPORE 539197

TEL : 6 289 2298

FAX : 6 287 9635

TOWN COUNCIL

NEE SOON TOWN COUNCIL

LOCATION

YISHUN AVE 6/ST 42 (NEE SOON LINK)

DATE OF SERVICING

11 /09/2025

WEEKLY SPRINKLER CHECKLIST REPORT

1. INLETS, SPRINKLERS & PRESSURE TANKS

- 1.1 Check the fire Service breeching inlet to ensure it is in good condition
- 1.2 Ensure the Fire Service breeching inlet is easily visible and accessible

Block No :

461	471A	-	-	-	-	-	-
/	/	-	-	-	-	-	-
/	/	-	-	-	-	-	-
/	/	-	-	-	-	-	-

REMARKS

Name & signature of Technician(s)

1 Rf.

2 _____

Verified By :

(Name & signature)

RED-POWER ELECTRICAL ENGINEERING PTE LTD

BLK 16 DEFU LANE 10. #01 - 364. SINGAPORE 539197

TEL : 6 289 2298

FAX : 6 287 9635

TOWN COUNCIL

NEE SOON TOWN COUNCIL

LOCATION

YISHUN AVE 6/ST 42 (NEE SOON LINK)

DATE OF SERVICING

18 /09/2025

WEEKLY SPRINKLER CHECKLIST REPORT

1. INLETS, SPRINKLERS & PRESSURE TANKS

- 1.1 Check the fire Service breeching inlet to ensure it is in good condition
- 1.2 Ensure the Fire Service breeching inlet is easily visible and accessible

Block No :

461	471A	-	-	-	-	-	-
/	/	-	-	-	-	-	-
/	/	-	-	-	-	-	-
/	/	-	-	-	-	-	-

REMARKS

Name & signature of Technician(s)

1 Rf.

Verified By :

(Name & signature)

2 _____

RED-POWER ELECTRICAL ENGINEERING PTE LTD

BLK 16 DEFU LANE 10. #01 - 364. SINGAPORE 539197

TEL : 6 289 2298

FAX : 6 287 9635

TOWN COUNCIL

NEE SOON TOWN COUNCIL

LOCATION

YISHUN AVE 6/ST 42 (NEE SOON LINK)

DATE OF SERVICING

 /09/2025

WEEKLY SPRINKLER CHECKLIST REPORT

1. INLETS, SPRINKLERS & PRESSURE TANKS

- 1.1 Check the fire Service breeching inlet to ensure it is in good condition
- 1.2 Ensure the Fire Service breeching inlet is easily visible and accessible

Block No :

461	471A	-	-	-	-	-	-
/	/	-	-	-	-	-	-
/	/	-	-	-	-	-	-
/	/	-	-	-	-	-	-

REMARKS

Name & signature of Technician(s)

1 

Verified By :

(Name & signature)

2 _____