

BLK 16 DEFU LANE 10. #01 - 364. SINGAPORE 539197
TEL : 6 289 2298 FAX : 6 287 9635

NEE SOON TOWN COUNCIL

NEE SOON CENTRAL DIVISION

25 /09/2025

1. HOSEREEL
 - 1.1 Check hosereels remain unobstructed
 - 1.2 Ensure hosereel are available for use at all times
 - 1.3 Check hosereel cabinet, hosereel and rubber hose for damage
 - 1.4 Inspect the stop valves, glands, pipings and shut-off nozzles are free from leak
 - 1.5 Check & verify operation of stop valve at hosereel feed pipe & ensure valve is fully closed
 - 1.6 Check operation of nozzle and stopcock for blockage
2. PUMPS & TANKS
 - 2.1 Pumps and associated mechanical & electrical equipment must be checked
 - 2.2 Check water level in storage tanks
 - 2.3 Check and service ball float/pilot operated/solenoid operated valve for water storage tanks
 - 2.4 Ensure ball float/pilot operated/solenoid operated valve are in functional conditions
 - 2.5 Check pumping operating conditions such as auto cut in and off when pressure is re-established
 - 2.6 Check auto changeover of duty to standby pump
 - 2.7 Check working pressure of pressure tank and pump air if necessary
 - 2.8 Check pressure tank and its accessories
3. ALARMS, SWITCHES & CIRCUITS
 - 3.1 Check relays contact
 - 3.2 Check pressure switches setting
 - 3.3 Check pump starting equipment including circuit breakers and contactors
 - 3.4 Check and verify pump running alarm and failure alarm

[illegible]

Verified By :

1 Schlag

Name & signature

2 _____