

RED-POWER ELECTRICAL ENGINEERING PTE LTD

BLK 16 DEFU LANE 10. #01 - 364. SINGAPORE 539197

TEL : 6 289 2298

FAX : 6 287 9635

TOWN COUNCIL

NEE SOON TOWN COUNCIL

LOCATION

NEE SOON SOUTH DIVISION

DATE OF SERVICING

23 /09/2025

MONTHLY HOSEREEL SYSTEM CHECKLIST REPORT

1. HOSEREEL

- 1.1 Check hoses remain unobstructed
- 1.2 Ensure hoses are available for use at all times
- 1.3 Check hose reel cabinet, hose reel and rubber hose for damage
- 1.4 Inspect the stop valves, glands, pipings and shut-off nozzles are free from leak
- 1.5 Check & verify operation of stop valve at hose reel pipe & ensure valve is fully closed
- 1.6 Check operation of nozzle and stopcock for blockage

Block No :

505A	505B	505C	505D	506	506A
✓	✓	✓	✓	✓	✓
✓	✓	✓	✓	✓	✓
✓	✓	✓	✓	✓	✓
✓	✓	✓	✓	✓	✓
✓	✓	✓	✓	✓	✓
✓	✓	✓	✓	✓	✓
✓	✓	✓	✓	✓	✓

REMARKS

Name & signature of Technician(s)

Verified By :

1 Scher es


(Name & signature)

2 _____

**Blk 505B level- 12
staircase B , door can't
open**

FIRE HOSEREEL

Turn on inlet valve before running out hose



TEL 6758 0125
Email: Feedback@ntc.org.sg
Website: www.ntc.org.sg

The Town Council conducts regular maintenance of the fire safety premises to ensure that it is operationally ready at all times. We seek your help to ensure there is no obstruction to the electrical, water or dry clean up of all times.
Placement of any personal belongings is not permitted. The Town Council reserves the right to remove any personal items without prior notice.
--- can make this form a safe place to file in.



**RED POWER
DURAI**

19:01 Mon
15/09/2025

■ 505B Yishun St 51

Timemark App
Authentic time, GPS

**Blk 505B level- 5 staircase
B , door can't open**



FIRE HOSEREEL

Turn on inlet valve before running out hose



**RED POWER
DURAI**

19:05 Mon
15/09/2025

■ 505B Yishun St 51

Timemark App
Authentic time, GPS

**Blk 505C level- 3 door
can't open**

FIRE HOSEREEL


Turn on inlet valve before running out hose



**RED POWER
DURAI**

18:49 Mon
15/09/2025

■ Acacia Breeze @ Yishun,
505C Yishun Street 51,
763505



Timemark App
Authentic time, GPS

XHEE4XT1Y14MUB Timemark Verified

**Blk 505C level- 8 door
can't open**

No.	Unit No.	Remarks
1	505C	Door can't open
2		
3		
4		
5		
6		
7		
8		
9		
10		
11		
12		
13		
14		
15		
16		
17		
18		
19		
20		

FIRE HOSE REEL

Turn on inlet valve before running out



**RED POWER
DURAI**

18:45 Mon
15/09/2025

■ Acacia Breeze @ Yishun,
505C Yishun Street 51,
763505

Timemark App
Authentic time, GPS

**Blk 505C level- 2 door
can't open**

FIRE HOSE REEL

Turn on inlet valve before running out hose



**RED POWER
DURAI**

18:50 Mon
15/09/2025

■ Acacia Breeze @ Yishun,
505C Yishun Street 51,
763505



Timemark App
Authentic time, GPS

U1D6PL6344RKYA Timemark Verified