

BLK 16 DEFU LANE 10. #01 - 364. SINGAPORE 539197
TEL : 6 289 2298 FAX : 6 287 9635

TOWN COUNCIL NEE SOON TOWN COUNCIL
LOCATION NEE SOON EAST DIVISION
DATE OF SERVICING 2 /09/2025

1. HOSEREEL
 - 1.1 Check hosereels remain unobstructed
 - 1.2 Ensure hosereel are available for use at all times
 - 1.3 Check hosereel cabinet, hosereel and rubber hose for damage
 - 1.4 Inspect the stop valves, glands, pipings and shut-off nozzles are free from leak
 - 1.5 Check & verify operation of stop valve at hosereel pipe & ensure valve is fully closed
 - 1.6 Check operation of nozzle and stopcock for blockage

[illegible]

Name & signature of Technician(s)

Verified By :

1 Mami ohri

(Name & signature)

2 _____