

RED-POWER ELECTRICAL ENGINEERING PTE LTD

BLK 16 DEFU LANE 10. #01 - 364. SINGAPORE 539197

TEL : 6 289 2298

FAX : 6 287 9635

TOWN COUNCIL

NEE SOON TOWN COUNCIL

LOCATION

NEE SOON SOUTH DIVISION

DATE OF SERVICING

30 /09/2025

MONTHLY HOSEREEL SYSTEM CHECKLIST REPORT

1. HOSEREEL

1.1 Check hoses remain unobstructed

1.2 Ensure hoses are available for use at all times

1.3 Check hose reel cabinet, hose reel and rubber hose for damage

1.4 Inspect the stop valves, glands, pipings and shut-off nozzles are free from leak

1.5 Check & verify operation of stop valve at hose reel pipe & ensure valve is fully closed

1.6 Check operation of nozzle and stopcock for blockage

Block No :

813B	840A	845	846	848A	849
✓	✓	✓	✓	✓	✓
✓	✓	✓	✓	✓	✓
✓	✓	✓	✓	✓	✓
✓	✓	✓	✓	✓	✓
✓	✓	✓	✓	✓	✓
✓	✓	✓	✓	✓	✓

REMARKS

Name & signature of Technician(s)

Verified By :

1. Seha

(Name & signature)

2. _____