

BLK 16 DEFU LANE 10. #01 - 364. SINGAPORE 539197
TEL : 6 289 2298 FAX : 6 287 9635

NEE SOON TOWN COUNCIL

CHONG PANG DIVISION

2/09/2025

1. GENERAL

1.1a If any part of DECAM equipment supplied by DECAM sub-con become defective/repairs required

1.1b Contractor shall carry out all the repairs and replacement of parts at its own expense

2. ALARM

2.1 Monitor the Premises 24 hours daily for any fire alarm signals from the System and line fault

2.2 Immediately upon receipt of fire alarm signals from the System to relay the fire alarm signal

2.3 Immediately upon receipt of fire alarm signal from System to notify the Appropriate Authority

2.4 To record details of fire alarm activation and line fault

3. SYSTEM TEST

3.1 Notify telcom company of any faults in the line which the company may discover

3.2 Request telcom company to make any necessary repairs on any line faults

4. REPORTS

4.1 To submit 2 reports to the Town Council for every activation

4.2 One from the Contractor and the other from the DECAM sub-con

5. CLAIMS

5.1a Town Council shall indemnify the Company against any claim

5.1b Made against the Contractor by the appropriate Authority

5.1b(1) A Defect in the Equipment

5.1b(2) Malfunction of the Equipment

5.1b(3) Improper installation or maintenance of the Equipment

5.1b(4) Smoke/heat from a burning source is a potential fire hazard

5.1b(5) To the premises or the contents therein

5.1b(6) An Act of God

5.1c By the Appropriate Authority due to a false alarm signal from System unless is attributed to.

Block No :

[illegible]

REMARKS

Name & signature of Technician(s)

1 *Silva*

2 _____

Verified By :

(Name & signature)