

RED-POWER ELECTRICAL ENGINEERING PTE LTD

BLK 16 DEFU LANE 10. #01 - 364. SINGAPORE 539197

TEL : 6 289 2298

FAX : 6 287 9635

TOWN COUNCIL

NEE SOON TOWN COUNCIL

LOCATION

NEE SOON LINK DIVISION

DATE OF SERVICING

30 /09/2025

MONTHLY HOSEREEL SYSTEM CHECKLIST REPORT

1. HOSEREEL

- 1.1 Check hoses remain unobstructed
- 1.2 Ensure hoses are available for use at all times
- 1.3 Check hose reel cabinet, hose reel and rubber hose for damage
- 1.4 Inspect the stop valves, glands, pipings and shut-off nozzles are free from leak
- 1.5 Check & verify operation of stop valve at hose reel pipe & ensure valve is fully closed
- 1.6 Check operation of nozzle and stopcock for blockage

Block No :

432A	432B	432C	432D	436	438
/	/	/	/	/	/
/	/	/	/	/	/
/	/	/	/	/	/
/	/	/	/	/	/
/	/	/	/	/	/
/	/	/	/	/	/
/	/	/	/	/	/

REMARKS

Name & signature of Technician(s)

Verified By :

1

S. M. Selva

(Name & signature)

2

Blk 432D #1 Nozzle Box Glass Broken



NSTC
Hosereel drum

15:24 Wed
17/09/2025

- Work Content: glass missing & broken
- 432D Yishun Ave 1

Timemark App
Authentic time, GPS

BIK 438 #2 Nozzle Box Glass Broken



**RED POWER
MANI**

10:33 Wed
17/09/2025

■ 438 Yishun Avenue 11,
760438

Timemark App
Authentic time, GPS

**Blk 438 level- 12 glass
broken**



NSTC

Hosereel drum

10:39

Wed

17/09/2025

- 438 Yishun Ave 11
- Missing and broken glass

Timemark App
Authentic time, GPS

**Blk 438 level- 1 glass
broken**



NSTC

Hosereel drum

10:33 Wed
17/09/2025

- 438 Yishun Ave 11
- Missing and broken glass

Timemark App
Authentic time, GPS