

RED-POWER ELECTRICAL ENGINEERING PTE LTD

BLK 16 DEFU LANE 10. #01 - 364. SINGAPORE 539197

TEL : 6 289 2298

FAX : 6 287 9635

TOWN COUNCIL

NEE SOON TOWN COUNCIL

LOCATION

NEE SOON LINK DIVISION

DATE OF SERVICING

29 /09/2025

MONTHLY HOSEREEL SYSTEM CHECKLIST REPORT

1. HOSEREEL

- 1.1 Check hoses remain unobstructed
- 1.2 Ensure hoses are available for use at all times
- 1.3 Check hose reel cabinet, hose reel and rubber hose for damage
- 1.4 Inspect the stop valves, glands, pipings and shut-off nozzles are free from leak
- 1.5 Check & verify operation of stop valve at hose reel pipe & ensure valve is fully closed
- 1.6 Check operation of nozzle and stopcock for blockage

Block No :


462A	462B	462C	462D	465	465A
/	/	/	/	/	/
/	/	/	/	/	/
/	/	/	/	/	/
/	/	/	/	/	/
/	/	/	/	/	/
/	/	/	/	/	/

REMARKS

Name & signature of Technician(s)

Verified By :

1



2

(Name & signature)

**Blk 462B level- 2 glass
broken**



NSTC

Hosereel drum

17:27 Wed
17/09/2025

- Chapayom Yishun, 462B,
Yishun Avenue 6, 762462
- Missing and broken glass

Timemark App
Authentic time, GPS

**Blk 462B level- 5 glass
broken**



NSTC


Hosereel drum

17:24 Wed
17/09/2025

- Chapayom Yishun, 462B,
Yishun Avenue 6, 762462
- Missing and broken glass

Timemark App
Authentic time, GPS

**Blk 462B level- 9 glass
broken**



NSTC


Hosereel drum

17:20 Wed
17/09/2025

- Chapayom Yishun, 462B,
Yishun Avenue 6, 762462
- Missing and broken glass

Timemark App
Authentic time, GPS

**Blk 462B level- 6 glass
broken**



NSTC

Hosereel drum

17:23 Wed
17/09/2025

- 406 Yishun Ave 6, Block 406
- Missing and broken glass

Timemark App
Authentic time, GPS

**Blk 462B level- 11 glass
broken 1-4**



NSTC

Hosereel drum

17:32 Wed
17/09/2025

- Chapayom Yishun, 462B,
Yishun Avenue 6, 762462
- Missing and broken glass

Timemark App
Authentic time, GPS