

**RED-POWER ELECTRICAL ENGINEERING PTE LTD**

BLK 16 DEFU LANE 10. #01 - 364. SINGAPORE 539197

TEL : 6 289 2298

FAX : 6 287 9635

TOWN COUNCIL

NEE SOON TOWN COUNCIL

LOCATION

NEE SOON LINK DIVISION

DATE OF SERVICING

29 /09/2025

**MONTHLY HOSEREEL SYSTEM CHECKLIST REPORT**

**1. HOSEREEL**

- 1.1 Check hoses remain unobstructed
- 1.2 Ensure hoses are available for use at all times
- 1.3 Check hose reel cabinet, hose reel and rubber hose for damage
- 1.4 Inspect the stop valves, glands, pipings and shut-off nozzles are free from leak
- 1.5 Check & verify operation of stop valve at hose reel pipe & ensure valve is fully closed
- 1.6 Check operation of nozzle and stopcock for blockage

**Block No :**

| 475A | 475B | 476 | 476A | 476B | 476C |
|------|------|-----|------|------|------|
|      |      |     |      |      |      |
|      |      |     |      |      |      |
|      |      |     |      |      |      |
|      |      |     |      |      |      |
|      |      |     |      |      |      |
|      |      |     |      |      |      |

**REMARKS**

\_\_\_\_\_  
Name & signature of Technician(s)

\_\_\_\_\_  
Verified By :

1

\_\_\_\_\_  
(Name & signature)

2 \_\_\_\_\_

# Blk 476mscp roof top lift A



**NSTC**

**Hosereel drum**

**14:05** Sat  
20/09/2025

- MSCP, 476 Yishun Street 42, 760476
- Missing and broken glass

**Timemark App**  
Authentic time, GPS



**Blk 476mscp level- 8A lift**

**A**

**FIRE HOSE**



**NSTC**

**Hosereel drum**

**14:11**

Sat

20/09/2025

■ MSCP, 476 Yishun Street 42,  
760476

■ Missing and broken glass

**Timemark App**

Authentic time, GPS

**Blk 476B #7 1-2**  
**Door can't open**

**DRY RISING MAIN OUTLET 1-2**  
**FIRE HOSE REEL**

Turn on the valve before running out hose



**NSL**

**Hosereel drum**

**15:05** Sat  
20/09/2025

- Work Content: Door can't open
- 476B Yishun Street 44

**Timemark App**  
Authentic time, GPS



**Blk 476B #6 1-2 Door  
can't open**

**DRY RISING MAIN OUTLET 1-2  
FIRE HOSE REEL**

Turn on the valve before running out hose



**NSL  
Hosereel drum**

**15:07** Sat  
20/09/2025

- Work Content: Door can't open
- 476B Yishun Street 44

**Timemark App**  
Authentic time, GPS