

RED-POWER ELECTRICAL ENGINEERING PTE LTD

BLK 16 DEFU LANE 10. #01 - 364. SINGAPORE 539197

TEL : 6 289 2298

FAX : 6 287 9635

TOWN COUNCIL

NEE SOON TOWN COUNCIL

LOCATION

NEE SOON LINK DIVISION

DATE OF SERVICING

29 / 09 / 2025

MONTHLY HOSEREEL SYSTEM CHECKLIST REPORT

1. HOSEREEL

- 1.1 Check hoses remain unobstructed
- 1.2 Ensure hoses are available for use at all times
- 1.3 Check hose reel cabinet, hose reel and rubber hose for damage
- 1.4 Inspect the stop valves, glands, pipings and shut-off nozzles are free from leak
- 1.5 Check & verify operation of stop valve at hose reel pipe & ensure valve is fully closed
- 1.6 Check operation of nozzle and stopcock for blockage

Block No :

478C	479A	479B	479C	-	-
/	/	/	/	-	-
/	/	/	/	-	-
/	/	/	/	-	-
/	/	/	/	-	-
/	/	/	/	-	-
/	/	/	/	-	-

REMARKS

Name & signature of Technician(s)

Verified By :

1 Sela

(Name & signature)

2 _____

**Blk 479A level- 10 glass
broken**



NSTC

Hosereel drum

10:16

Sun

21/09/2025

- Valley Spring @ Yishun,
479A Yishun Street 44,
761479
- Missing and broken glass

Timemark App
Authentic time, GPS

**Blk 479A level- 5 glass
broken**



NSTC


Hosereel drum

10:21 Sun
21/09/2025

- Valley Spring @ Yishun,
479A Yishun Street 44,
761479
- Missing and broken glass

Timemark App
Authentic time, GPS

**Blk 479B level- 1 glass
broken**



NSTC

Hosereel drum

09:45 Sun
21/09/2025

- Valley Spring @ Yishun,
479B Yishun Street 44,
762479
- Missing and broken glass

Timemark App
Authentic time, GPS