RED-POWER ELECTRICAL ENGINEERING PTE LTD
BLK 16 DEFU LANE 10. #01 - 364. SINGAPORE 539197
TEL : 6 289 2298 FAX : 6 287 9635

TOWN COUNCIL NEE SOON TOWN COUNCIL
LOCATION CHONG PANG DIVISION
DATE OF SERVICING ____/09/2025

MONTHLY HOSEREEL SYSTEM CHECKLIST REPORT

1. HOSEREEL

1.1 Check hosereels remain unobstructed
1.2 Ensure hosereel are available for use at all times
1.3 Check hosereel cabinet, hosereel and rubber hose for damage
1.4 Inspect the stop valves, glands, pipings and shut-off nozzles are free from leak
1.5 Check & verify operation of stop valve at hosereel pipe & ensure valve is fully closed
1.6 Check operation of nozzle and stopcock for blockage

Block No :

104	105	115A	162	165	-
✓	✓	✓	✓	✓	-
✓	✓	✓	✓	✓	-
✓	✓	✓	✓	✓	-
✓	✓	✓	✓	✓	-
✓	✓	✓	✓	✓	-
✓	✓	✓	✓	✓	-
✓	✓	✓	✓	✓	-

REMARKS

Name & signature of Technician(s)

1 Selva

2 _____

Verified By :

_____
(Name & signature)