

BLK 16 DEFU LANE 10. #01 - 364. SINGAPORE 539197  
TEL : 6 289 2298 FAX : 6 287 9635

|                   |                               |
|-------------------|-------------------------------|
| TOWN COUNCIL      | <u>NEE SOON TOWN COUNCIL</u>  |
| LOCATION          | <u>NEE SOON LINK DIVISION</u> |
| DATE OF SERVICING | <u>29 /09/2025</u>            |

1. HOSEREEL
  - 1.1 Check hoses/reels remain unobstructed
  - 1.2 Ensure hoses/reel are available for use at all times
  - 1.3 Check hoses/reel cabinet, hoses/reel and rubber hose for damage
  - 1.4 Inspect the stop valves, glands, pipings and shut-off nozzles are free from leak
  - 1.5 Check & verify operation of stop valve at hoses/reel feed pipe & ensure valve is fully closed
  - 1.6 Check operation of nozzle and stopcock for blockage
2. PUMPS & TANKS
  - 2.1 Pumps and associated mechanical & electrical equipment must be checked
  - 2.2 Check water level in storage tanks
  - 2.3 Check and service ball float/pilot operated/solenoid operated valve for water storage tanks
  - 2.4 Ensure ball float/pilot operated/solenoid operated valve are in functional conditions
  - 2.5 Check pumping operating conditions such as auto cut in and off when pressure is re-established
  - 2.6 Check auto changeover of duty to standby pump
  - 2.7 Check working pressure of pressure tank and pump air if necessary
  - 2.8 Check pressure tank and its accessories
3. ALARMS, SWITCHES & CIRCUITS
  - 3.1 Check relays contact
  - 3.2 Check pressure switches setting
  - 3.3 Check pump starting equipment including circuit breakers and contactors
  - 3.4 Check and verify pump running alarm and failure alarm

[illegible]

---

---

---

Verified By :

1 sema ref.

(Name & signature)

2 \_\_\_\_\_