

(Name & signature)

MAIN INCOMING LIGHT



PUMP N° : 1		PUMP N° : 2	
RUNNING	TRIP	RUNNING	TRIP

**Blk 468A HP, income light
and low pressure light**

PUMP N° : 1		PUMP N° : 2	
START	STOP	START	STOP

ALARM CANCEL	LOW LEVEL	LOW PRESSURE	LAMP & BELL TEST



NSTC

Pressure tank

15:55 Sun
28/09/2025

■ Meadow Spring @ Yishun,
468A Yishun Street 43,
761468

■ spoil



Timemark App
Authentic time, GPS

MAIN INCOMING LIGHT

PUMP N^o : 1 PUMP N^o : 2
START STOP START STOP

Blk 469A HP ,income light
and p1 start light spoil

PUMP N^o : 1 PUMP N^o : 2
START STOP START STOP

ALARM CANCEL LOW LEVEL LOW PRESSURE LAMP & BELL TEST



NSTC

Pressure tank

16:04 Sun
28/09/2025


■ Aranda Breeze, 469A Yishun
Street 43, 761469

■ spoil



Timemark App
Authentic time, GPS

Blk 470B HP alarm bell
SPOIL



NSTC

Hosereel pump

10:04

Mon

29/09/2025

■ 470B Yishun Street 42

■ spoil

Timemark App

Authentic time, GPS