

BLK 16 DEFU LANE 10. #01 - 364. SINGAPORE 539197
TEL : 6 289 2298 FAX : 6 287 9635

TOWN COUNCIL	<u>NEE SOON TOWN COUNCIL</u>
LOCATION	<u>NEE SOON LINK DIVISION</u>
DATE OF SERVICING	29/09/2025

1. HOSEREEL
 - 1.1 Check hoses remain unobstructed
 - 1.2 Ensure hose reel are available for use at all times
 - 1.3 Check hose reel cabinet, hose reel and rubber hose for damage
 - 1.4 Inspect the stop valves, glands, pipings and shut-off nozzles are free from leak
 - 1.5 Check & verify operation of stop valve at hose reel feed pipe & ensure valve is fully closed
 - 1.6 Check operation of nozzle and stopcock for blockage
2. PUMPS & TANKS
 - 2.1 Pumps and associated mechanical & electrical equipment must be checked
 - 2.2 Check water level in storage tanks
 - 2.3 Check and service ball float/pilot operated/solenoid operated valve for water storage tanks
 - 2.4 Ensure ball float/pilot operated/solenoid operated valve are in functional conditions
 - 2.5 Check pumping operating conditions such as auto cut in and off when pressure is re-established
 - 2.6 Check auto changeover of duty to standby pump
 - 2.7 Check working pressure of pressure tank and pump air if necessary
 - 2.8 Check pressure tank and its accessories
3. ALARMS, SWITCHES & CIRCUITS
 - 3.1 Check relays contact
 - 3.2 Check pressure switches setting
 - 3.3 Check pump starting equipment including circuit breakers and contactors
 - 3.4 Check and verify pump running alarm and failure alarm

Block No :

471A	471B	472A	472B	473A
				
				
				
				
				
				
				
				
				
				
				
				
				
				
				
				

BLK 473A HP Alaym bell spoil.

Name & signature of Technician(s)

Verified By :

1 Selva Joff -

2

(Name & signature)

Blk 473A HP alarm bell

SPOIL



NSTC

Hosereel pump

10:49 Mon
29/09/2025

■ Forest Spring @ Yishun,
473A Yishun Street 42,
761473

■ spoil

Timemark App
Authentic time, GPS