

BLK 16 DEFU LANE 10. #01 - 364. SINGAPORE 539197
TEL : 6 289 2298 FAX : 6 287 9635

TOWN COUNCIL
LOCATION
DATE OF SERVICING

NEE SOON TOWN COUNCIL
NEE SOON EAST DIVISION

17/09/2025

1. QUALIFIED PERSON
- 1.1 All servicing and recharging of fire extinguishers shall only be performed by qualified person
- 1.2 Qualified person must belong to companies approved by Singapore Civil Defence Force
- 1.3 Carry out maintenance as specified in CP 55: 1991
2. FIRE EXTINGUISHERS
- 2.1 All fire extinguishers are in their designated & proper places as specified by code of practice
- 2.1 All fire extinguishers are in their designated & proper places as specified by code of practice
- 2.2 All fire extinguishers have not been discharged or lost pressure
- 2.3 Access to and visibility of each extinguishers is not obstructed
- 2.4 Operating instructions on each extinguishers surface shall be legible and faced outward
- 2.5 Pressure gauge readings if any shall be in the operable range
- 2.6 Any seals, safety clip or tamper indicators that are broken or missing shall be replaced
- 2.7 Any physical damage, corrosion, leakage or clogged nozzle shall be rectified
- 2.8 Damaged, broken or rusty fire extinguishers shall be repaired or replaced
- 2.9 Keep inspection records for those extinguishers that are found to require corrective actions
- 2.10 Submit inspection records to Superintending Officer
- 2.11 All extinguishers are to be properly hung
- 2.12 Date of service is shown and has not expired
- 2.13 The extinguishers shall bear a PSB label

Block No :

269A	269B	290	291	292	293	296	296A

REMARKS

REMARKS
BLK-269 A - RHE Fire Extinguisher missing, BLK 269 B RHE
Fire Extinguisher missing.
BLK 296 RHE Fire Extinguisher missing.

Name & signature of Technician(s)

Verified By :

1 Mami Ohi

2

(Name & signature)



NSTC

fire extinguisher

10:08 Fri
19/09/2025

■ 269A Yishun Street 22,
761269

■ fire extinguisher missing

Timemark App
Authentic time, GPS



NSTC

fire extinguisher

10:09

Fri

19/09/2025

■ 269B Yishun Street 22,
762269

■ fire extinguisher missing



© MNLPH412UCKMWA Timemark Verified

Timemark App
Authentic time, GPS



NSTC
fire extinguisher

08:53 Fri
19/09/2025

- 296 Yishun Street 20
- fire extinguisher missing

Timemark App
Authentic time, GPS