

BLK 16 DEFU LANE 10. #01 - 364. SINGAPORE 539197
TEL : 6 289 2298 FAX : 6 287 9635

NEE SOON TOWN COUNCIL

NEE SOON LINK DIVISION

29 09/2025

1. HOSEREEL

- 1.1 Check hoses/reeels remain unobstructed
- 1.2 Ensure hoses/reeels are available for use at all times
- 1.3 Check hoses/reeel cabinet, hoses/reeel and rubber hose for damage
- 1.4 Inspect the stop valves, glands, pipings and shut-off nozzles are free from leak
- 1.5 Check & verify operation of stop valve at hoses/reeel feed pipe & ensure valve is fully closed
- 1.6 Check operation of nozzle and stopcock for blockage
2. PUMPS & TANKS
- 2.1 Pumps and associated mechanical & electrical equipment must be checked
- 2.2 Check water level in storage tanks
- 2.3 Check and service ball float/pilot operated/solenoid operated valve for water storage tanks
- 2.4 Ensure ball float/pilot operated/solenoid operated valve are in functional conditions
- 2.5 Check pumping operating conditions such as auto cut in and off when pressure is re-established
- 2.6 Check auto changeover of duty to standby pump
- 2.7 Check working pressure of pressure tank and pump air if necessary
- 2.8 Check pressure tank and its accessories
3. ALARMS, SWITCHES & CIRCUITS
- 3.1 Check relays contact
- 3.2 Check pressure switches setting
- 3.3 Check pump starting equipment including circuit breakers and contactors
- 3.4 Check and verify pump running alarm and failure alarm

479B	479C	-	-	-
		-	-	-
		-	-	-
		-	-	-
		-	-	-
		-	-	-
		-	-	-
		-	-	-
		-	-	-
		-	-	-
		-	-	-
		-	-	-
		-	-	-
		-	-	-
		-	-	-
		-	-	-
		-	-	-
		-	-	-
		-	-	-
		-	-	-
		-	-	-
		-	-	-
		-	-	-
		-	-	-
		-	-	-
		-	-	-
		-	-	-
		-	-	-
		-	-	-
		-	-	-
		-	-	-
		-	-	-
		-	-	-
		-	-	-
		-	-	-
		-	-	-
		-	-	-
		-	-	-
		-	-	-
		-	-	-
		-	-	-
		-	-	-
		-	-	-
		-	-	-
		-	-	-
		-	-	-
		-	-	-
		-	-	-
		-	-	-

REMARKS

Name & signature of Technician(s)

Verified By :

1 Solve a mystery

(Name & signature)

2 _____