

BLK 16 DEFU LANE 10. #01 - 364. SINGAPORE 539197
TEL : 6 289 2298 FAX : 6 287 9635

NEE SOON TOWN COUNCIL

NEE SOON LINK DIVISION

28/09/2025

1. QUALIFIED PERSON

1.2 Qualified person must belong to companies approved by Singapore Civil Defence Force

1.3 Carry out maintenance as specified in CP 55: 1991

2.1 All fire extinguishers are in their designated & proper places as specified by code of practice

2.1 All fire extinguishers are in their designated & proper places as specified by code of practice

2.2 All fire extinguishers have not been discharged or lost pressure

2.3 Access to and visibility of each extinguishers is not obstructed

2.4 Operating instructions on each extinguishers surface shall be legible and faced outward

2.5 Pressure gauge readings if any shall be in the operable range

2.6 Any seals, safety clip or tamper indicators that are broken or missing shall be replaced

2.7 Any physical damage, corrosion, leakage or clogged nozzle shall be rectified

2.8 Damaged, broken or rusty fire extinguishers shall be repaired or replaced

2.9 Keep inspection records for those extinguishers that are found to require corrective actions

2.10 Submit inspection records to Superintending Officer

2.11 All extinguishers are to be properly hung

2.12 Date of service is shown and has not expired

2.13 The extinguishers shall bear a PSB label

385	386	387	388	389	390	391	392

Name & signature of Technician(s)

1 Selva et.

2

Verified By :

(Name & signature)