

BLK 16 DEFU LANE 10. #01 - 364. SINGAPORE 539197
TEL : 6 289 2298 FAX : 6 287 9635

NEE SOON TOWN COUNCIL
NEE SOON LINK DIVISION

29/09/2025

1. QUALIFIED PERSON

- 1.1 All servicing and recharging of fire extinguishers shall only be performed by qualified person
- 1.2 Qualified person must belong to companies approved by Singapore Civil Defence Force
- 1.3 Carry out maintenance as specified in CP 55: 1991
2. FIRE EXTINGUISHERS
- 2.1 All fire extinguishers are in their designated & proper places as specified by code of practice
- 2.1 All fire extinguishers are in their designated & proper places as specified by code of practice
- 2.2 All fire extinguishers have not been discharged or lost pressure
- 2.3 Access to and visibility of each extinguishers is not obstructed
- 2.4 Operating instructions on each extinguishers surface shall be legible and faced outward
- 2.5 Pressure gauge readings if any shall be in the operable range
- 2.6 Any seals, safety clip or tamper indicators that are broken or missing shall be replaced
- 2.7 Any physical damage, corrosion, leakage or clogged nozzle shall be rectified
- 2.8 Damaged, broken or rusty fire extinguishers shall be repaired or replaced
- 2.9 Keep inspection records for those extinguishers that are found to require corrective actions
- 2.10 Submit inspection records to Superintending Officer
- 2.11 All extinguishers are to be properly hung
- 2.12 Date of service is shown and has not expired
- 2.13 The extinguishers shall bear a PSB label

472A	472B	473A	473B	475A	475B	476	476A

Name & signature of Technician(s)

1 John & Mary

2 _____

Verified By :

(Name & signature)