

RED-POWER ELECTRICAL ENGINEERING PTE LTD

BLK 16 DEFU LANE 10. #01 - 364. SINGAPORE 539197

TEL : 6 289 2298

FAX : 6 287 9635

TOWN COUNCIL

NEE SOON TOWN COUNCIL

LOCATION

NEE SOON EAST DIVISION

DATE OF SERVICING

08/09/2025**MONTHLY PRESSURE TANK CHECKLIST REPORT**

1. Test run of pumps
2. Check pump and motor running condition
3. Check coupling set, baseplate and spring isolator
4. Check mechanical seal / gland-packing and bearings
5. Check all pipe work, check valve, gate valve, expansion joint, strainer
6. Check correct function of pump system in auto and manual mode
7. Check control panel and electrical isolator
8. Check electrical components in control panel
9. Check all indicator lamps
10. Check conduit and wiring
11. Check electrode holder and sensor
12. Check ball float valve / pilot valve and motorised valve
13. Check pump running ampere
14. Check pressure switch setting and pressure gauge

Block No :

316A	316B	316C	317	317A	317B	317C	318A	318B
✓	✓	✓	✓	✓	✓	✓	✓	✓
✓	✓	✓	✓	✓	✓	✓	✓	✓
✓	✓	✓	✓	✓	✓	✓	✓	✓
✓	✓	✓	✓	✓	✓	✓	✓	✓
✓	✓	✓	✓	✓	✓	✓	✓	✓
✓	✓	✓	✓	✓	✓	✓	✓	✓
✓	✓	✓	✓	✓	✓	✓	✓	✓
✓	✓	✓	✓	✓	✓	✓	✓	✓
✓	✓	✓	✓	✓	✓	✓	✓	✓
✓	✓	✓	✓	✓	✓	✓	✓	✓
3.0	3.8	3.8	3.0	4.0	6.5	4.5	4.0	4.5
✓	✓	✓	✓	✓	✓	✓	✓	✓

REMARKS

BLK-317B PT1 & PT2 Spoil. BLK-316B PT1 - Spoil^o
BLK-316B ~~PT1~~ PT1 - Spoil.

Name & signature of Technician(s)

1 Mami Olayi

2 _____

Verified By :

(Name & signature)



RED POWER
DURAI

16:38 Mon
08/09/2025

■ Yishun Greenwalk, 316B
Yishun Avenue 9, 762316

Timemark App.
Authentic time, GPS



© KT2D499GHX9BK1 Timemark Verified



RED POWER
DURAI

15:31 Mon
08/09/2025

■ Yishun Greenwalk, 317B
Yishun Avenue 9, 762317

Timemark App
Authentic time, GPS