

RED-POWER ELECTRICAL ENGINEERING PTE LTD

BLK 16 DEFU LANE 10. #01 - 364. SINGAPORE 539197

TEL : 6 289 2298

FAX : 6 287 9635

TOWN COUNCIL

NEE SOON TOWN COUNCIL

LOCATION

NEE SOON SOUTH DIVISION

DATE OF SERVICING

30 /09/2025**MONTHLY PRESSURE TANK CHECKLIST REPORT**


1. Test run of pumps
2. Check pump and motor running condition
3. Check coupling set, baseplate and spring isolator
4. Check mechanical seal / gland-packing and bearings
5. Check all pipe work, check valve, gate valve, expansion joint, strainer
6. Check correct function of pump system in auto and manual mode
7. Check control panel and electrical isolator
8. Check electrical components in control panel
9. Check all indicator lamps
10. Check conduit and wiring
11. Check electrode holder and sensor
12. Check ball float valve / pilot valve and motorised valve
13. Check pump running ampere
14. Check pressure switch setting and pressure gauge

Block No :

846	848A	849	-	-	-	-	-	-
/	/	/	-	-	-	-	-	-
/	/	/	-	-	-	-	-	-
/	/	/	-	-	-	-	-	-
/	/	/	-	-	-	-	-	-
/	/	/	-	-	-	-	-	-
/	/	/	-	-	-	-	-	-
/	/	/	-	-	-	-	-	-
/	/	/	-	-	-	-	-	-
/	/	/	-	-	-	-	-	-
/	/	/	-	-	-	-	-	-
3.5	3.0	4.0	-	-	-	-	-	-
/	/	/	-	-	-	-	-	-

REMARKS

Name & signature of Technician(s)

1 

2 _____

Verified By :

(Name & signature)