

RED-POWER ELECTRICAL ENGINEERING PTE LTD

BLK 16 DEFU LANE 10, #01 - 364, SINGAPORE 539197

TEL : 6 289 2298

FAX : 6 287 9635

TOWN COUNCIL

NEE SOON TOWN COUNCIL

LOCATION

NEE SOON LINK DIVISION

DATE OF SERVICING

28/09/2025**MONTHLY PRESSURE TANK CHECKLIST REPORT**

1. Test run of pumps
2. Check pump and motor running condition
3. Check coupling set, baseplate and spring isolator
4. Check mechanical seal / gland-packing and bearings
5. Check all pipe work, check valve, gate valve, expansion joint, strainer
6. Check correct function of pump system in auto and manual mode
7. Check control panel and electrical isolator
8. Check electrical components in control panel
9. Check all indicator lamps
10. Check conduit and wiring
11. Check electrode holder and sensor
12. Check ball float valve / pilot valve and motorised valve
13. Check pump running ampere
14. Check pressure switch setting and pressure gauge

Block No :

462D	465	465A	465B	466A	466B	467A	467B	467C
/	/	/	/	/	/	/	/	/
/	/	/	/	/	/	/	/	/
/	/	/	/	/	/	/	/	/
/	/	/	/	/	/	/	/	/
/	/	/	/	/	/	/	/	/
/	/	/	/	/	/	/	/	/
/	/	/	/	/	/	/	/	/
/	/	/	/	/	/	/	/	/
/	/	/	/	/	/	/	/	/
/	/	/	/	/	/	/	/	/
/	/	/	/	/	/	/	/	/
303.5	3.5	3.5	3.5	3.0	3.0	3.0	3.0	3.5
/	/	/	/	/	/	/	/	/

REMARKS

Blk 465 MSCP HP Pressure tank 2 Spoil.
Blk 467B HP Pressure tank Spoil.

Name & signature of Technician(s)

1 J. S. Selva

2 _____

Verified By :

(Name & signature)

Blk 465 mscp HP PT2

SPOIL



NSTC

Pressure tank

15:39

Sun

28/09/2025

■ MSCP, 465 Yishun Avenue 6,
760465

■ spoil

Timemark App

Authentic time, GPS

PT2 SPOIL

PT2



NSTC
Pressure tank

15:25 Sun
28/09/2025

■ Casa Spring @ Yishun, 467B
Yishun Avenue 6, 762467

■ spoil

Timemark App
Authentic time, GPS