TAG NO.	605-V-218
SERVICE	COALESCER
ID x TT	VESSEL 1000 x 3200 MM
	BOOTS 356 x 957 MM
DESIGN PRESS.	315 / FV PSIG
DESIGN TEMP.	200 ° F
INSULATION	NONE NOTE 9 MM
MATERIAL	CS WITH GLASS FLAKE LINING

FROM INLET SEPARATOR 605-V-202

605-007-01

605-6"-GR-BDA-029-H50 NOTE 9

HIC 185 NOTE 1

605 HV 185

6" FC

3/4"

NOTE 13

TWO PHASE FLOW

TO CONDENSATE STRIPPER PREHEATER 605-E-109

605-007-03

SET @ 14 PSI

605 PDI 144 H

605 PDT 144

SET@ 315 PSIG 3"xKx4"

605 PSV 101

RH 695-082-01

605-6"-RH-ASA-151

FREE DRAINING

6" 6"x4"

LO

ASA BDA

4"x3"

3/4"

2"

605-4"-GR-BDA-153-H50

FREE DRAINING

6"

3/4"

FREE DRAINING

FREE DRAINING

BY INSTR. BY PIPING

3/4"

605-3/4"-GR-BDA-154

605-3/4"-GR-BDA-155

605 PG 138

2" 600# NOTE 6

605-6"-GR-BDA-152-H50 NOTE 9, 13

6"x10"

10" 600# NOTE 6

SET @ 315 PSIG 1"xEx2"

605 PSV 121

2"x3"

2"x1"

LO

605-3"-RH-ASA-156

FREE DRAINING

RH 695-082-01

ASA BDA

2" LC

3/4"

605-2"-GR-BDA-156-H40 NOTE 13

2" NOTE 13

FREE DRAINING

605-3/4"-GR-BDA-159 NOTE 13

SC TYPE V NOTE 11

605-3/4"-RH-ASA-157

RH 695-082-01

605-V-218

20" MW

600# 10" NOTE 6

24" MW

6"x10"

NOTE 9 605-6"-GR-BDA-151-H50

600# NOTE 6

605 LA 134 LL

605 LZT 134 DISP

UC 2"

2" 600# NOTE 7

605-2"-RH-BDA-155

605-3/4"-GR-BDA-164

605 LG NOTE 10 136

605 LT 137 DISP

605 LIC 137 NOTE 2 H L

605-3/4"-GR-BDA-165

600# NOTE 6

ESS

605 SDV 101

2" FC TSO

LOW POINT

MIN.

605-2"-WP-BDA-151

2"x1"

605 LV 137

FC 1"

3/4"

1"

BDA ADA

605-2"-WP-ADA-151

TO 660-V-201

660-001-01


ASA BDA


RH 695-082-01

605-2"-RH-ASA-152

605-2"-WP-BDA-152

NOTES

1. 605-HV-185 IS AUTOMATICALLY OPENED BY 605-PDIH-144.
2. TO PROVIDE GAP CONTROL.
3. DELETED
4. DELETED
5. DELETED
6. 

7. 

8. DELETED
9. ALL PIPING HOT INSULATION TO BE CHANGED TO S25, IF SWEATING IS OBSERVED ON SITE.
10. WITH ILUMINATION
11. CONNECT AT BOTTOM OF PIPE.
12. DELETED
13. VALVE'S MATERIAL BELONG TO THIS LINE ARE CARBON STEEL (BCB CLASS) INSTEAD OF DUPLEX.

BCD3-000-42-PID-1-001-01 TO 012	P&ID SYMBOLS
NO.	REFERENCE DOCUMENT

REV.	ISSUED	PURPOSE	LDE	PEM	PM	STATUS	DATE
COMPANY STATUS							
2	RE-AS BUILT		21-MAR-12				
1	AS BUILT		13-OCT-06	non	JW	RF	WT
0	ISSUED FOR CONSTRUCTION INCLUDING HAZOP COMMENTS		13-JUNE-06	non	JW	RF	WT
NO.	DESCRIPTION		DATE	BY	CHKD	RVD	APVD
CONTRACTOR REVISIONS							

PT. CHIYODA INTERNATIONAL INDONESIA

PT. Sempec Indonesia

CONTRACT	JOB
	E3X01

PetroChina International Jabung Ltd.

BETARA COMPLEX DEVELOPMENT

PIPING AND INSTRUMENTATION DIAGRAM
BETARA GAS PLANT
COALESCER

SCALE : NTS

DOCUMENT: BCD3-605-42-PID-1-007-02

REVISION: 2

FILE NAME :\BCD3-605-42-PID-1-007-01.DWG