TAG NO.	605-E-109			
SERVICE	CONDENSATE STRIPPER PRE-HEATER			
TYPE/SURFACE	BEM/238		M2	
HEAT DUTY	6.30		MM BTU/HR	
	SHELL		TUBE	
DESIGN PRESS.	300	PSIG	315	PSIG
DESIGN TEMP.	411	° F	200	° F
INSULATION	P40	MM	H50	MM
MATERIAL	CS		SS 316L	

NOTES

1. 605-TV-121A AND B ARE REVERSE ACTING.
2. THESE HOT INSULATIONS TO BE CHANGED TO S25, IF SWEATING IS OBSERVED ON SITE.
3. VALVE'S MATERIAL BELONG TO THIS LINE ARE CARBON STEEL (BCB CLASS) INSTEAD OF DUPLEX.

SET @ 300 PSIG 1-1/2"xFx2"
605 PSV 192
RH 695-083-01
605-4"-RH-ASA-061
FREE DRAINING
2"x4"
LO
1-1/2"x4"
3/4"
ASA BCC H50
2" LC
3/4"
2" LC
ASA BCC
LO
605-4"-GR-BCC-166-H50
FREE DRAINING

SET @ 315 PSIG 1"xDx2"
605 PSV 193
RH 695-083-01
605-3"-RH-ASA-062
FREE DRAINING
2"x3"
LO
1"x2"
3/4"
ASA BDA H40
2" LC
3/4"
2" LC
ASA BDA
LO
605-2"-GR-BDA-169-H40
FREE DRAINING

FROM CONDENSATE STRIPPER 605-C-101
605-011-01
605-8"-GR-BCC-161-H62

SET@120°F
605 TIC 121 L
NOTE 1
605 TT 121
1 1/2"

TO CONDENSATE STRIPPER 605-C-101
605-011-01
MIN
605-6"-GR-BDA-029-H50
TWO PHASE FLOW

605-6"-GR-BDA-029-H50 NOTE 2, 3
TWO PHASE FLOW

605 TG 136
1 1/2"
8"
605 TG 137
1 1/2"
6"
8"x4"
4"
6"

605 TYC 121B
605 TYC 121A
605 TV 121A
8"
8" FO
8"
3/4"
3/4"
8"

605-E-109

6"
4"
H50 P40
4"x8"
P40 H50

605 PG 121
3/4"
605 TG 135
1 1/2"

605-8"-GR-BCC-163-P40
605-8"-GR-BCC-162-P40

605 TG 101
1 1/2"
LOW POINT
605-8"-GR-BCC-162-P40
605 TV 121B
8"
8" FC
8"
3/4"
3/4"
8"

TO NGL RUNDOWN COOLER 605-E-104
605-011-02
605-8"-GR-BCC-039-P40
605-2"-GR-BCC-043-P25
2"
2"
3/4"
BCC ASA
605-2"-RH-ASA-026
RH 695-083-01

605-2"-RH-ASA-161
RH 695-083-01
605-2"-GR-BCC-168-P25
3/4"
BCC ASA P25

FROM COALESCER 605-V-218
605-007-02
605-6"-GR-BDA-029-H50 NOTE 2, 3
TWO PHASE FLOW
6"
LOW POINT

RH 695-083-01
605-2"-RH-ASA-162
3/4"
ASA BDA H40
605-2"-GR-BDA-167-H40

BCD3-000-42-PID-1-001-01 TO 012	P&ID SYMBOLS
NO.	REFERENCE DOCUMENT

REV.	ISSUED PURPOSE	LDE	PEM	PM	STATUS	DATE
COMPANY STATUS						
2	RE-AS BUILT					21-MAR-12
1	AS BUILT					13-OCT-06
0	ISSUED FOR CONSTRUCTION INCLUDING HAZOP COMMENTS					13-JUNE-06
NO.	DESCRIPTION			DATE	BY	CHKD RVD APVD
CONTRACTOR REVISIONS						

PT. CHIYODA INTERNATIONAL INDONESIA
PT. Sempec Indonesia

CONTRACT	JOB
	E3X01

PetroChina International Jabung Ltd.

BETARA COMPLEX DEVELOPMENT

PIPING AND INSTRUMENTATION DIAGRAM
BETARA GAS PLANT
CONDENSATE STRIPPER PRE-HEATER

SCALE : NTS

DOCUMENT	REVISION
BCD3-605-42-PID-1-007-03	2

FILE NAME :\BCD3-605-42-PID-1-007-01.DWG