TAG NO.	605-V-203	
SERVICE	CONDENSATE STRIPPER OVHD KO DRUM	
ID x TT	1000 x 2100	MM
DESIGN PRESS.	600 / FV	PSIG
DESIGN TEMP.	240 / 73	°F
INSULATION	NONE	MM
MATERIAL	CS + SS 316L CLAD	

NOTES

1. CARBON STEEL PLATE WITH AUSTENITIC STAINLESS STEEL CLAD LINING.
2. THE VALVE SHALL BE SIZED FOR FULL FLOW.
3. TO BE LOCATED AT HIGH POINT.
4. 605-PV-162 HAS SOV FOR EMERGENCY ACTION.

NOTE 4 ESS
NOTE 2, 3
605 PV 162
SPILL BACK LINE FROM COND. STRIPPER COMP. AFTER K.O. DRUM 605-V-205
605-014-01
605-6"-GR-BDA-074
FREE DRAINING
6"x3"
3"x6"
3" FO
3/4"
BDA CSA
605-6"-GR-CSA-074
605 PIC 162 SET @ 256.3 psig.
605 PT 162
3/4"
TO CONDENSATE STRIPPER OVHD COMP. 605-K-101 A/B
605-013-01
605-10"-GR-CSA-052-H1A50-E
(NO POCKET)
SET @600 Psig
3"xJx4"
605 PSV 161
LO
ASA CSA
605-4"-RH-ASA-012
FREE DRAINING
RH 695-085-02
6"x3"
3/4"
LO
RH 695-083-01
2"
605-10"-GR-CSA-052-H1A50-E
605-6"-GR-CSA-055
FREE DRAINING
RH 695-083-01
3/4"
2"
605-2"-VES-CSA-203A
605 RO 162
2"
10"
605-2"-VES-CSA-203C
2"
605 PG 161
6"
605 TG 161
1½"
605-10"-GR-BDA-035
10"
605-V-203
NOTE 1
600#
605-2"-VES-CSA-203D
605-2"-VES-CSA-203F
605-2"-VES-CSA-203E
2"
605 LG 161
605 LT 162
605 LZT 161
605 LX 161 HH
605 LA 161 HH
24"
SET @ 50%
605 LIC 162
UC
TL EL.1800
605-2"-VES-CSA-203B
605-3/4"-RH-ASA-048
605 LV 162
ASA CSA
2"x1"
1"x2"
1" FC
3/4"
605-2"-RH-ASA-016
RH 695-083-01
605-2"-GR-CSA-076
RH 695-083-01
1"
ASA CSA
605-2"-GR-CSA-079
TO NGL STORAGE-B
670-001-01
3/4"
2"
3/4"
605-8"-GR-BDA-083
605 PV 140
BDA ASA
8" FC
3/4"
605-8"-RH-ASA-023
3/4"
ESS
605 BDV 130
605 RO 131
BDA ASA
6"x10"
6"-FO TSO TYPE-III
3/4"
LO
605-10"-RH-ASA-027
FREE DRAINING
605-6"-GR-BDA-047
FREE DRAINING
SET @ 283 psig.
TO 605-FI-161
605-011-01
605 PIC 140 H L
605 PT 140
3/4"
FLASH GAS FROM INLET SEPARATOR 605-V-202
605-007-01
605-6"-GR-BDA-028
6" 6"x10"
3/4"
6"
ESS
605 SDV 161
FC TSO TYPE I
GAS FROM CONDENSATE STRIPPER 605-C-101
605-011-01
605-6"-GR-BDA-035

BCD3-000-42-PID-1-001-01 TO 012		P&ID SYMBOLS					
NO.		REFERENCE DOCUMENT					

REV.	ISSUED	PURPOSE	LDE	PEM	PM	STATUS	DATE
COMPANY STATUS							
6	AS BUILT		22-MAR-12				
5JB	ISSUED FOR REVIEW		29-AUG-08	WST	WID	BG	
5	AS BUILT		18-JUL-05	ASW	RF	BS	TU
4	ISSUED FOR CONSTRUCTION		11-MAY-05	ASW	RF	BS	TU
3	ISSUED FOR CONSTRUCTION		09-SEPT.-04	ASW	RF	BS	TU
2	ISSUED FOR CONSTRUCTION		19-JUNE-04	ASW	RF	BS	TU
1	ISSUED FOR CONSTRUCTION		27-MAR-04	ASW	RF	BS	TU
0	ISSUED FOR CONSTRUCTION		14-JAN-04	ASW	K.T. RD	AU BS	TU
E	ISSUED FOR HAZOP		19-SEPT-03	ASW	K.T. RD	AU BS	TU
D	ISSUED FOR HAZOP		08-SEPT-03	ASW	K.T. RD	AU BS	TU
C	THE APPROVAL		7-AUGUST-03	ASW	K.T. RD	AU BS	TU
B	INTERNAL REVISION		10-MAY-03	ASW	K.T. RD	AU BS	TU
A	ISSUED FOR REVIEW		01-APR-03	ASW	K.T. RD	AU BS	TU
NO.	DESCRIPTION		DATE	BY	CHKD	RVD	APVD
CONTRACTOR REVISIONS							

PT. CHIYODA INTERNATIONAL INDONESIA
PT. Sempec Indonesia

CONTRACT	JOB
	E3X01

PetroChina International Jabung Ltd.

BETARA COMPLEX DEVELOPMENT

PIPING AND INSTRUMENTATION DIAGRAM
BETARA GAS PLANT
CONDENSATE STRIPPER OVERHEAD COMPRESSOR
(1/3)

SCALE : NTS

DOCUMENT	REVISION
BCD3-605-42-PID-1-012-01	6

FILE NAME :\BCD3-605-42-PID-1-012-01.DWG