TAG. NO	605-E-110 A	
SERVICE	INLET COMPRESSOR AFTER COOLER A	
TYPE/SURFACE (FIN)	FORCED / NOTE 2	M2
HEAT DUTY	18.18	MMBTU/HR
DESIGN PRESS.	910 / FV	PSIG
DESIGN TEMP.	300/73	° F
DRIVER	40	HP
HEAD MATERIAL	SS 316L	
TUBE MATERIAL	SS 316L	

TAG NO.	605-V-221 A	
SERVICE	INLET COMPRESSOR DISCHARGE SCRUBBER A	
ID x TT	850 x 2625	MM
DESIGN PRESS.	910 / FV	PSIG
DESIGN TEMP.	200/70	° F
INSULATION	NONE	MM
MATERIAL	CS + SS 316L CLAD	
TRIM MATERIAL	SS 316 L	

FROM INLET COMPRESSOR A
605-016-01
605-K-102 A

605-12"-GR-CDA-123

605 TG 412 1-1/2"

605 PG 412 3/4"

12" 12"

8" 8" 8" 8" 8" 8" 8" 8"

605-E-110 A

605 XI 413A TYPE-B1

605 VA 414A H

605 XI 413B TYPE-B1

605 VA 414B H

ESS ESS

12" 12"

NOTE 3

605 PG 415 3/4"

FREE DRAINING

605 TI 415 H L

605 TT 415 RTD

1-1/2"

605-12"-GR-CDA-124

SET @ 910 PSIG
4"x M x 6" (BLOCKED OUTLET)

605 PSV 420

8"x6" LO 8"

150# 600#

6"x4"

3/4"

6" LO

2" ASA CSA

2" 3/4"

605-8"-RH-ASA-162

RH 695-084-02

ANTI SURGE FLOW SUCTION SCRUBBER A
605-015-01
605-V-220 A

605-10"-GR-CDA-127
(NO POCKET)

CCP ESS NOTE 1

605 BDV 422

605 RO 421

2" 4"x2" 4" LO

605-4"-RH-ASA-163

RH 695-084-02

CSA ASA

FO TSO TYPE IV

605-2"-GR-CSA-186

605 TG 416 1-1/2"

CDA CSA 12"x10"

605-12"-GR-CSA-190

NOTE 3, 6

CCP ESS

605 SDV 420

12" NOTE 7

12" FC TSO TYPE II

3/4" 12" 3/4" CSA CDA

605-12"-GR-CDA-125

RAW GAS TO INLET COMPRESSOR DISCHARGE HEADER
605-019-04

605-6"-GR-CSA-152

16"x12" MIN. 2D STRAIGHT LENGTH

2" 16" N2 N6

6" N9

20"x12" 20" N1 MIN. 10D STRAIGHT LENGTH

NOTE 4

2" N7A

2" N8A

605 LG 416

605 LZT 416 NOTE 8

CCP HH LL

2" N8B

2" N7B

605 LT 417

605 LIC 417 H L

2" N6A

2" N6B

605-V-221 A

24" MW

N4 2" UC

N3

2"

MIN.

605-2"-GR-CSA-172

605-3/4"-RH-ASA-164

CCP 605 SDV 418

2" FC TSO TYPE 1

605 LV 417

2"x1" 2"x1" CSA BSA

2" 3/4" FC 3/4" 2"

1" CSA BSA

605-2"-GR-BSA-128

HC LIQUID TO INLET SEPARATOR
605-019-04

RH 695-084-02

605-2"-RH-ASA-173 2" ASA CSA 3/4"

2" 605-2"-GR-CSA-174 2"

LEVEL DIAGRAM 605-V-221A
(FROM BOTTOM TANGENT LINE)

LEVEL	UNIT (MM)
HHLL	650
HLL	550
NLL	450
LLL	350
LLLL	250

BY PIPING BY INSTR.

605 PDZT 420

CCP

FINAL APPROVAL BY COMPANY			
DRAWING NO.	REV. NO.	APPROVED BY	DATE

NOTES :
1. TO PROVIDE MANUAL OVERRIDE FROM DCS.
2. VENDOR SHALL SPECIFY SURFACE AREA REQUIRED
3. USE EQUAL TEES TO MINIMIZE FLOW INDUCED RESONANCE ON NON-FLOWING LINES CONNECTIONS.
4. VANE TYPE INTERNALS SHALL BE APPLIED.
5. DELETED.
6. DISSIMILAR WELDING
7. NON SLAM CHECK VALVE
8. SDV-418 CLOSES IF LZT-416 ON LOW-LOW ALARM STATUS AND COMPRESSOR SHUTDOWN LZT-416 ON HIGH-HIGH ALARM STATUS.

REFERENCE DWG NO	DESCRIPTION
BCD4-000-42-PID-3-001-01~15	P&ID SYMBOLS

REVISIONS

REV	DRFT'G	DATE	DESCRIPTION	PREPARED BY	CHECKED BY	APPROVED BY	APPROVED BY
1	NUR	08/07/11	AS BUILT	PBS/AW	SPD	ECR/RPS	RSD
0	EB	05/02/10	APPROVED FOR CONSTRUCTION	PBS/AW	SPD	ECR/RPS	RSD
C	EB	23/10/09	FOR ACCEPTANCE	PBS/AW	SPD	ECR/RPS	RSD
B	EB	04/09/09	FOR ACCEPTANCE	PBS/AW	SPD	ECR/RPS	RSD
A	DP	24/08/09	FOR DISCIPLINE COORDINATION	PBS/AW	SPD	ECR/RPS	RSD

CLIENT

PetroChina International Jabung Ltd.
Betara Complex Development
Job No. : BCD - 335 - CA

CONTRACTOR

PT MEINDO ELANG INDAH PT CAKRA NUSA DARMA PT SINGGAR MULIA

TITLE
PIPING AND INSTRUMENTATION DIAGRAM
BETARA GAS PLANT
INLET COMP. AFTER COOLER A AND DISCH. SCRUBBER A

SIZE	SCALE	DRAWING No.	SHT No.	REV.
A3	NTS	BCD4-605-42-PID-3-019-01	1 OF 4	1

CAD FILE NAME : BCD4-605-42-PID-3-019-01_1.DWG