

# कार्यालय मुख्य चिकित्सा एवं स्वास्थ्य अधिकारी,

जिला – रायपुर (छ.ग.)

(Email-cmho\_raipur@yahoo.co.in Ph-0771-2535304)

क्रमांक / सीएमएचओ / सत्रह / 2025 / 24021

रायपुर दिनांक 25/07/2025

## REGARDING SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

It is certified that an inspection team headed by DR. S. K. Vohra DHO (Name of Officers with designation) from CHIEF MEDICAL AND HEALTH OFFICER RAIPUR (C.G.) (Name of Department/Office) inspected the KRISHNA PUBLIC SCHOOL RAIPUR DISTTI. RAIPUR (C.G.) (Name & Address of the School ) on 21-07-2025 and found that KRISHNA PUBLIC SCHOOL NADANVAN ROAD, NEAR BANGLAMUKHI MANDIR (VILG. TENDUA) RAIPUR DISTTI. RAIPUR (C.G.) (Name of School) has safe drinking water facilities for the students and members of staff of the institution and is maintaining the hygienic sanitation condition in the school building and campus as per the norms prescribed by the Central/State/U.T Govt.

The above valid Certificate is for a period of ONE YEAR FROM DATE OF ISSUE.

The Chief Medical & Health Officer  
C.M. District - Raipur (C.G.)

TO,

PRINCIPAL  
KRISHNA PUBLIC SCHOOL  
TENDUA, RAIPUR  
DISTTI. RAIPUR (C.G.)

  
Principal  
Krishna Public School  
Tendua, Raipur (C.G.)

  
Manager  
Krishna public School  
Tendua, Raipur (C.G.)

कार्यालय सहायक अभियंता,  
लोक स्वास्थ्य यांत्रिकी उपखण्ड,  
रायपुर (छ.ग.)

क्रमांक .....168.....जि.प्र.शा./लो.स्वा.या./उपखण्ड रायपुर

दिनांक 26/05/25

✓ प्रति,

Principal  
Krishna Public School  
Tendua, Raipur (C.G.)

विषय :- जल नमूनों के परीक्षण रिपोर्ट प्रेषित करने बाबत।  
संदर्भ :- आपका पत्र क्रमांक. KPSTEN/25/361 दिनांक 21.05.2025

उपरोक्त विषयान्तर्गत लेख है कि संदर्भित पत्र के माध्यम से प्राप्त जल नमूने का, जिला जल परीक्षण प्रयोगशाला लोक स्वास्थ्य यांत्रिकी विभाग रायपुर में परीक्षण कर रिपोर्ट आपकी ओर प्रेषित है।

संलग्न :- रिपोर्ट नंबर - 349 एवं बिल नंबर - 419 की एक प्रति।

  
सहायक अभियंता

लोक स्वास्थ्य यांत्रिकी उपखण्ड  
रायपुर (छ.ग.)

  
Principal  
Krishna Public School  
Tendua, Raipur (C.G.)

  
Manager  
Krishna Public School  
Tendua, Raipur (C.G.)



TC-13095

जिला जल परीक्षण प्रयोगशाला  
लोकस्वास्थ्य यांत्रिकी विभाग रिंगरोड 1, रावणभाटा, रायपुर (छ.ग.)  
**DISTRICT WATER TESTING LABOARATORY, PHED.**  
**RING ROAD NO.1 RAWANBHANTA RAIPUR (C.G.)**  
email:- dwtlraipur@gmail.com

**TEST REPORT (DRINKING WATER)**

|                                                                                             |                               |                        |                                |                        |
|---------------------------------------------------------------------------------------------|-------------------------------|------------------------|--------------------------------|------------------------|
| Report No. DI/Phed/Rpr.: 349                                                                | Discipline:- Chemical Testing | Group:- Drinking Water | ULR no. -: TC1309525000000349F |                        |
| Senders name & address:-<br><br>Principal<br>Krishna Public School<br>Tendua, Raipur (C.G.) | Senders letter no./Date       | 361 / 21.05.2025       | Sampled by & Date              | Customer<br>22.05.2025 |
|                                                                                             | DL receipt no.                | 349                    | DL Receipt date                | 22.05.2025             |
|                                                                                             | Date of analysis started      | 22.05.2025             | Date of analysis completed     | 24.05.2025             |

**SAMPLE DETAILS**

| S.N. | Sample I.D.      | District / Block | City / Village | Habita. | Location/Source ID./GPS Identification |
|------|------------------|------------------|----------------|---------|----------------------------------------|
| 1.   | 349/2135/05/2025 | Raipur           | Raipur         | -       | Water Sample Of, Krishna Public School |
| -    | -                | -                | -              | -       | -                                      |
| -    | -                | -                | -              | -       | -                                      |
| -    | -                | -                | -              | -       | -                                      |

**DETAILS OF PARAMETERS THEIR TEST METHOD UNITS AND SPECIFICATION AS PER IS/APHA**

| S.N. | Parameters                          | Test method<br>IS:3025/APHA 24th ed. | Unit     | As per IS-10500-2012<br>drinking water |                   | Result Of S.No. |   |   |   |
|------|-------------------------------------|--------------------------------------|----------|----------------------------------------|-------------------|-----------------|---|---|---|
|      |                                     |                                      |          | Acceptable Limit                       | Permissible Limit | 1               | - | - | - |
| 1    | Fluoride                            | APHA 24 <sup>th</sup> ed4500-F- C    | mg/L.    | 1.0                                    | 1.5               | 0.363           | - | - | - |
| 2    | Chloride                            | IS:3025Part- 32                      | mg/L.    | 250                                    | 1000              | 38.80           | - | - | - |
| 3    | Alkalinity as CaCO <sub>3</sub>     | IS:3025Part-23                       | mg/L.    | 200                                    | 600               | 264.37          | - | - | - |
| 4    | Calcium                             | IS:3025Part-40                       | mg/L.    | 75                                     | 200               | 67.59           | - | - | - |
| 5    | Magnesium                           | APHA24th ed.3500 Mg-B                | mg/L.    | 30                                     | 100               | 23.62           | - | - | - |
| 6    | pH @ 25°C                           | IS:3025Part-11                       | PH scale | 6.5-8.5                                | 6.5-8.5           | 7.29            | - | - | - |
| 7    | Turbidity                           | IS:3025Part-10                       | NTU      | 1                                      | 5                 | 0.60            | - | - | - |
| 8    | Total Hardness as CaCO <sub>3</sub> | IS:3025Part-21                       | mg/L.    | 200                                    | 600               | 265.85          | - | - | - |
| 9    | Spe.Conductivity @ 25°C             | IS:3025Part- 14                      | µmho/cm  | -                                      | -                 | 611.75          | - | - | - |

**Remark:-**

- The report should not be produced partly or full without approval signatory authority of legal purpose.
- It is recommended that acceptable limit is to be implemented. Values in excess of those mentioned under "acceptable" render the water not suitable, but still may be tolerated in the absence of an alternative source but up to the limits indicated under the "permissible" limit in the absence of alternate source in column 7 above which the sources will have to be rejected.
- The results refer only to tested samples and parameters.
- Samples will be stored for a period of 10 days from date of issue of report.
- This Lab does not hold any responsibility for variation in results for samples kept on hold for wants of clarification.
- Results apply to the sample as received. 7. Sampling not done by Lab staff.

Tested by

Report Reviewed &amp; Approved by

(Mani Shankar Roy)  
Lab Assistant

Principal  
Krishna Public School  
Tendua, Raipur (C.G.)

Manager  
Krishna public School  
Tendua, Raipur (C.G.)

(Umesh Sahu)  
Authorized Signatory

जिला जल परीक्षण प्रयोगशाला  
लोकस्वास्थ्य यांत्रिकी विभाग रिंगरोड 1, रावणभाठा, रायपुर (छ.ग.)  
**DISTRICT WATER TESTING LABOARATORY, PHED.**  
**RING ROAD NO.1 RAWANBHANTA RAIPUR (C.G.)**  
email:- dwtlraipur@gmail.com

**TEST REPORT (DRINKING WATER)**

|                                                                                             |                               |                        |                            |                        |
|---------------------------------------------------------------------------------------------|-------------------------------|------------------------|----------------------------|------------------------|
| Report No. DI/Phed/Rpr.: 349                                                                | Discipline:- Chemical Testing | Group:- Drinking Water |                            |                        |
| Senders name & address:-<br><br>Principal<br>Krishna Public School<br>Tendua, Raipur (C.G.) | Senders letter no./Date       | 361 / 21.05.2025       | Sampled by & Date          | Customer<br>22.05.2025 |
|                                                                                             | DL receipt no.                | 349                    | DL Receipt date            | 22.05.2025             |
|                                                                                             | Date of analysis started      | 22.05.2025             | Date of analysis completed | 24.05.2025             |

**SAMPLE DETAILS**

| S.N. | Sample I.D.      | District / Block | City / Village | Habita. | Location/Source ID./GPS Identification |
|------|------------------|------------------|----------------|---------|----------------------------------------|
| 1.   | 349/2135/05/2025 | Raipur           | Raipur         | -       | Water Sample Of, Krishna Public School |
| -    | -                | -                | -              | -       | -                                      |
| -    | -                | -                | -              | -       | -                                      |
| -    | -                | -                | -              | -       | -                                      |

**DETAILS OF PARAMETERS THEIR TEST METHOD UNITS AND SPECIFICATION AS PER IS/APHA**

| S.N. | Parameters        | Test method<br>IS:3025/APHA 24th ed. | Unit  | As per IS-10500-2012<br>drinking water |                   | Result Of S.No. |   |   |   |
|------|-------------------|--------------------------------------|-------|----------------------------------------|-------------------|-----------------|---|---|---|
|      |                   |                                      |       | Acceptable Limit                       | Permissible Limit | 1               | - | - | - |
| 10   | Colour            | APHA 24 <sup>th</sup> ed.2120-B      | Hazen | 05                                     | 15                | 4               | - | - | - |
| 11   | Odour             | IS:3025 Part -5                      | -     | Agreeable                              | Agreeable         | Agreeable       | - | - | - |
| 12   | Iron              | APHA 24th ed 3500-Fe-B               | mg/l. | 1.0                                    | No relaxation     | 0.057           | - | - | - |
| 13   | Nitrates          | APHA 24th ed 4500-NO <sub>3</sub> -B | mg/l. | 45                                     | No relaxation     | 1.812           | - | - | - |
| 14   | TDS               | APHA 24th ed.2540-C                  | mg/l. | 500                                    | 2000              | 421             | - | - | - |
| 15   | Residual Chlorine | -                                    | mg/l. | 0.2                                    | 1.0               | 0.00            | - | - | - |
| 16   | Sulphate          | IS:3025 part -24                     | mg/l. | 200                                    | 400               | 2.419           | - | - | - |
| 17   | Manganese         | APHA24th ed 3500Mn-B.                | Mg/l. | 0.1                                    | 0.3               | 0.00            | - | - | - |

Remark:-

- The report should not be produced partly or full without approval signatory authority of legal purpose.
- It is recommended that acceptable limit is to be implemented. Values in excess of those mentioned under "acceptable" render the water not suitable, but still may be tolerated in the absence of an alternative source but up to the limits indicated under the "permissible" limit in the absence of alternate source in column 7 above which the sources will have to be rejected.
- The results refer only to tested samples and parameters.
- Samples will be stored for a period of 15 days from date of issue of report.
- This Lab does not hold any responsibility for variation in results for samples kept on hold for wants of clarification.
- Results apply to the sample as received.7. Sampling not done by Lab staff.
- Agreeable is denoted by Agr.

Tested by

(Mani Shankar Roy)  
Lab Assistant

Principal  
Krishna Public School  
Tendua, Raipur (C.G.)

Report Reviewed & Approved by

Manager  
Krishna public School  
Tendua, Raipur (C.G.)

(Umesh Sahu)  
Authorized Signatory

जिला जल परीक्षण प्रयोगशाला  
लोकस्वास्थ्य यांत्रिकी विभाग रिंगरोड 1, रावणभाठा, रायपुर (छ.ग.)  
**DISTRICT WATER TESTING LABOARATORY, PHED.**  
**RING ROAD NO.1 RAWANBHANTA RAIPUR (C.G.)**  
email:- dwt1raipur@gmail.com

**BACTERIOLOGICAL - TEST REPORT (DRINKING WATER)**

|                                                                                             |                          |                  |                            |                        |
|---------------------------------------------------------------------------------------------|--------------------------|------------------|----------------------------|------------------------|
| Report No. DI/Phed/Rpr. : 349                                                               |                          |                  |                            |                        |
| Senders name & address:-<br><br>Principal<br>Krishna Public School<br>Tendua, Raipur (C.G.) | Senders letter no./Date  | 361 / 21.05.2025 | Sampled by & Date          | Customer<br>22.05.2025 |
|                                                                                             | DL receipt no.           | 349              | DL Receipt date            | 22.05.2025             |
|                                                                                             | Date of analysis started | 22.05.2025       | Date of analysis completed | 24.05.2025             |

**SAMPLE DETAILS**

| S.N. | Sample I.D.      | District / Block | City / Village | Habita. | Location/Source ID./GPS Identification |
|------|------------------|------------------|----------------|---------|----------------------------------------|
| 1.   | 349/2135/05/2025 | Raipur           | Raipur         | -       | Water Sample Of, Krishna Public School |
| -    | -                | -                | -              | -       | -                                      |
| -    | -                | -                | -              | -       | -                                      |
| -    | -                | -                | -              | -       | -                                      |

**DETAILS OF PARAMETERS THEIR TEST METHOD UNITS AND SPECIFICATION AS PER IS/APHA**

| S.N. | Parameters | Test method |            | As per IS-10500-2012 drinking water |                   | Result Of S.No. |   |   |   |
|------|------------|-------------|------------|-------------------------------------|-------------------|-----------------|---|---|---|
|      |            | Method      | Unit       | Acceptable Limit                    | Permissible Limit | 1               | - | - | - |
|      |            |             |            |                                     |                   |                 |   |   |   |
| 18   | E.Coli     | APHA / IS   | Cfu/100ml. | Nil                                 | Nil               | Nil             | - | - | - |

**Remark:-**

1. It is recommended that acceptable limit is to be implemented. Values in excess of those mentioned under "acceptable" render the water not suitable, but still may be tolerated in the absence of an alternative source but up to the limits indicated under the "permissible" limit in the absence of alternate source in column 7 above which the sources will have to be rejected.
2. The results refer only to tested samples and parameters.
3. Samples will be stored for a period of 15 days from date of issue of report.
4. This Lab does not hold any responsibility for variation in results for samples kept on hold for wants of clarification.
5. Results apply to the sample as received.
6. Sampling not done by Lab staff.

**Tested by**

(Mani Shankar Roy)  
Lab Assistant

**Report Reviewed & Approved by**

(Umesh Sahu)  
Authorized Signatory

Issue no.349 / Date- 26.05.2025

Page no. 03/03

..... End of Report .....

  
Principal  
Krishna Public School  
Tendua, Raipur (C.G.)

  
Manager  
Krishna public School  
Tendua, Raipur (C.G.)

जिला जल परीक्षण प्रयोगशाला  
लोकस्वास्थ्य यांत्रिकी विभाग रिंगरोड 1, रावणभाटा, रायपुर (छ.ग.)  
**DISTRICT WATER TESTING LABOARATORY, PHED.**  
**RING ROAD NO.1 RAWANBHANTA RAIPUR (C.G.)**  
email:- dwtlraipur@gmail.com

**INVOICE**

(Water Sample Analysis Charge)

Invoice no. 419

Date -26.05.2025

To

**Principal  
Krishna Public School  
Tendua, Raipur (C.G.)**

( Letter no. KPSTEN/25/361 दिनांक 21.05.2025

**DESCRIPTION**


| Sr. no. | parameters                                     | Fee in Rs. Per sample | Required parameter tick ( √ ) | Total fee in Rs. according to no. of sample = 01 |
|---------|------------------------------------------------|-----------------------|-------------------------------|--------------------------------------------------|
| 1       | Colour                                         | 1.00                  | √                             | 1.00                                             |
| 2       | Odour                                          | 1.00                  | √                             | 1.00                                             |
| 3       | Turbidity in NTU                               | 5.00                  | √                             | 5.00                                             |
| 4       | PH                                             | 1.00                  | √                             | 1.00                                             |
| 5       | Total Alkalinity as CaCO <sub>3</sub> in mg/l. | 20.00                 | √                             | 20.00                                            |
| 6       | TDS in mg/l.                                   | 1.00                  | √                             | 1.00                                             |
| 7       | Chloride in Mg/l.                              | 50.00                 | √                             | 50.00                                            |
| 8       | Nitrate in mg/l.                               | 50.00                 | √                             | 50.00                                            |
| 9       | Total Hardness as CaCO <sub>3</sub> in mg/l.   | 20.00                 | √                             | 20.00                                            |
| 10      | Iron in mg/l.                                  | 50.00                 | √                             | 50.00                                            |
| 11      | Sulphate mg/l.                                 | 50.00                 | √                             | 50.00                                            |
| 12      | Fluoride in mg/l.                              | 50.00                 | √                             | 50.00                                            |
| 13      | Residual Chlorine in mg/l.                     | 1.00                  | √                             | 1.00                                             |
| 14      | E.Coli                                         | 100.00                | √                             | 100.00                                           |
|         |                                                |                       | <b>Grand Total</b>            | <b>400.00</b>                                    |

[ Invoice Amount In words ₹. Four Hundred Rupees only]

  
**Chemist**  
District Water Testing Laboratory  
PHED Raipur (C.G.)

  
**Assistant Engineer**  
PHED Sub Div.  
Raipur (C.G.)

■ कार्यपालन अभियंता, लोक स्वास्थ्य यांत्रिकी खण्ड रायपुर, के नाम से चेक / डी.डी. का भूगतान करें।

  
**Principal**  
Krishna Public School  
Tendua, Raipur (C.G.)

  
**Manager**  
Krishna public School  
Tendua, Raipur (C.G.)